

RE:Urgent 134061/LO/2022 &134087/FO/2022 NCH

Hampson, Frances <fhampson@deloitte.co.uk>

Thu 13/10/2022 18:27

To: Angela Leckie <angela.leckie@manchester.gov.uk>; Fitzgerald, Eithne <eithnefitzgerald@deloitte.co.uk>

Hi Angela,

Yes, they are the same colour.

Kind regards,

Frances

Frances Hampson

Pronouns: she / her / hers

Assistant Director | FA - Real Assets Advisory | Deloitte LLP

D: +44 161 455 6766 | M: +44 7795 665721

fhampson@deloitte.co.uk | www.deloitte.co.uk/realestate

**The world isn't perfect. You don't have to be.**

Let's talk about mental health.

Deloitte is proud to have signed the [Mental Health at Work Commitment](#). Find out more about how we continue to promote an [open culture around mental health](#).

From: Angela Leckie <angela.leckie@manchester.gov.uk>

Sent: 13 October 2022 17:03

To: Fitzgerald, Eithne <eithnefitzgerald@deloitte.co.uk>

Cc: Hampson, Frances <fhampson@deloitte.co.uk>

Subject: [EXT] Re: Urgent 134061/LO/2022 &134087/FO/2022 NCH

Hi Eithne

Thanks for this can you just confirm the match of frame colour with the curtain walling frame as well.

Oh and that copy of the application form

Best Wishes

Angela

From: Fitzgerald, Eithne <eithnefitzgerald@deloitte.co.uk>

Sent: Thursday, October 13, 2022 4:56:00 PM

To: Angela Leckie <angela.leckie@manchester.gov.uk>

Cc: Hampson, Frances <fhampson@deloitte.co.uk>

Subject: RE:Urgent 134061/LO/2022 &134087/FO/2022 NCH

Hi Angela,

When the window hatch is opened back through 180 degrees, the window magnet will make contact with the steel plate on the glass frame. The magnet will be strong enough to hold the hatch in place under normal conditions, and the hatch would not be used where there are extremely high wind levels that might risk the hatch being pulled loose.

As per the sketch below, the hatch will "fold" back to the screen beside it and will stick out from the glass line by 84mm. The localised handle (which would be on the outside when the hatch is in the open position) would stick out a further 50mm.

This minimal distance is considered unlikely to catch passing pedestrians, and will not have any sharp edges ect. that would cause injury. It will also be ensured that no pedestrians are about to pass the opening when the hatch is being opened or closed, as both hatch and wall are glazed there will be good visibility of the entire external area.