D TO
OW

Temporary balustrade to void (pre-fit-out) by contractor

Floor Type D3

Floor Type D3

Floor Type D3

LMZ.009
UNIT L4

Floor Type D3

Floor Type D5

Floor Type D5

ZL – 2 – 4120

Freezer outdoor unit WINTSYS size M 1174x654x710mm , installed on anti vibration rubber mounts and on Big Foot system

Cold room chiller outdoor unit WINTSYS size S 942x654x710mm , installed on anti vibration rubber mounts above freezer room outdoor unit

PTS-165
Colour ref: Brilliant White

FLOOR GULLEY

Indicative Retail Plant Layout

LMZ.002
PLANT (L1, L2, L3 & L8)
FFL 38.225

Void for Unit L8 to plant above

LMZ.033
STAIR 02

PTS-231
Colour ref: Light Grey

Floor Type C1

FFL 38.225

L15.070
STAIR 02 LOBBY

Floo Type D4

FFL 38.225

Floor Type C5

PTS-161
Colour ref: Brilliant White

DRS-542
ID.MZ.19
Umbra Grey
RAL 7022

DRS-401
ED.MZ.02
Umbra Grey
RAL 7022

AC 1 and AC2 outdoor heat pump unit 12.5kW Fujitsu AOYG45KRTA 998Hx940Wx320Dmm , installed on anti vibration rubber mounts and on Big Foot system on top of each other

PTS-231
Colour ref: Light Grey

Colour ref: Brilliant White
PTS-161

PTS-231
Colour ref: Light Grey

Floor Type D4

PTS-161
Colour ref: Brilliant White

1 – 5130

LMZ.004
CLEANER

ZL – 4 – 4710

Floor Type A1

LMZ.005
REFUSE CHUTE

PTS-231
Colour ref: Light Grey

LMZ.017
STORE

LMZ.034
BOH CORRIDOR

2 – 5130

All builders work holes to be adequately fire stopped by main contractor

DRS-501
ID.MZ.17
Umbra Grey
RAL 7022

DRS-501
ID.MZ.18
Umbra Grey
RAL 7022

DRS-542
ID.MZ.21
Umbra Grey
RAL 7022

AC and Chiller/ Freezer Refrigerant pipe work to run on a galvanised tray system

RWP07

D09

D10

PTS-231
Colour ref: Light Grey

FFL 38.225

Floor Type D4

LMZ.037
BOH CORRIDOR 2

Floor Type D3

LMZ.001
UNIT L1

FFL 38.225

Temporar balustrade void (pre-f by contrac

AC and Chiller/ Freezer Refrigerant pipe work system enter into the unit

RWP06

1:50

1m 0 1m 2m 3m 4m 5m

Note:

Project Title:
Boo Manchester - Condensers Location & Route - REV A

Drawing Number:
Boo Manchester - Condensers Location & Route - REV A

Scale:
1:50 @ A2

Date:
09/06/2022

FAN RESCUE
Commercial kitchen and HVAC System Specialists
Ability House, Unit 129, 121 Brooker Road, Waltham Abbey EN9 1JH