


Mains operated interconnected smoke detector with battery backup to be installed in the newly formed bedroom, ground floor lounge, hall and 1st floor landing. (S)

Mains operated interconncted heat detector with battery backup to be installed in the kitchen. (H)



PROPOSED GROUND FLOOR LAYOUT.

REF - 004

Manchester Equipment and Adaptations Partnership (MEAP)
Unit 1,
29 Poland Street,
Ancoats,
Manchester,
M4 6AZ.

12 Lindsay Road
MANCHESTER
M19 2JG.

Drawn By:

AW

Date:

14.06.22.

Scale:

1:100

Drawing No:

REF - 004

