



Notes

1. This drawing is to be read in conjunction with the standard details, layouts, schedules and specifications for the development.
2. A 1% gradient represents a rise of 1m in 100m.
3. Left and right hand channels are on the left and right hand side respectively, with standing at zero chance and looking along the road.
4. Pipe sizes are stated in millimetres and levels are shown in metres A.O.D.
5. All pipes will have flexible joints with granular bedding (Class S) unless stated otherwise. Where 150mm concrete bed and surround is specified the concrete must be broken at the joint positions by the insertion of a 'flexcoll' collar.
6. Connections to existing sewers are to be SOFFIT TO SOFFIT Unless noted otherwise
7. All varied clay pipe to be EXTRA STRENGTH to B.S. 65. 1991.
8. Existing levels to be confirmed on site prior to commencement of works.
9. All concrete pipes to be CLASS 'M'.
10. Refer to additional drainage notes on RSK drawing 40-01 for further information.
11. 150mm Concrete Surround required on pipes with less than 1.2m cover
12. All connections to be soffit to soffit

P7	18.05.23	Updated to phase 2 re design	LGS	MAR	
P6	03.04.23	Revised to new planning layout Rev S	PO	AP	
	04.04.23	Memorise S15A added to the design			
F4	12.08.82	Revised following the addition of impermeable areas (05-105, 106-140 and 214-217) added to existing system	AP	MAR	
F3	03.05.82	Revised to new planning layout Rev L			
F2	30.11.21	Revised following comments from client	AP	MAR	
P1	20.10.21	Final Issue	AP	MAR	
Rev.	Date	Amendment	Drawn	Chkd	Appd.

			
LAND & DEVELOPMENT ENGINEERING LTD			
Spring Lodge 172 Chester Road Helsby Cheshire, WA6 6AR United Kingdom		Tel: +44 (0) 1928 720096 Fax: +44 (0) 1928 725633 Email: info@rsk.co.uk Web: www.rsk.co.uk	
Client			
			
Project Title			
Northenden Manchester			
Status			
DETAILED DESIGN			
Drawing Title			
Longitudinal Sections Sheet 2 of 4			
Drawn AP	Date Oct 21	Checked MAR Date Oct 21	Approved Date
Scale H=1:500 V=1:100		Orig Size A0	Dimensions m
Project No. 882187		Drawing File	
Drawing No. 40-02-02			Rev. P7

Scale 1:500

