

Zone name	SFP [W/(l/s)]										HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I			
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard	
3.47-03_Mac Suite	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.45-03_Mac Suite	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.44-03_Mac Suite	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.28-03_Garment Construction Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.17-03_Digital Workshop	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
2.CD06-02_Circ	-	-	-	1	-	-	-	-	-	-	N/A	
3.22-03_Laser Cutting	-	0.8	1.2	-	-	-	-	-	-	-	N/A	
3.23-03_Plastics Rm	-	-	-	1.1	-	-	-	-	-	-	N/A	
3.57-03_Training Salon - Beauty	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.ST02-04_Stair FE1	-	-	-	1	-	-	-	-	-	-	N/A	
4.39-04_Cln	-	-	-	1	-	-	-	-	-	-	N/A	
4.49-04_Rehearsal Rm - Drama	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.07-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.55-04_Welcome	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.52-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.22-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.19-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.15-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.12-04_Assessment Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.13-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.11-04_D. C.	-	-	-	1	-	-	-	-	-	-	N/A	
4.08-04_Changing	-	-	-	1	-	-	-	-	-	-	N/A	
04_Shower	-	-	-	1	-	-	-	-	-	-	N/A	
4.09-04_Changing	-	-	-	1	-	-	-	-	-	-	N/A	
4.05-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.02-04_Rehearsal Rm - Large	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.01-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.44-04_Rehearsal Rm - Drama	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
04_Shower	-	-	-	1	-	-	-	-	-	-	N/A	
4.43-04_Changing	-	-	-	1	-	-	-	-	-	-	N/A	
4.14-04_Rehearsal Rm - Flexible	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
0.CD08-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A	
0.09-00_TV Studio - FE	-	-	0.9	-	-	-	-	-	-	-	N/A	
0.08-00_Sound Studio	-	-	0.9	-	-	-	-	-	-	-	N/A	
0.06-00_Store	-	-	-	1	-	-	-	-	-	-	N/A	
0.05-00_Studio S	-	-	0.9	-	-	-	-	-	-	-	N/A	
0.CD04-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A	
0.04-00_LiveRoom S	-	-	0.9	-	-	-	-	-	-	-	N/A	
0.03-00_Studio S	-	-	0.9	-	-	-	-	-	-	-	N/A	
0.02-00_LiveRoom L	-	-	0.9	-	-	-	-	-	-	-	N/A	
0.CD03-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A	
0.01-00_Studio L	-	-	0.9	-	-	-	-	-	-	-	N/A	
0.71-00_Foley Store	-	-	-	1	-	-	-	-	-	-	N/A	

Zone name	SFP [W/(l/s)]									HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1		
0.CD25-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A
0.CD26-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A
0.62-00_Set & Prop St.	-	1	1	-	-	-	-	-	-	-	N/A
0.61-00_Paint Cosh	-	-	-	1	-	-	-	-	-	-	N/A
0.60-00_Scene Dock	-	1	1	-	-	-	-	-	-	-	N/A
0.59-00_A. Ch	-	-	-	1	-	-	-	-	-	-	N/A
0.58-00_Cross over	-	-	-	1	-	-	-	-	-	-	N/A
0.57-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A
0.55-00_Stage Kit.	-	-	-	1.1	-	-	-	-	-	-	N/A
0.54-00_Quick Chng	-	-	-	1	-	-	-	-	-	-	N/A
0.ST05-00_Theatre Stair	-	-	-	1	-	-	-	-	-	-	N/A
0.56-00_Dressing Room 1	-	-	-	1	-	-	-	-	-	-	N/A
00_W/C	-	-	-	1	-	-	-	-	-	-	N/A
0.48-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A
1.49-01_Film IT Suite	-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.47-01_Film IT Suite	-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.36-01_Dressing Room 3	-	-	-	1	-	-	-	-	-	-	N/A
1.35-01_Shower	-	-	-	1	-	-	-	-	-	-	N/A
1.31-01_Dressing Room 2	-	-	-	1	-	-	-	-	-	-	N/A
01_W/C	-	-	-	1	-	-	-	-	-	-	N/A
01_Shower	-	-	-	1	-	-	-	-	-	-	N/A
01_Dry Store	-	-	-	1	-	-	-	-	-	-	N/A
2.07-02_1-2-1	-	-	-	1.1	-	-	-	-	-	-	N/A
2.08-02_1-2-1	-	-	-	1.1	-	-	-	-	-	-	N/A
2.09-02_Adult Maintenance Lab Lvl3	-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.68-02_Seminar Room	-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.60-02_Cln	-	-	-	1	-	-	-	-	-	-	N/A
2.52-02_Meeting Rm	-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.48-02_Meeting Rm	-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.47-02_Meeting Rm	-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.07-03_Media Makeup	-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.62-03_Hospitality & Events Tch	-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.60-03_Mac Suite	-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.61-03_General Teaching	-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.39-03_DJ Classroom	-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.43-03_DJ Booth	-	-	-	1.1	-	-	-	-	-	-	N/A
3.42-03_DJ Booth	-	-	-	1.1	-	-	-	-	-	-	N/A
3.41-03_DJ Booth	-	-	-	1.1	-	-	-	-	-	-	N/A
3.40-03_DJ Booth	-	-	-	1.1	-	-	-	-	-	-	N/A
3.59-03_Laser Room	-	-	-	1.1	-	-	-	-	-	-	N/A
3.58-03_Treatment Room	-	-	-	1.1	-	-	-	-	-	-	N/A
3.49-03_Cln	-	-	-	1	-	-	-	-	-	-	N/A
3.63-03_Media Makeup - Hair	-	1.1	0.9	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]									HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I	Zone	Standard
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1		
3.66-03_General Teaching	-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.67-03_Dispensary	-	-	-	1	-	-	-	-	-	-	N/A
3.06-03_1-2-1	-	-	-	1.1	-	-	-	-	-	-	N/A
2.44-01_HE LRC & Social	-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.50-04_Rehearsal Rm - Film	-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.CD07-04_Circ.	-	-	-	1	-	-	-	-	-	-	N/A
4.42-04_Solo Singing	-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.33-04_Ensemble Singing	-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.45-04_Solo Singing	-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.46-04_Solo Singing	-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.47-04_Store	-	-	-	1	-	-	-	-	-	-	N/A
4.CD06-04_Circ.	-	-	-	1	-	-	-	-	-	-	N/A
1.32-01_Green Rm	-	-	-	1	-	-	-	-	-	-	N/A
3.48-03_Mac Suite	-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.43-00_Social	-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.24-01_Group Study	-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.04-01_Social Dining	-	-	-	1.1	-	-	-	-	-	-	N/A
1.05-01_Social/Work area	-	-	-	1.1	-	-	-	-	-	-	N/A
0.49-00_01_Studio Theatre	-	-	0.9	-	-	-	-	-	-	-	N/A
0.39-00_Bakery Kitchen_Oven	-	-	-	1.8	-	-	-	-	-	-	N/A
03_3D Workshop Specialist	-	0.8	1.2	-	-	-	-	-	-	-	N/A
3.21-03_Jewellery Workshop Specialist	-	0.8	1.2	-	-	-	-	-	-	-	N/A
3.21-03_Jewellery Workshop	-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.42-00_Access W/C	-	-	-	1	-	-	-	-	-	-	N/A
0.ST03-00_Stair Stair FE2	-	-	-	1	-	-	-	-	-	-	N/A
0.47-00_Cln	-	-	-	1	-	-	-	-	-	-	N/A
0.CD15-00_Circ.	-	-	-	1	-	-	-	-	-	-	N/A
0.CD16-00_Circ.	-	-	-	1	-	-	-	-	-	-	N/A
0.ST04-00_Stair HE2	-	-	-	1	-	-	-	-	-	-	N/A
0.68-00_Store	-	-	-	1	-	-	-	-	-	-	N/A
0.67-00_Water	-	-	-	1	-	-	-	-	-	-	N/A
0.CD20-00_Circ.	-	-	-	1	-	-	-	-	-	-	N/A
0.CD22-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A
0.CD24-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A
0.66-00_Equip Store	-	1	1	-	-	-	-	-	-	-	N/A
0.69-00_Foley Suite	-	-	0.9	-	-	-	-	-	-	-	N/A
0.70-00_Post Sound	-	-	0.9	-	-	-	-	-	-	-	N/A
0.79-00_Exam St.	-	-	-	1	-	-	-	-	-	-	N/A
0.78-00_Hygiene Room	-	-	-	1	-	-	-	-	-	-	N/A
0.80-00_Store	-	-	-	1	-	-	-	-	-	-	N/A
0.81-00_First Aid	-	-	-	1	-	-	-	-	-	-	N/A
0.82-00_W/C	-	-	-	1	-	-	-	-	-	-	N/A
0.CD01-00_Lobby	-	-	-	1	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I		
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
0.83-00_W/C		-	-	-	1	-	-	-	-	-	-	N/A
0.ST01-00_Stair HE 1		-	-	-	1	-	-	-	-	-	-	N/A
0.CD02-00_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
0.CD09-00_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
0.16-00_Acc W/C		-	-	-	1	-	-	-	-	-	-	N/A
0.17-00_Female W/C		-	-	-	1	-	-	-	-	-	-	N/A
0.07-00_ST		-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.CD05-00_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
0.22-00_Quiet Room		-	-	-	1.1	-	-	-	-	-	-	N/A
0.24-00_1-2-1		-	-	-	1.1	-	-	-	-	-	-	N/A
0.26-00_1-2-1		-	-	-	1.1	-	-	-	-	-	-	N/A
0.25-00_1-2-1		-	-	-	1.1	-	-	-	-	-	-	N/A
0.23-00_Student Hub		-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.29-00_W/C		-	-	-	1	-	-	-	-	-	-	N/A
0.CD12-00_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
0.ST02-00_Stair FE1		-	-	-	1	-	-	-	-	-	-	N/A
0.30-00_01_Front Reception & Display-		-	-	-	1.1	-	-	-	-	-	-	N/A
0.31-00_Front Reception		-	1	1	-	-	-	-	-	-	-	N/A
0.32-00_Reception & Box Office		-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.33-00_Back Office		-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.37-00_W/C		-	-	-	1	-	-	-	-	-	-	N/A
0.36-00_W/C		-	-	-	1	-	-	-	-	-	-	N/A
0.34-00_Cash Off.		-	-	-	1.1	-	-	-	-	-	-	N/A
0.38-00_Production Kitchen		-	-	-	1.8	-	-	-	-	-	-	N/A
0.35-00_Restaurant		-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.CD13-00_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
1.ST03-01_Stair FE2		-	-	-	1	-	-	-	-	-	-	N/A
1.23-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.CD07-01_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
1.21-01_Cln		-	-	-	1	-	-	-	-	-	-	N/A
1.CD05-01_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
1.22-01_CLICK + Repair		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.16-01_LRC Staff		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.20-01_Multi Faith		-	-	-	1.1	-	-	-	-	-	-	N/A
1.CD06-01_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
1.17-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.18-01_Wash Room		-	-	-	1	-	-	-	-	-	-	N/A
1.19-01_Wash Room		-	-	-	1	-	-	-	-	-	-	N/A
1.14-01_LRC		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.27-01_Control Room		-	-	-	1.1	-	-	-	-	-	-	N/A
1.29-01_1-2-1		-	-	-	1.1	-	-	-	-	-	-	N/A
1.28-01_Store		-	-	-	1	-	-	-	-	-	-	N/A
1.26-01_Lobby		-	-	-	1	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I		
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
1.40-01_Laundry		-	-	-	1	-	-	-	-	-	-	N/A
1.38-01_St		-	-	-	1	-	-	-	-	-	-	N/A
1.37-01_St		-	-	-	1	-	-	-	-	-	-	N/A
1.ST05-01_Theatre Stair		-	-	-	1	-	-	-	-	-	-	N/A
1.41-01_St		-	-	-	1	-	-	-	-	-	-	N/A
1.CD09-01_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
1.56-01_Staff		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.48-01_Production Meeting		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.45-01_Edit Suite		-	-	-	1.1	-	-	-	-	-	-	N/A
1.46-01_Edit Suite		-	-	-	1.1	-	-	-	-	-	-	N/A
1.43-01_Edit Suite		-	-	-	1.1	-	-	-	-	-	-	N/A
1.44-01_Edit Suite		-	-	-	1.1	-	-	-	-	-	-	N/A
1.42-01_Edit Suite		-	-	-	1.1	-	-	-	-	-	-	N/A
1.50-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.CD11-01_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
1.55-01_Theory Room		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.51-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.52-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.54-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.53-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.ST04-01_Stair HE2		-	-	-	1	-	-	-	-	-	-	N/A
1.01-01_HE Reception		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.61-01_Future U		-	-	-	1.1	-	-	-	-	-	-	N/A
1.60-01_Kit. Store		-	-	-	1	-	-	-	-	-	-	N/A
1.62-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.63-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.ST01-01_Stair HE 1		-	-	-	1	-	-	-	-	-	-	N/A
1.64-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.CD12-01_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
1.03-01_Future U		-	-	-	1.1	-	-	-	-	-	-	N/A
1.02-01_Future U		-	-	-	1.1	-	-	-	-	-	-	N/A
1.CD01-01_Circ.		-	-	-	1.1	-	-	-	-	-	-	N/A
1.08-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
1.10-01_Cln		-	-	-	1	-	-	-	-	-	-	N/A
1.09-01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
01_Changing		-	-	-	1	-	-	-	-	-	-	N/A
01_W/C		-	-	-	1	-	-	-	-	-	-	N/A
01_Office		-	-	-	1.1	-	-	-	-	-	-	N/A
1.CD04-01_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
1.CD02-01_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
2.ST03-02_Stair FE2		-	-	-	1	-	-	-	-	-	-	N/A
2.33-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.CD08-02_Lobby		-	-	-	1	-	-	-	-	-	-	N/A

Zone name	SFP [W/(I/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I		
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
2.37-02_Cln		-	-	-	1	-	-	-	-	-	-	N/A
2.35-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.34-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.61-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.CD10-02_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
2.ST04-02_Stair HE2		-	-	-	1	-	-	-	-	-	-	N/A
2.66-02_Staff		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.62-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.63-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.65-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.64-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.69-02_Security		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.73-02_CCNA Patch Rm		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.70-02_Security Operations		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.72-02_CCNA		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.74-02_Theory Room		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.76-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.CD11-02_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
2.77-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.ST01-02_Stair HE1		-	-	-	1	-	-	-	-	-	-	N/A
2.02-02_Mac Suite		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.04-02_Screen Print		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.03-02_Wet Rm		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.10-02_Adult Maintenance Lab		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.14-02_Hygiene Room		-	-	-	1	-	-	-	-	-	-	N/A
2.13-02_Admin		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.11-02_HE Admin		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.CD05-02_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
2.CD04-02_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
2.22-02_Principalship		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.21-02_Principalship Admin		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.30-02_FE Maintenance Lab		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.43-02_Store		-	-	-	1	-	-	-	-	-	-	N/A
2.42-02_1-2-1		-	-	-	1.1	-	-	-	-	-	-	N/A
2.53-02_Radio Studio		-	-	0.9	-	-	-	-	-	-	-	N/A
2.45-02_Meeting Rm		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.46-02_HE Kitchenette		-	-	-	1.1	-	-	-	-	-	-	N/A
2.57-02_Mac Suite		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.49-02_Meeting Rm		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.55-02_TV & Film		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.50-02_HE LRC & Social		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.51-02_Meeting Rm		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.59-02_3D Games		-	1.1	0.9	-	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]										HR efficiency	
ID of system type	A	B	C	D	E	F	G	H	I			
Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard	
3.29-03_Fashion & Pattern Cutting	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.32-03_W/C	-	-	-	1	-	-	-	-	-	-	N/A	
3.CD08-03_Lobby	-	-	-	1	-	-	-	-	-	-	N/A	
3.ST03-03_Stair FE2	-	-	-	1	-	-	-	-	-	-	N/A	
3.37-03_Cln	-	-	-	1	-	-	-	-	-	-	N/A	
3.34-03_W/C	-	-	-	1	-	-	-	-	-	-	N/A	
3.33-03_W/C	-	-	-	1	-	-	-	-	-	-	N/A	
3.50-03_W/C	-	-	-	1	-	-	-	-	-	-	N/A	
3.ST04-03_Stair HE2	-	-	-	1	-	-	-	-	-	-	N/A	
3.CD10-03_Lobby	-	-	-	1	-	-	-	-	-	-	N/A	
3.55-03_Staff	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.CD09-03_Circ	-	-	-	1	-	-	-	-	-	-	N/A	
3.64-03_Photo	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.65-03_Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.69-03_W/C	-	-	-	1	-	-	-	-	-	-	N/A	
3.68-03_SH	-	-	-	1	-	-	-	-	-	-	N/A	
3.ST01-03_Stair HE1	-	-	-	1	-	-	-	-	-	-	N/A	
3.CD11-03_Lobby	-	-	-	1	-	-	-	-	-	-	N/A	
3.70-03_W/C	-	-	-	1	-	-	-	-	-	-	N/A	
3.01-03_Special Effects Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.05-03_Spray Booth	-	0.8	1.2	-	-	-	-	-	-	-	N/A	
3.04-03_Store	-	-	-	1	-	-	-	-	-	-	N/A	
3.CD01-03_Circ.	-	-	-	1	-	-	-	-	-	-	N/A	
3.08-03_Photography Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.10-03_Darkrm - Wet	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.09-03_Darkrm - Processing	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.11-03_Photography Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.13-03_Photography St	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.12-03_Staff /kitchen	-	-	-	1.1	-	-	-	-	-	-	N/A	
3.CD06-03_Lobby	-	-	-	1	-	-	-	-	-	-	N/A	
3.18-03_Textile Print Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.19-03_Storage	-	-	-	1	-	-	-	-	-	-	N/A	
3.20-03_Print Making Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.CD04-03_Circ.	-	-	-	1	-	-	-	-	-	-	N/A	
3.26-03_Kiln Room	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.25-03_Cold Storage	-	-	-	1.1	-	-	-	-	-	-	N/A	
3.24-03_Ceramics Studio	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
3.CD07-03_Circ.	-	-	-	1	-	-	-	-	-	-	N/A	
3.30-03_3D Workshop	-	1.1	0.9	-	-	-	-	-	-	-	N/A	
4.24-04_W/C	-	-	-	1	-	-	-	-	-	-	N/A	
4.CD05-04_Lobby	-	-	-	1	-	-	-	-	-	-	N/A	
4.26-04_Cln	-	-	-	1	-	-	-	-	-	-	N/A	
4.23-04_W/C	-	-	-	1	-	-	-	-	-	-	N/A	

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I		
	Standard value	0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
4.25-04_W/C		-	-	-	1	-	-	-	-	-	-	N/A
4.32-04_Rehearsal Rm - Flexible		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.31-04_General Teaching		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.30-04_General Teaching		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.29-04_General Teaching		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.28-04_Computer Suite		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.ST04-04_Stair HE2		-	-	-	1	-	-	-	-	-	-	N/A
4.34-04_W/C		-	-	-	1	-	-	-	-	-	-	N/A
4.CD09-04_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
4.40-04_Ensemble Singing		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.38-04_A. Ch		-	-	-	1	-	-	-	-	-	-	N/A
4.37-04_W/C		-	-	-	1	-	-	-	-	-	-	N/A
4.36-04_W/C		-	-	-	1	-	-	-	-	-	-	N/A
4.35-04_W/C		-	-	-	1	-	-	-	-	-	-	N/A
04_Shower		-	-	-	1	-	-	-	-	-	-	N/A
4.41-04_Changing		-	-	-	1	-	-	-	-	-	-	N/A
4.51-04_1-2-1		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.54-04_Audio Live		-	-	0.9	-	-	-	-	-	-	-	N/A
4.53-04_Audio Control		-	-	0.9	-	-	-	-	-	-	-	N/A
4.58-04_W/C		-	-	-	1	-	-	-	-	-	-	N/A
4.56-04_W/C		-	-	-	1	-	-	-	-	-	-	N/A
4.CD10-04_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
4.57-04_W/C		-	-	-	1	-	-	-	-	-	-	N/A
4.ST01-04_Stair HE1		-	-	-	1	-	-	-	-	-	-	N/A
4.03-04_Rehearsal Rm - Flexible		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.04-04_Rehearsal Rm - Flexible		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.06-04_Rehearsal Rm - Flexible		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.CD03-04_Lobby		-	-	-	1	-	-	-	-	-	-	N/A
4.CD02-04_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
4.17-04_Stu Ex.		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.18-04_Singing		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.20-04_Ensemble Singing		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.CD04-04_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
4.21-04_Store		-	-	-	1	-	-	-	-	-	-	N/A
4.48-04_Staff		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.CD08-04_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
0.40-00_Kitchen St		-	-	-	1	-	-	-	-	-	-	N/A
0.41-00_LV		-	-	-	1	-	-	-	-	-	-	N/A
0.45-00_Changing		-	-	-	1	-	-	-	-	-	-	N/A
00_Shower		-	-	-	1	-	-	-	-	-	-	N/A
00_Shower		-	-	-	1	-	-	-	-	-	-	N/A
0.46-00_Changing		-	-	-	1	-	-	-	-	-	-	N/A
0.CD21-00_Stair		-	-	-	1	-	-	-	-	-	-	N/A

Zone name	SFP [W/(l/s)]										HR efficiency	
	ID of system type	A	B	C	D	E	F	G	H	I		
Standard value		0.3	1.1	0.5	1.9	1.6	0.5	1.1	0.5	1	Zone	Standard
0.64-00_Store		-	-	-	1	-	-	-	-	-	-	N/A
1.39-01_Wardrobe Store		-	1	1	-	-	-	-	-	-	-	N/A
1.58-01_HE Union		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.59-01_Future-U		-	1.1	0.9	-	-	-	-	-	-	-	N/A
2.75-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.75-02_W/C		-	-	-	1	-	-	-	-	-	-	N/A
2.06-02_Software Development		-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.31-03_Storage		-	-	-	1	-	-	-	-	-	-	N/A
3.27-03_Storage		-	-	-	1	-	-	-	-	-	-	N/A
4.ST03-04_Stair FE2		-	-	-	1	-	-	-	-	-	-	N/A
4.16-04_Staff		-	1.1	0.9	-	-	-	-	-	-	-	N/A
4.CD01-04_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
3.03-03_Fibre Glass Workshop Specialist		-	0.8	1.2	-	-	-	-	-	-	-	N/A
3.03-03_Fibre Glass Workshop		-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.02-03_Encapsulation Specialist		-	0.8	1.2	-	-	-	-	-	-	-	N/A
3.02-03_Encapsulation		-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.65-00_01_Film Studio		-	-	0.9	-	-	-	-	-	-	-	N/A
1.57-01_HE Social		-	1.1	0.9	-	-	-	-	-	-	-	N/A
3.35-03_Art Studios & Drawing Room		-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.39-00_Bakery Kitchen		-	-	-	1.8	-	-	-	-	-	-	N/A
1.15-01_Quiet Study		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.06-01_Social Dining		-	1.1	0.9	-	-	-	-	-	-	-	N/A
1.07-01_Kitchen		-	-	-	1.8	-	-	-	-	-	-	N/A
3.46-03_HE Art studios & Digi		-	1.1	0.9	-	-	-	-	-	-	-	N/A
0.67-00_01_Teaching Studio		-	-	0.9	-	-	-	-	-	-	-	N/A
0.CD18-00_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
0.CD17-00_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
1.CD10-01_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
0.27-00_Social		-	-	-	1.1	-	-	-	-	-	-	N/A
0.18-00_Male W/C		-	-	-	1	-	-	-	-	-	-	N/A
0.CD08-00_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
0.CD11-00_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
0.CD19-00_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
0.CD23-00_Circ.		-	-	-	1	-	-	-	-	-	-	N/A
00_01_West Entrance		-	-	-	1.1	-	-	-	-	-	-	N/A
2.CD07-02_Circ		-	-	-	1	-	-	-	-	-	-	N/A
2.CD09-02_Circ		-	-	-	1	-	-	-	-	-	-	N/A

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
Standard value		60	60	22	
0.CD14-00_Escape		-	90	-	60
0.EX01-00_DNO SubStation		90	-	-	108

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
0.EX02-00_Private Transformer		90	-	-	108
0.28-00_IT Hub		90	-	-	167
0.21-00_Control Room		90	-	-	243
0.CD10-00_Lobby		-	90	-	46
0.19-00_Control Room		90	-	-	240
0.11-00_LiveRoom - S		90	-	-	236
0.10-00_Control Room		90	-	-	399
0.20-00_LiveRoom - L		90	-	-	292
0.CD07-00_Lobby		-	90	-	45
0.77-00_Cln		90	-	-	22
0.72-00_Make-Up		90	-	-	198
0.63-00_Machines Room		90	-	-	729
0.76-00_Practice Room		90	-	-	157
0.73-00_Band Room		90	-	-	330
0.74-00_Practice Room		90	-	-	139
0.CD06-00_Lobby		-	90	-	34
0.15-00_Practice Room		90	-	-	148
0.75-00_Practice Room		90	-	-	146
0.14-00_Practice Room		90	-	-	148
0.12-00_Band Room		90	-	-	268
0.13-00_Practice Room		90	-	-	141
01_Control & Dimmer Room		90	-	-	562
1.ST02-01_Stair FE1		-	90	-	89
1.11-01_IT Hub		90	-	-	104
1.13-01_W/C		-	90	-	59
1.12-01_W/C		-	90	-	35
00_Lobby ???		-	90	-	45
0.50-00_Bar		-	90	-	131
00_Lobby ???		-	90	-	45
0.51-00_Lobby		-	90	-	26
0.52-00_Lobby		-	90	-	26
0.53-00_01_Main Theatre		90	-	-	1698
1.34-01_Shower		-	90	-	13
1.33-01_Shower		-	90	-	12
1.CD08-01_Circ.		-	90	-	72
2.32-02_PC / Games Design		90	-	-	477
2.31-02_PC / Games Design		90	-	-	396
2.28-02_Staff		90	-	-	326
2.27-02_PC Suite / Theory		90	-	-	344
2.25-02_PC Suite / Theory		90	-	-	346
2.23-02_PC Suite / Theory		90	-	-	347
2.15-02_IT Hub		90	-	-	104
2.17-02_W/C		-	90	-	59

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
02_W/C		-	90	-	35
2.ST02-02_Stair FE1		-	90	-	98
2.29-02_PC Suite		90	-	-	321
2.26-02_PC Suite		90	-	-	312
2.24-02_PC Suite		90	-	-	302
2.67-02_W/C		-	90	-	46
2.58-02_Mac Suite		90	-	-	348
2.56-02_Mac Suite		90	-	-	356
2.54-02_Mac Suite		90	-	-	354
2.41-02_Mac Suite		90	-	-	357
2.40-02_PC Suite		90	-	-	354
2.71-02_Reprographics		90	-	-	175
2.39-02_PC Suite		90	-	-	298
2.36-02_Boardroom		90	-	-	225
2.18-02_Edit Suite		90	-	-	56
2.19-02_Edit Suite		90	-	-	81
2.20-02_Edit Suite		90	-	-	78
2.12-02_Admin		90	-	-	145
2.05-02_Operation Systems Lab		90	-	-	528
2.CD01-02_Circ.		-	90	-	378
2.01-02_Mac Suite		90	-	-	455
3.14-03_IT Hub		90	-	-	104
3.16-03_W/C		-	90	-	59
3.15-03_W/C		-	90	-	35
3.ST02-03_Stair FE1		-	90	-	98
3.56-03_W/C		-	90	-	46
3.47-03_Mac Suite		90	-	-	356
3.45-03_Mac Suite		90	-	-	354
3.44-03_Mac Suite		90	-	-	357
3.28-03_Garment Construction Studio		90	-	-	842
3.17-03_Digital Workshop		90	-	-	484
2.CD06-02_Circ		-	90	-	130
3.22-03_Laser Cutting		90	-	-	153
3.23-03_Plastics Rm		90	-	-	19
3.57-03_Training Salon - Beauty		90	-	-	897
4.10-04_IT Hub		90	-	-	141
4.ST02-04_Stair FE1		-	90	-	114
4.39-04_Cln		90	-	-	12
4.49-04_Rehearsal Rm - Drama		90	-	-	306
4.07-04_Rehearsal Rm - Flexible		90	-	-	471
4.55-04_Welcome		-	90	-	104
4.52-04_Rehearsal Rm - Flexible		90	-	-	450
4.22-04_Rehearsal Rm - Flexible		90	-	-	516