

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
4.19-04_Rehearsal Rm - Flexible		90	-	-	569
4.15-04_Rehearsal Rm - Flexible		90	-	-	562
4.12-04_Assessment Studio		90	-	-	575
4.13-04_Rehearsal Rm - Flexible		90	-	-	565
4.11-04_D. C.		-	90	-	95
4.08-04_Changing		-	90	-	95
04_Shower		-	90	-	29
4.09-04_Changing		-	90	-	129
4.05-04_Rehearsal Rm - Flexible		90	-	-	528
4.02-04_Rehearsal Rm - Large		90	-	-	584
4.01-04_Rehearsal Rm - Flexible		90	-	-	541
4.44-04_Rehearsal Rm - Drama		90	-	-	309
04_Shower		-	90	-	12
4.43-04_Changing		-	90	-	157
4.14-04_Rehearsal Rm - Flexible		90	-	-	474
0.CD08-00_Lobby		-	90	-	30
0.09-00_TV Studio - FE		90	-	-	386
0.08-00_Sound Studio		90	-	-	156
0.06-00_Store		90	-	-	23
0.05-00_Studio S		90	-	-	160
0.CD04-00_Lobby		-	90	-	52
0.04-00_LiveRoom S		90	-	-	152
0.03-00_Studio S		90	-	-	155
0.02-00_LiveRoom L		90	-	-	217
0.CD03-00_Lobby		-	90	-	50
0.01-00_Studio L		90	-	-	349
0.71-00_Foley Store		90	-	-	21
0.CD25-00_Lobby		-	90	-	31
0.CD26-00_Lobby		-	90	-	27
0.62-00_Set & Prop St.		90	-	-	39
0.61-00_Paint Cosh		90	-	-	15
0.60-00_Scene Dock		90	-	-	110
0.59-00_A. Ch		-	90	-	57
0.58-00_Cross over		-	90	-	69
0.57-00_Lobby		-	90	-	36
0.55-00_Stage Kit.		-	90	-	60
0.54-00_Quick Chng		-	90	-	64
0.ST05-00_Theatre Stair		-	90	-	45
0.56-00_Dressing Room 1		-	90	-	114
00_W/C		-	90	-	47
0.48-00_Lobby		-	90	-	32
1.49-01_Film IT Suite		90	-	-	305
1.47-01_Film IT Suite		90	-	-	352

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
1.36-01_Dressing Room 3		-	90	-	124
1.35-01_Shower		-	90	-	14
1.31-01_Dressing Room 2		-	90	-	126
01_W/C		-	90	-	57
01_Shower		-	90	-	15
01_Dry Store		90	-	-	19
2.07-02_1-2-1		90	-	-	111
2.08-02_1-2-1		90	-	-	108
2.09-02_Adult Maintenance Lab Lvl3		90	-	-	429
2.68-02_Seminar Room		90	-	-	411
2.60-02_Cln		90	-	-	9
2.52-02_Meeting Rm		90	-	-	156
2.48-02_Meeting Rm		90	-	-	150
2.47-02_Meeting Rm		90	-	-	135
3.07-03_Media Makeup		90	-	-	881
3.62-03_Hospitality & Events Tch		90	-	-	285
3.60-03_Mac Suite		90	-	-	344
3.61-03_General Teaching		90	-	-	258
3.39-03_DJ Classroom		90	-	-	240
3.43-03_DJ Booth		90	-	-	84
3.42-03_DJ Booth		90	-	-	80
3.41-03_DJ Booth		90	-	-	80
3.40-03_DJ Booth		90	-	-	80
3.59-03_Laser Room		90	-	-	153
3.58-03_Treatment Room		90	-	-	153
3.49-03_Cln		90	-	-	9
3.63-03_Media Makeup - Hair		90	-	-	549
3.66-03_General Teaching		90	-	-	235
3.67-03_Dispensary		90	-	-	18
3.06-03_1-2-1		90	-	-	116
2.44-01_HE LRC & Social		90	-	-	1734
4.50-04_Rehearsal Rm - Film		90	-	-	350
4.CD07-04_Circ.		-	90	-	110
4.42-04_Solo Singing		90	-	-	141
4.33-04_Ensemble Singing		90	-	-	248
4.45-04_Solo Singing		90	-	-	142
4.46-04_Solo Singing		90	-	-	152
4.47-04_Store		90	-	-	26
4.CD06-04_Circ.		-	90	-	115
1.32-01_Green Rm		90	-	-	19
3.48-03_Mac Suite		90	-	-	348
0.43-00_Social		90	-	-	443
1.24-01_Group Study		-	90	-	222

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
1.04-01_Social Dining		-	90	-	317
1.05-01_Social/Work area		90	-	-	795
0.49-00_01_Studio Theatre		90	-	-	1028
0.39-00_Bakery Kitchen_Oven		-	90	-	55
03_3D Workshop Specialist		90	-	-	27
3.21-03_Jewellery Workshop Specialist		90	-	-	28
3.21-03_Jewellery Workshop		90	-	-	667
0.42-00_Access W/C		-	90	-	53
0.ST03-00_Stair Stair FE2		-	90	-	81
0.47-00_Cln		90	-	-	7
0.44-00_IT Hub		90	-	-	108
0.CD15-00_Circ.		-	90	-	18
0.CD16-00_Circ.		-	90	-	92
0.ST04-00_Stair HE2		-	90	-	67
0.68-00_Store		90	-	-	19
0.67-00_Water		90	-	-	148
0.CD20-00_Circ.		-	90	-	116
0.CD22-00_Lobby		-	90	-	26
0.CD24-00_Lobby		-	90	-	27
0.66-00_Equip Store		90	-	-	73
0.69-00_Foley Suite		90	-	-	228
0.70-00_Post Sound		90	-	-	358
0.79-00_Exam St.		90	-	-	16
0.78-00_Hygiene Room		90	-	-	20
0.80-00_Store		90	-	-	21
0.81-00_First Aid		90	-	-	15
0.82-00_W/C		-	90	-	57
0.CD01-00_Lobby		-	90	-	27
0.83-00_W/C		-	90	-	56
0.ST01-00_Stair HE 1		-	90	-	67
0.CD02-00_Circ.		-	90	-	154
0.CD09-00_Lobby		-	90	-	48
0.16-00_Acc W/C		-	90	-	53
0.17-00_Female W/C		-	90	-	153
0.07-00_ST		90	-	-	110
0.CD05-00_Circ.		-	90	-	83
0.22-00_Quiet Room		90	-	-	161
0.24-00_1-2-1		90	-	-	131
0.26-00_1-2-1		90	-	-	140
0.25-00_1-2-1		90	-	-	134
0.23-00_Student Hub		-	90	-	305
0.29-00_W/C		-	90	-	35
0.CD12-00_Lobby		-	90	-	63

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
0.ST02-00_Stair FE1		-	90	-	91
0.30-00_01_Front Reception & Display		-	90	-	121
0.31-00_Front Reception		-	90	-	68
0.32-00_Reception & Box Office		-	90	15	57
0.33-00_Back Office		90	-	-	170
0.37-00_W/C		-	90	-	33
0.36-00_W/C		-	90	-	48
0.34-00_Cash Off.		90	-	-	134
0.38-00_Production Kitchen		-	90	-	862
0.35-00_Restaurant		-	90	-	384
0.CD13-00_Lobby		-	90	-	66
1.ST03-01_Stair FE2		-	90	-	76
1.23-01_W/C		-	90	-	56
1.CD07-01_Lobby		-	90	-	67
1.21-01_Cln		90	-	-	8
1.CD05-01_Circ.		-	90	-	157
1.22-01_CLICK + Repair		90	-	-	601
1.16-01_LRC Staff		90	-	-	153
1.20-01_Multi Faith		-	90	-	58
1.CD06-01_Circ.		-	90	-	32
1.17-01_W/C		-	90	-	34
1.18-01_Wash Room		-	90	-	33
1.19-01_Wash Room		-	90	-	33
1.14-01_LRC		90	-	-	1545
1.27-01_Control Room		90	-	-	160
1.25-01_IT Hub		90	-	-	109
1.29-01_1-2-1		90	-	-	131
1.28-01_Store		90	-	-	8
1.26-01_Lobby		-	90	-	23
1.40-01_Laundry		-	90	-	116
1.38-01_St		90	-	-	6
1.37-01_St		90	-	-	8
1.ST05-01_Theatre Stair		-	90	-	61
1.41-01_St		90	-	-	8
1.CD09-01_Circ.		-	90	-	106
1.56-01_Staff		90	-	-	196
1.48-01_Production Meeting		90	-	-	212
1.45-01_Edit Suite		90	-	-	83
1.46-01_Edit Suite		90	-	-	84
1.43-01_Edit Suite		90	-	-	81
1.44-01_Edit Suite		90	-	-	81
1.42-01_Edit Suite		90	-	-	80
1.50-01_W/C		-	90	-	60

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
1.CD11-01_Lobby		-	90	-	59
1.55-01_Theory Room		90	-	-	304
1.51-01_W/C		-	90	-	50
1.52-01_W/C		-	90	-	36
1.54-01_W/C		-	90	-	36
1.53-01_W/C		-	90	-	36
1.ST04-01_Stair HE2		-	90	-	85
1.01-01_HE Reception		-	90	15	64
1.61-01_Future U		-	90	-	44
1.60-01_Kit. Store		90	-	-	8
1.62-01_W/C		-	90	-	32
1.63-01_W/C		-	90	-	55
1.ST01-01_Stair HE 1		-	90	-	81
1.64-01_W/C		-	90	-	50
1.CD12-01_Lobby		-	90	-	64
1.03-01_Future U		-	90	-	45
1.02-01_Future U		-	90	-	48
1.CD01-01_Circ.		-	90	-	317
1.08-01_W/C		-	90	-	104
1.10-01_Cln		90	-	-	8
1.09-01_W/C		-	90	-	105
01_Changing		-	90	-	55
01_W/C		-	90	-	42
01_Office		90	-	-	49
1.CD04-01_Lobby		-	90	-	32
1.CD02-01_Circ.		-	90	-	265
2.ST03-02_Stair FE2		-	90	-	81
2.33-02_W/C		-	90	-	52
2.CD08-02_Lobby		-	90	-	68
2.37-02_Cln		90	-	-	5
2.38-02_IT Hub		90	-	-	120
2.35-02_W/C		-	90	-	111
2.34-02_W/C		-	90	-	125
2.61-02_W/C		-	90	-	55
2.CD10-02_Lobby		-	90	-	60
2.ST04-02_Stair HE2		-	90	-	89
2.66-02_Staff		90	-	-	353
2.62-02_W/C		-	90	-	50
2.63-02_W/C		-	90	-	36
2.65-02_W/C		-	90	-	35
2.64-02_W/C		-	90	-	35
2.69-02_Security		90	-	-	429
2.73-02_CCNA Patch Rm		90	-	-	179

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
2.70-02_Security Operations		90	-	-	171
2.72-02_CCNA		90	-	-	404
2.74-02_Theory Room		90	-	-	303
2.76-02_W/C		-	90	-	55
2.CD11-02_Lobby		-	90	-	56
2.77-02_W/C		-	90	-	57
2.ST01-02_Stair HE1		-	90	-	75
2.02-02_Mac Suite		90	-	-	391
2.04-02_Screen Print		90	-	-	175
2.03-02_Wet Rm		90	-	-	156
2.10-02_Adult Maintenance Lab		90	-	-	437
2.14-02_Hygiene Room		90	-	-	20
2.13-02_Admin		90	-	-	268
2.11-02_HE Admin		90	-	-	512
2.CD05-02_Lobby		-	90	-	32
2.CD04-02_Circ.		-	90	-	100
2.22-02_Principalship		90	-	-	471
2.21-02_Principalship Admin		90	-	-	326
2.30-02_FE Maintenance Lab		90	-	-	316
2.43-02_Store		90	-	-	14
2.42-02_1-2-1		90	-	-	110
2.53-02_Radio Studio		90	-	-	161
2.45-02_Meeting Rm		90	-	-	122
2.46-02_HE Kitchenette		-	90	-	56
2.57-02_Mac Suite		90	-	-	271
2.49-02_Meeting Rm		90	-	-	153
2.55-02_TV & Film		90	-	-	430
2.50-02_HE LRC & Social		90	-	-	381
2.51-02_Meeting Rm		90	-	-	155
2.59-02_3D Games		90	-	-	478
3.29-03_Fashion & Pattern Cutting		90	-	-	836
3.32-03_W/C		-	90	-	58
3.CD08-03_Lobby		-	90	-	68
3.ST03-03_Stair FE2		-	90	-	75
3.37-03_Cln		90	-	-	5
3.38-03_IT Hub		90	-	-	120
3.34-03_W/C		-	90	-	111
3.33-03_W/C		-	90	-	125
3.50-03_W/C		-	90	-	58
3.ST04-03_Stair HE2		-	90	-	88
3.CD10-03_Lobby		-	90	-	61
3.55-03_Staff		90	-	-	351
3.CD09-03_Circ		-	90	-	193

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
3.64-03_Photo		90	-	-	523
3.65-03_Studio		90	-	-	314
3.69-03_W/C		-	90	-	55
3.68-03_SH		-	90	-	17
3.ST01-03_Stair HE1		-	90	-	77
3.CD11-03_Lobby		-	90	-	60
3.70-03_W/C		-	90	-	36
3.01-03_Special Effects Studio		90	-	-	997
3.05-03_Spray Booth		90	-	-	128
3.04-03_Store		90	-	-	17
3.CD01-03_Circ.		-	90	-	295
3.08-03_Photography Studio		90	-	-	800
3.10-03_Darkrm - Wet		90	-	-	564
3.09-03_Darkrm - Processing		90	-	-	335
3.11-03_Photography Studio		90	-	-	723
3.13-03_Photography St		90	-	-	183
3.12-03_Staff /kitchen		-	90	-	393
3.CD06-03_Lobby		-	90	-	32
3.18-03_Textile Print Studio		90	-	-	887
3.19-03_Storage		90	-	-	27
3.20-03_Print Making Studio		90	-	-	852
3.CD04-03_Circ.		-	90	-	293
3.26-03_Kiln Room		90	-	-	196
3.25-03_Cold Storage		90	-	-	18
3.24-03_Ceramics Studio		90	-	-	507
3.CD07-03_Circ.		-	90	-	378
3.30-03_3D Workshop		90	-	-	727
4.24-04_W/C		-	90	-	54
4.CD05-04_Lobby		-	90	-	89
4.26-04_Cln		90	-	-	6
4.27-04_IT Hub		90	-	-	163
4.23-04_W/C		-	90	-	143
4.25-04_W/C		-	90	-	163
4.32-04_Rehearsal Rm - Flexible		90	-	-	585
4.31-04_General Teaching		90	-	-	333
4.30-04_General Teaching		90	-	-	354
4.29-04_General Teaching		90	-	-	336
4.28-04_Computer Suite		90	-	-	360
4.ST04-04_Stair HE2		-	90	-	103
4.34-04_W/C		-	90	-	59
4.CD09-04_Lobby		-	90	-	83
4.40-04_Ensemble Singing		90	-	-	295
4.38-04_A. Ch		-	90	-	86

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
4.37-04_W/C		-	90	-	38
4.36-04_W/C		-	90	-	38
4.35-04_W/C		-	90	-	38
04_Shower		-	90	-	11
4.41-04_Changing		-	90	-	137
4.51-04_1-2-1		90	-	-	151
4.54-04_Audio Live		90	-	-	159
4.53-04_Audio Control		90	-	-	362
4.58-04_W/C		-	90	-	63
4.56-04_W/C		-	90	-	36
4.CD10-04_Lobby		-	90	-	76
4.57-04_W/C		-	90	-	61
4.ST01-04_Stair HE1		-	90	-	92
4.03-04_Rehearsal Rm - Flexible		90	-	-	553
4.04-04_Rehearsal Rm - Flexible		90	-	-	523
4.06-04_Rehearsal Rm - Flexible		90	-	-	475
4.CD03-04_Lobby		-	90	-	43
4.CD02-04_Circ.		-	90	-	290
4.17-04_Stu Ex.		90	-	-	183
4.18-04_Singing		90	-	-	146
4.20-04_Ensemble Singing		90	-	-	281
4.CD04-04_Circ.		-	90	-	427
4.21-04_Store		90	-	-	35
4.48-04_Staff		90	-	-	295
4.CD08-04_Circ.		-	90	-	166
0.40-00_Kitchen St		90	-	-	30
0.41-00_LV		90	-	-	123
0.45-00_Changing		-	90	-	81
00_Shower		-	90	-	13
00_Shower		-	90	-	15
0.46-00_Changing		-	90	-	72
0.CD21-00_Stair		-	90	-	31
0.64-00_Store		90	-	-	14
1.39-01_Wardrobe Store		90	-	-	65
1.58-01_HE Union		-	90	-	89
1.59-01_Future-U		-	90	-	167
2.75-02_W/C		-	90	-	34
2.75-02_W/C		-	90	-	14
2.06-02_Software Development		90	-	-	481
3.31-03_Storage		90	-	-	14
3.27-03_Storage		90	-	-	22
4.ST03-04_Stair FE2		-	90	-	96
4.16-04_Staff		90	-	-	511

General lighting and display lighting		Luminous efficacy [lm/W]			General lighting [W]
Zone name		Luminaire	Lamp	Display lamp	
	Standard value	60	60	22	
4.CD01-04_Circ.		-	90	-	448
3.03-03_Fibre Glass Workshop Specialist		90	-	-	21
3.03-03_Fibre Glass Workshop		90	-	-	356
3.02-03_Encapsulation Specialist		90	-	-	19
3.02-03_Encapsulation		90	-	-	322
0.65-00_01_Film Studio		90	-	-	2044
1.57-01_HE Social		90	-	-	928
3.35-03_Art Studios & Drawing Room		90	-	-	4246
0.39-00_Bakery Kitchen		-	90	-	899
1.15-01_Quiet Study		90	-	-	323
1.06-01_Social Dining		-	90	-	496
1.07-01_Kitchen		-	90	-	1388
3.46-03_HE Art studios & Digi		90	-	-	2206
0.67-00_01_Teaching Studio		90	-	-	1077
0.CD18-00_Circ.		-	90	-	63
0.CD17-00_Circ.		-	90	-	58
1.CD10-01_Circ.		-	90	-	286
0.27-00_Social		90	-	-	1991
0.18-00_Male W/C		-	90	-	150
0.CD08-00_Circ.		-	90	-	110
0.CD11-00_Circ.		-	90	-	272
0.CD19-00_Circ.		-	90	-	117
0.CD23-00_Circ.		-	90	-	107
00_01_West Entrance		-	90	-	245
2.CD07-02_Circ		-	90	-	382
2.CD09-02_Circ		-	90	-	228

Criterion 3: The spaces in the building should have appropriate passive control measures to limit solar gains

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
0.28-00_IT Hub	N/A	N/A
0.21-00_Control Room	N/A	N/A
0.19-00_Control Room	N/A	N/A
0.11-00_LiveRoom - S	N/A	N/A
0.10-00_Control Room	N/A	N/A
0.20-00_LiveRoom - L	N/A	N/A
0.72-00_Make-Up	N/A	N/A
0.63-00_Machines Room	N/A	N/A
0.76-00_Practice Room	N/A	N/A
0.73-00_Band Room	N/A	N/A
0.74-00_Practice Room	N/A	N/A
0.15-00_Practice Room	N/A	N/A
0.75-00_Practice Room	N/A	N/A
0.14-00_Practice Room	N/A	N/A

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
0.12-00_Band Room	N/A	N/A
0.13-00_Practice Room	N/A	N/A
01_Control & Dimmer Room	N/A	N/A
1.11-01_IT Hub	N/A	N/A
0.53-00_01_Main Theatre	N/A	N/A
2.32-02_PC / Games Design	NO (-58.4%)	NO
2.31-02_PC / Games Design	NO (-31.5%)	NO
2.28-02_Staff	NO (-44.1%)	NO
2.27-02_PC Suite / Theory	NO (-3.5%)	NO
2.25-02_PC Suite / Theory	NO (-16%)	NO
2.23-02_PC Suite / Theory	NO (-4.5%)	NO
2.15-02_IT Hub	N/A	N/A
2.29-02_PC Suite	NO (-98.2%)	NO
2.26-02_PC Suite	NO (-98.7%)	NO
2.24-02_PC Suite	NO (-99.3%)	NO
2.58-02_Mac Suite	NO (-58.6%)	NO
2.56-02_Mac Suite	NO (-59.7%)	NO
2.54-02_Mac Suite	NO (-59.4%)	NO
2.41-02_Mac Suite	NO (-59.8%)	NO
2.40-02_PC Suite	NO (-59.4%)	NO
2.71-02_Reprographics	N/A	N/A
2.39-02_PC Suite	NO (-97.8%)	NO
2.36-02_Boardroom	NO (-97.8%)	NO
2.18-02_Edit Suite	NO (-90.6%)	NO
2.19-02_Edit Suite	N/A	N/A
2.20-02_Edit Suite	N/A	N/A
2.12-02_Admin	N/A	N/A
2.05-02_Operation Systems Lab	NO (-43%)	NO
2.01-02_Mac Suite	NO (-21.3%)	NO
3.14-03_IT Hub	N/A	N/A
3.47-03_Mac Suite	NO (-64.7%)	NO
3.45-03_Mac Suite	NO (-64.5%)	NO
3.44-03_Mac Suite	NO (-64.8%)	NO
3.28-03_Garment Construction Studio	NO (-33.4%)	NO
3.17-03_Digital Workshop	NO (-97.7%)	NO
3.22-03_Laser Cutting	N/A	N/A
3.57-03_Training Salon - Beauty	N/A	N/A
4.10-04_IT Hub	N/A	N/A
4.49-04_Rehearsal Rm - Drama	YES (+14.7%)	NO
4.07-04_Rehearsal Rm - Flexible	YES (+14.6%)	NO
4.55-04_Welcome	NO (-94.9%)	NO
4.52-04_Rehearsal Rm - Flexible	NO (-90.3%)	NO
4.22-04_Rehearsal Rm - Flexible	NO (-17.8%)	NO
4.19-04_Rehearsal Rm - Flexible	YES (+26.5%)	NO
4.15-04_Rehearsal Rm - Flexible	YES (+28.3%)	NO
4.12-04_Assessment Studio	YES (+22.3%)	NO
4.13-04_Rehearsal Rm - Flexible	YES (+27.3%)	NO
4.05-04_Rehearsal Rm - Flexible	YES (+12.3%)	NO
4.02-04_Rehearsal Rm - Large	YES (+17%)	NO

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
4.01-04_Rehearsal Rm - Flexible	YES (+10.3%)	NO
4.44-04_Rehearsal Rm - Drama	NO (-13.5%)	NO
4.14-04_Rehearsal Rm - Flexible	NO (-94.5%)	NO
0.09-00_TV Studio - FE	N/A	N/A
0.08-00_Sound Studio	N/A	N/A
0.05-00_Studio S	N/A	N/A
0.04-00_LiveRoom S	N/A	N/A
0.03-00_Studio S	N/A	N/A
0.02-00_LiveRoom L	N/A	N/A
0.01-00_Studio L	N/A	N/A
0.62-00_Set & Prop St.	N/A	N/A
0.60-00_Scene Dock	N/A	N/A
1.49-01_Film IT Suite	NO (-57.8%)	NO
1.47-01_Film IT Suite	NO (-64.4%)	NO
2.07-02_1-2-1	N/A	N/A
2.08-02_1-2-1	N/A	N/A
2.09-02_Adult Maintenance Lab Lvl3	NO (-43.4%)	NO
2.68-02_Seminar Room	N/A	N/A
2.52-02_Meeting Rm	N/A	N/A
2.48-02_Meeting Rm	N/A	N/A
2.47-02_Meeting Rm	N/A	N/A
3.07-03_Media Makeup	NO (-5.7%)	NO
3.62-03_Hospitality & Events Tch	NO (-23.3%)	NO
3.60-03_Mac Suite	NO (-57.4%)	NO
3.61-03_General Teaching	NO (-33.5%)	NO
3.39-03_DJ Classroom	NO (-63.6%)	NO
3.43-03_DJ Booth	NO (-66%)	NO
3.42-03_DJ Booth	N/A	N/A
3.41-03_DJ Booth	N/A	N/A
3.40-03_DJ Booth	N/A	N/A
3.59-03_Laser Room	N/A	N/A
3.58-03_Treatment Room	N/A	N/A
3.63-03_Media Makeup - Hair	NO (-94.8%)	NO
3.66-03_General Teaching	NO (-93.6%)	NO
3.06-03_1-2-1	NO (-94.7%)	NO
2.44-01_HE LRC & Social	NO (-84.3%)	NO
4.50-04_Rehearsal Rm - Film	NO (-4.6%)	NO
4.42-04_Solo Singing	N/A	N/A
4.33-04_Ensemble Singing	N/A	N/A
4.45-04_Solo Singing	N/A	N/A
4.46-04_Solo Singing	N/A	N/A
3.48-03_Mac Suite	NO (-63.8%)	NO
0.43-00_Social	NO (-36.1%)	NO
1.24-01_Group Study	NO (-52.9%)	NO
1.04-01_Social Dining	NO (-90%)	NO
1.05-01_Social/Work area	NO (-80.5%)	NO
0.49-00_01_Studio Theatre	N/A	N/A
03_3D Workshop Specialist	N/A	N/A
3.21-03_Jewellery Workshop Specialist	N/A	N/A

Zone	Solar gain limit exceeded? (%)	Internal blinds used?
3.21-03_Jewellery Workshop	NO (-94.5%)	NO
0.44-00_IT Hub	N/A	N/A
0.66-00_Equip Store	N/A	N/A
0.69-00_Foley Suite	N/A	N/A
0.70-00_Post Sound	N/A	N/A
0.07-00_ST	N/A	N/A
0.22-00_Quiet Room	N/A	N/A
0.24-00_1-2-1	N/A	N/A
0.26-00_1-2-1	NO (-82.3%)	NO
0.25-00_1-2-1	N/A	N/A
0.23-00_Student Hub	NO (-67.5%)	NO
0.31-00_Front Reception	YES (+81%)	NO
0.32-00_Reception & Box Office	YES (+7.2%)	NO
0.33-00_Back Office	N/A	N/A
0.34-00_Cash Off.	N/A	N/A
0.35-00_Restaurant	YES (+97.5%)	NO
1.22-01_CLICK + Repair	NO (-14.3%)	NO
1.16-01_LRC Staff	N/A	N/A
1.14-01_LRC	YES (+44.8%)	NO
1.27-01_Control Room	N/A	N/A
1.25-01_IT Hub	NO (-73.1%)	NO
1.29-01_1-2-1	N/A	N/A
1.56-01_Staff	N/A	N/A
1.48-01_Production Meeting	N/A	N/A
1.45-01_Edit Suite	N/A	N/A
1.46-01_Edit Suite	N/A	N/A
1.43-01_Edit Suite	N/A	N/A
1.44-01_Edit Suite	N/A	N/A
1.42-01_Edit Suite	N/A	N/A
1.55-01_Theory Room	NO (-25.1%)	NO
1.01-01_HE Reception	NO (-19.6%)	NO
01_Office	N/A	N/A
2.38-02_IT Hub	N/A	N/A
2.66-02_Staff	NO (-50.1%)	NO
2.69-02_Security	NO (-49.6%)	NO
2.73-02_CCNA Patch Rm	NO (-52.3%)	NO
2.70-02_Security Operations	N/A	N/A
2.72-02_CCNA	NO (-53.1%)	NO
2.74-02_Theory Room	NO (-43.6%)	NO
2.02-02_Mac Suite	NO (-41.8%)	NO
2.04-02_Screen Print	N/A	N/A
2.03-02_Wet Rm	N/A	N/A
2.10-02_Adult Maintenance Lab	NO (-42.9%)	NO
2.13-02_Admin	NO (-13.9%)	NO
2.11-02_HE Admin	NO (-17.3%)	NO
2.22-02_Principalship	NO (-6.9%)	NO
2.21-02_Principalship Admin	NO (-29.8%)	NO
2.30-02_FE Maintenance Lab	NO (-98.6%)	NO
2.42-02_1-2-1	N/A	N/A