

*Drawings to be read in conjunction with NBS specifications.
 *Presence of internal existing VCL to be investigated.
 *All replacement cladding, render systems to achieve minimum Fire Rating A2-s1, d0 to BS EN 13501-1

Existing composite RC slab.

OUTSIDE

Existing insulation: 2 layers Rockwool RW3 75mm. Insulation must be A1 Fire Rated under BS EN 13501-1.

General Note:
Internal arrangements for existing SFS shown is notional only for the purposes of showing design intent only.

This Drawing Is Copyright of DMWR Architects LTD

Scale Bar	To be used as guidance only	
1:5	mm	50 150
1:10	mm	100 300
1:20	mm	200 600
1:50	mm	500 1500

Manufacturers to provide Fire Test Certification for open state and closed state barrier systems confirming compatibility with overall wall assembly and compliance.

B	12/05/2022	Cladding system revised	SE	CL
A	29/04/2022	Notes added	SE	-
Rev	Date	Revision Description	Drm	Chk

Project Name Design House, Manchester.		North
Client THOMASONS		
Drawing Title Proposed Slab Edge (Party Floor)		Client Job No Client No
		DMWR Job No 3685
Drawing Reference. 3685-DR-200		Revision B
Drawn Date 29.10.2020	Scale 1:5@A3	Drawn By FA
Drawing Status TENDER		Checked By CL



0161 413 4656
mail@dmwr.co.uk
www.dmwr.co.uk

Contact DMWR for more information