

NOMA 2 & 3

ES Chapter 6 Appendix 6.2

XXXX-BHE-XX-XX-XX-X-XXXX

0050930

30 June 2022

Revision P01

Revision	Description	Issued by	Date	Checked
P01	Issue for planning	NS	1/07/2022	NS

https://burohappold.sharepoint.com/sites/050930/02_Documents/04_Reports/S&P/Daylight and Sunlight/23 Angel Square Daylight Sunlight Overshadowing Appendices 220606.docx

Report Disclaimer

This Report was prepared by Buro Happold Limited ("BH") for the sole benefit, use and information of MEPC Limited for Planning Application. BH assumes no liability or responsibility for any reliance placed on this Report by any third party for any actions taken by any third party in reliance of the information contained herein. BH's responsibility regarding the contents of the Report shall be limited to the purpose for which the Report was produced and shall be subject to the express contract terms with MEPC Limited. The Report shall not be construed as investment or financial advice. The findings of this Report are based on the available information as set out in this Report.

author **Neil Shankland**

date **30/06/2022**

approved **Neil Shankland**

signature 

date **30/06/2022**

Contents

Appendix 6.2 Detailed tables of sunlight results	4
--	---

Appendix 6.2 Detailed tables of sunlight results

Table 0—1 Impact of 2 AS on sunlight access at adjacent receptors

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
Name	No.	%	%	-	%	%	-	%	-	-
Linx building - Living rooms	1	47	31	0.66	13	14	1.08	16	Above	Negligible
	2	48	32	0.67	14	14	1	16	Above	Negligible
	3	22	9	0.41	7	8	1.14	13	Below	Medium
	4	52	33	0.63	11	12	1.09	19	Above	Negligible
	5	13	2	0.15	7	2	0.29	11	Below	High
	6	12	0	0	6	0	0	12	Below	High
	7	20	2	0.1	2	0	0	18	Below	High
	8	31	11	0.35	4	4	1	20	Below	High
	9	31	10	0.32	11	5	0.45	21	Below	High
	10	46	30	0.65	8	10	1.25	16	Above	Negligible
	11	20	23	1.15	3	5	1.67	3	Above	Negligible
	12	25	23	0.92	3	5	1.67	2	Above	Negligible
	13	32	26	0.81	5	7	1.4	6	Above	Negligible
	14	38	27	0.71	5	8	1.6	11	Above	Negligible
	15	49	27	0.55	9	10	1.11	22	Above	Negligible
	16	23	21	0.91	5	6	1.2	2	Above	Negligible
	17	22	20	0.91	4	4	1	2	Above	Negligible
	18	31	25	0.81	6	7	1.17	6	Above	Negligible
	19	31	23	0.74	6	7	1.17	8	Below	Low
	20	35	23	0.66	6	7	1.17	12	Below	Low
	21	35	25	0.71	6	8	1.33	10	Above	Negligible
	22	42	25	0.6	7	8	1.14	17	Above	Negligible

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	23	42	24	0.57	7	8	1.14	18	Below	Medium
	24	49	26	0.53	9	10	1.11	23	Above	Negligible
	25	19	9	0.47	8	1	0.12	10	Below	High
	26	20	9	0.45	7	0	0	11	Below	High
	27	43	20	0.47	12	5	0.42	23	Below	Medium
	28	30	20	0.67	3	4	1.33	10	Below	Low
	29	35	21	0.6	5	5	1	14	Below	Low
	30	39	22	0.56	6	5	0.83	17	Below	Medium
	31	43	24	0.56	8	5	0.62	19	Below	Medium
	32	53	38	0.72	10	11	1.1	15	Above	Negligible
	33	52	38	0.73	10	11	1.1	14	Above	Negligible
	34	40	31	0.78	6	9	1.5	9	Above	Negligible
	35	48	34	0.71	9	11	1.22	14	Above	Negligible
	36	33	30	0.91	5	8	1.6	3	Above	Negligible
	37	28	29	1.04	5	8	1.6	1	Above	Negligible
	38	23	27	1.17	4	7	1.75	4	Above	Negligible
	39	26	24	0.92	2	4	2	2	Above	Negligible
	40	18	23	1.28	5	6	1.2	5	Above	Negligible
	41	19	22	1.16	1	3	3	3	Above	Negligible
	42	40	30	0.75	5	6	1.2	10	Above	Negligible
	43	29	24	0.83	2	4	2	5	Above	Negligible
	44	24	26	1.08	5	6	1.2	2	Above	Negligible
	45	20	19	0.95	5	6	1.2	1	Above	Negligible
	46	25	20	0.8	5	6	1.2	5	Above	Negligible
	47	19	19	1	5	6	1.2	0	Above	Negligible
	48	35	25	0.71	9	10	1.11	10	Above	Negligible
	49	47	13	0.28	13	7	0.54	34	Below	High

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	50	44	18	0.41	10	4	0.4	26	Below	Medium
	51	30	16	0.53	3	3	1	14	Below	Medium
	52	31	17	0.55	3	3	1	14	Below	Medium
	53	36	18	0.5	5	4	0.8	18	Below	Medium
	54	36	17	0.47	5	4	0.8	19	Below	Medium
	55	39	20	0.51	5	4	0.8	19	Below	Medium
	56	38	19	0.5	5	4	0.8	19	Below	Medium
	57	43	20	0.47	7	4	0.57	23	Below	Medium
	58	45	20	0.44	7	4	0.57	25	Below	Medium
	59	44	17	0.39	10	4	0.4	27	Below	High
	60	39	6	0.15	9	2	0.22	33	Below	High
	61	36	11	0.31	4	3	0.75	25	Below	High
	62	44	24	0.55	10	5	0.5	20	Below	Medium
	63	44	19	0.43	15	5	0.33	25	Below	High
	64	40	21	0.52	7	5	0.71	19	Below	Medium
	65	36	21	0.58	6	5	0.83	15	Below	Medium
	66	31	20	0.65	3	4	1.33	11	Below	Low
	67	41	21	0.51	9	6	0.67	20	Below	Medium
	68	32	19	0.59	4	5	1.25	13	Below	Medium
	69	37	21	0.57	6	6	1	16	Below	Medium
	70	38	17	0.45	16	5	0.31	21	Below	High
	71	44	23	0.52	13	6	0.46	21	Below	Medium
	72	29	18	0.62	6	6	1	11	Below	Low
	73	33	21	0.64	10	7	0.7	12	Below	Low
	74	36	23	0.64	12	7	0.58	13	Below	Medium
	75	29	20	0.69	7	7	1	9	Below	Low
	76	42	21	0.5	18	7	0.39	21	Below	High

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
Linx building - Bedrooms	1	26	26	1	8	8	1	0	Above	Negligible
	2	52	36	0.69	11	12	1.09	16	Above	Negligible
	3	14	5	0.36	7	5	0.71	9	Below	High
	4	13	3	0.23	6	3	0.5	10	Below	High
	5	41	16	0.39	9	7	0.78	25	Below	High
	6	46	17	0.37	13	9	0.69	29	Below	High
	7	22	7	0.32	7	0	0	15	Below	High
	8	37	31	0.84	6	8	1.33	6	Above	Negligible
	9	46	36	0.78	9	11	1.22	10	Above	Negligible
	10	25	28	1.12	5	8	1.6	3	Above	Negligible
	11	30	30	1	5	8	1.6	0	Above	Negligible
	12	21	27	1.29	4	7	1.75	6	Above	Negligible
	13	25	17	0.68	4	5	1.25	8	Below	Low
	14	32	17	0.53	6	6	1	15	Below	Medium
	15	38	17	0.45	6	6	1	21	Below	Medium
	16	45	19	0.42	8	7	0.88	26	Below	Medium
	17	49	18	0.37	9	7	0.78	31	Below	High
	18	45	12	0.27	9	5	0.56	33	Below	High
	19	41	13	0.32	6	4	0.67	28	Below	High
	20	46	11	0.24	14	6	0.43	35	Below	High
	21	27	13	0.48	4	4	1	14	Below	Medium
	22	35	14	0.4	6	5	0.83	21	Below	Medium
	23	40	15	0.38	6	5	0.83	25	Below	High
	24	45	16	0.36	8	5	0.62	29	Below	High
	25	51	18	0.35	10	6	0.6	33	Below	High
	26	43	23	0.53	11	6	0.55	20	Below	Medium
	27	43	17	0.4	17	6	0.35	26	Below	High

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	28	35	21	0.6	6	6	1	14	Below	Low
	29	41	22	0.54	8	6	0.75	19	Below	Medium
	30	33	20	0.61	4	5	1.25	13	Below	Low

Table 0—2 Impact of 3 AS on sunlight access at adjacent receptors

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
Name	No.	%	%	-	%	%	-	%	-	-
Linx building - Living rooms	1	47	46	0.98	13	13	1	1	Above	Negligible
	2	48	46	0.96	14	13	0.93	2	Above	Negligible
	3	22	22	1	7	7	1	0	Above	Negligible
	4	52	51	0.98	11	11	1	1	Above	Negligible
	5	13	10	0.77	7	4	0.57	3	Above	Negligible
	6	12	10	0.83	6	4	0.67	2	Above	Negligible
	7	20	18	0.9	2	0	0	2	Above	Negligible
	8	31	31	1	4	4	1	0	Above	Negligible
	9	31	30	0.97	11	10	0.91	1	Above	Negligible
	10	46	50	1.09	8	10	1.25	4	Above	Negligible
	11	20	40	2	3	5	1.67	20	Above	Negligible
	12	25	41	1.64	3	5	1.67	16	Above	Negligible
	13	32	44	1.38	5	7	1.4	12	Above	Negligible
	14	38	46	1.21	5	8	1.6	8	Above	Negligible
	15	49	52	1.06	9	11	1.22	3	Above	Negligible
	16	23	44	1.91	5	7	1.4	21	Above	Negligible
	17	22	42	1.91	4	5	1.25	20	Above	Negligible

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	18	31	48	1.55	6	8	1.33	17	Above	Negligible
	19	31	48	1.55	6	9	1.5	17	Above	Negligible
	20	35	48	1.37	6	9	1.5	13	Above	Negligible
	21	35	48	1.37	6	9	1.5	13	Above	Negligible
	22	42	48	1.14	7	9	1.29	6	Above	Negligible
	23	42	49	1.17	7	10	1.43	7	Above	Negligible
	24	49	53	1.08	9	12	1.33	4	Above	Negligible
	25	19	19	1	8	8	1	0	Above	Negligible
	26	20	20	1	7	7	1	0	Above	Negligible
	27	43	45	1.05	12	14	1.17	2	Above	Negligible
	28	30	43	1.43	3	10	3.33	13	Above	Negligible
	29	35	45	1.29	5	12	2.4	10	Above	Negligible
	30	39	48	1.23	6	14	2.33	9	Above	Negligible
	31	43	49	1.14	8	14	1.75	6	Above	Negligible
	32	53	52	0.98	10	10	1	1	Above	Negligible
	33	52	50	0.96	10	10	1	2	Above	Negligible
	34	40	46	1.15	6	7	1.17	6	Above	Negligible
	35	48	50	1.04	9	9	1	2	Above	Negligible
	36	33	44	1.33	5	6	1.2	11	Above	Negligible
	37	28	43	1.54	5	6	1.2	15	Above	Negligible
	38	23	40	1.74	4	5	1.25	17	Above	Negligible
	39	26	35	1.35	2	2	1	9	Above	Negligible
	40	18	33	1.83	5	5	1	15	Above	Negligible
	41	19	33	1.74	1	1	1	14	Above	Negligible
	42	40	43	1.08	5	5	1	3	Above	Negligible
	43	29	36	1.24	2	3	1.5	7	Above	Negligible
	44	24	36	1.5	5	5	1	12	Above	Negligible

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	45	20	30	1.5	5	5	1	10	Above	Negligible
	46	25	31	1.24	5	5	1	6	Above	Negligible
	47	19	29	1.53	5	5	1	10	Above	Negligible
	48	35	37	1.06	9	9	1	2	Above	Negligible
	49	47	46	0.98	13	12	0.92	1	Above	Negligible
	50	44	46	1.05	10	12	1.2	2	Above	Negligible
	51	30	45	1.5	3	9	3	15	Above	Negligible
	52	31	44	1.42	3	9	3	13	Above	Negligible
	53	36	45	1.25	5	10	2	9	Above	Negligible
	54	36	46	1.28	5	10	2	10	Above	Negligible
	55	39	49	1.26	5	11	2.2	10	Above	Negligible
	56	38	47	1.24	5	11	2.2	9	Above	Negligible
	57	43	48	1.12	7	12	1.71	5	Above	Negligible
	58	45	50	1.11	7	12	1.71	5	Above	Negligible
	59	44	46	1.05	10	12	1.2	2	Above	Negligible
	60	39	38	0.97	9	8	0.89	1	Above	Negligible
	61	36	44	1.22	4	8	2	8	Above	Negligible
	62	44	48	1.09	10	14	1.4	4	Above	Negligible
	63	44	43	0.98	15	14	0.93	1	Above	Negligible
	64	40	47	1.18	7	14	2	7	Above	Negligible
	65	36	45	1.25	6	12	2	9	Above	Negligible
	66	31	44	1.42	3	11	3.67	13	Above	Negligible
	67	41	48	1.17	9	16	1.78	7	Above	Negligible
	68	32	44	1.38	4	13	3.25	12	Above	Negligible
	69	37	48	1.3	6	16	2.67	11	Above	Negligible
	70	38	37	0.97	16	15	0.94	1	Above	Negligible
	71	44	47	1.07	13	16	1.23	3	Above	Negligible

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	72	29	37	1.28	6	12	2	8	Above	Negligible
	73	33	38	1.15	10	15	1.5	5	Above	Negligible
	74	36	39	1.08	12	15	1.25	3	Above	Negligible
	75	29	37	1.28	7	15	2.14	8	Above	Negligible
	76	42	39	0.93	18	15	0.83	3	Above	Negligible
Linx building - Bedrooms	1	26	24	0.92	8	6	0.75	2	Above	Negligible
	2	52	51	0.98	11	11	1	1	Above	Negligible
	3	14	13	0.93	7	6	0.86	1	Above	Negligible
	4	13	11	0.85	6	4	0.67	2	Above	Negligible
	5	41	40	0.98	9	8	0.89	1	Above	Negligible
	6	46	44	0.96	13	11	0.85	2	Above	Negligible
	7	22	21	0.95	7	6	0.86	1	Above	Negligible
	8	37	44	1.19	6	6	1	7	Above	Negligible
	9	46	49	1.07	9	10	1.11	3	Above	Negligible
	10	25	40	1.6	5	6	1.2	15	Above	Negligible
	11	30	43	1.43	5	6	1.2	13	Above	Negligible
	12	21	38	1.81	4	5	1.25	17	Above	Negligible
	13	25	47	1.88	4	8	2	22	Above	Negligible
	14	32	47	1.47	6	9	1.5	15	Above	Negligible
	15	38	49	1.29	6	10	1.67	11	Above	Negligible
	16	45	52	1.16	8	12	1.5	7	Above	Negligible
	17	49	52	1.06	9	12	1.33	3	Above	Negligible
	18	45	47	1.04	9	11	1.22	2	Above	Negligible
	19	41	48	1.17	6	10	1.67	7	Above	Negligible
	20	46	45	0.98	14	13	0.93	1	Above	Negligible
	21	27	45	1.67	4	8	2	18	Above	Negligible
	22	35	46	1.31	6	9	1.5	11	Above	Negligible

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	23	40	49	1.23	6	11	1.83	9	Above	Negligible
	24	45	52	1.16	8	12	1.5	7	Above	Negligible
	25	51	54	1.06	10	13	1.3	3	Above	Negligible
	26	43	47	1.09	11	15	1.36	4	Above	Negligible
	27	43	41	0.95	17	15	0.88	2	Above	Negligible
	28	35	47	1.34	6	15	2.5	12	Above	Negligible
	29	41	48	1.17	8	15	1.88	7	Above	Negligible
	30	33	43	1.3	4	11	2.75	10	Above	Negligible

Table 0—3 Impact of 2&3 AS on sunlight access at adjacent receptors

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
Name	No.	%	%	-	%	%	-	%	-	-
Linx building - Living rooms	1	47	30	0.64	13	13	1	17	Above	Negligible
	2	48	31	0.65	14	13	0.93	17	Above	Negligible
	3	22	8	0.36	7	7	1	14	Below	High
	4	52	32	0.62	11	11	1	20	Above	Negligible
	5	13	2	0.15	7	2	0.29	11	Below	High
	6	12	0	0	6	0	0	12	Below	High
	7	20	2	0.1	2	0	0	18	Below	High
	8	31	11	0.35	4	4	1	20	Below	High
	9	31	10	0.32	11	5	0.45	21	Below	High
	10	46	30	0.65	8	10	1.25	16	Above	Negligible

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	11	20	23	1.15	3	5	1.67	3	Above	Negligible
	12	25	23	0.92	3	5	1.67	2	Above	Negligible
	13	32	26	0.81	5	7	1.4	6	Above	Negligible
	14	38	27	0.71	5	8	1.6	11	Above	Negligible
	15	49	27	0.55	9	10	1.11	22	Above	Negligible
	16	23	21	0.91	5	6	1.2	2	Above	Negligible
	17	22	20	0.91	4	4	1	2	Above	Negligible
	18	31	25	0.81	6	7	1.17	6	Above	Negligible
	19	31	23	0.74	6	7	1.17	8	Below	Low
	20	35	23	0.66	6	7	1.17	12	Below	Low
	21	35	25	0.71	6	8	1.33	10	Above	Negligible
	22	42	25	0.6	7	8	1.14	17	Above	Negligible
	23	42	24	0.57	7	8	1.14	18	Below	Medium
	24	49	26	0.53	9	10	1.11	23	Above	Negligible
	25	19	9	0.47	8	1	0.12	10	Below	High
	26	20	9	0.45	7	0	0	11	Below	High
	27	43	20	0.47	12	5	0.42	23	Below	Medium
	28	30	20	0.67	3	4	1.33	10	Below	Low
	29	35	21	0.6	5	5	1	14	Below	Low
	30	39	22	0.56	6	5	0.83	17	Below	Medium
	31	43	24	0.56	8	5	0.62	19	Below	Medium
	32	53	37	0.7	10	10	1	16	Above	Negligible
	33	52	37	0.71	10	10	1	15	Above	Negligible
	34	40	29	0.72	6	7	1.17	11	Above	Negligible
	35	48	32	0.67	9	9	1	16	Above	Negligible
	36	33	28	0.85	5	6	1.2	5	Above	Negligible
	37	28	27	0.96	5	6	1.2	1	Above	Negligible

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	38	23	25	1.09	4	5	1.25	2	Above	Negligible
	39	26	22	0.85	2	2	1	4	Above	Negligible
	40	18	22	1.22	5	5	1	4	Above	Negligible
	41	19	20	1.05	1	1	1	1	Above	Negligible
	42	40	29	0.72	5	5	1	11	Above	Negligible
	43	29	23	0.79	2	3	1.5	6	Below	Low
	44	24	25	1.04	5	5	1	1	Above	Negligible
	45	20	18	0.9	5	5	1	2	Above	Negligible
	46	25	19	0.76	5	5	1	6	Below	Low
	47	19	18	0.95	5	5	1	1	Above	Negligible
	48	35	24	0.69	9	9	1	11	Below	Low
	49	47	13	0.28	13	7	0.54	34	Below	High
	50	44	18	0.41	10	4	0.4	26	Below	Medium
	51	30	16	0.53	3	3	1	14	Below	Medium
	52	31	17	0.55	3	3	1	14	Below	Medium
	53	36	18	0.5	5	4	0.8	18	Below	Medium
	54	36	17	0.47	5	4	0.8	19	Below	Medium
	55	39	20	0.51	5	4	0.8	19	Below	Medium
	56	38	19	0.5	5	4	0.8	19	Below	Medium
	57	43	20	0.47	7	4	0.57	23	Below	Medium
	58	45	20	0.44	7	4	0.57	25	Below	Medium
	59	44	17	0.39	10	4	0.4	27	Below	High
	60	39	6	0.15	9	2	0.22	33	Below	High
	61	36	11	0.31	4	3	0.75	25	Below	High
	62	44	24	0.55	10	5	0.5	20	Below	Medium
	63	44	19	0.43	15	5	0.33	25	Below	High
	64	40	21	0.52	7	5	0.71	19	Below	Medium

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	65	36	21	0.58	6	5	0.83	15	Below	Medium
	66	31	20	0.65	3	4	1.33	11	Below	Low
	67	41	21	0.51	9	6	0.67	20	Below	Medium
	68	32	19	0.59	4	5	1.25	13	Below	Medium
	69	37	21	0.57	6	6	1	16	Below	Medium
	70	38	17	0.45	16	5	0.31	21	Below	High
	71	44	23	0.52	13	6	0.46	21	Below	Medium
	72	29	18	0.62	6	6	1	11	Below	Low
	73	33	21	0.64	10	7	0.7	12	Below	Low
	74	36	23	0.64	12	7	0.58	13	Below	Medium
	75	29	20	0.69	7	7	1	9	Below	Low
	76	42	21	0.5	18	7	0.39	21	Below	High
Linx building - Bedrooms	1	26	24	0.92	8	6	0.75	2	Above	Negligible
	2	52	35	0.67	11	11	1	17	Above	Negligible
	3	14	5	0.36	7	5	0.71	9	Below	High
	4	13	3	0.23	6	3	0.5	10	Below	High
	5	41	16	0.39	9	7	0.78	25	Below	High
	6	46	17	0.37	13	9	0.69	29	Below	High
	7	22	7	0.32	7	0	0	15	Below	High
	8	37	29	0.78	6	6	1	8	Above	Negligible
	9	46	35	0.76	9	10	1.11	11	Above	Negligible
	10	25	26	1.04	5	6	1.2	1	Above	Negligible
	11	30	28	0.93	5	6	1.2	2	Above	Negligible
	12	21	25	1.19	4	5	1.25	4	Above	Negligible
	13	25	17	0.68	4	5	1.25	8	Below	Low
	14	32	17	0.53	6	6	1	15	Below	Medium

Receptor	Window	APSH Baseline	APSH Proposed	APSH Ratio Proposed/Baseline	WPSH Baseline	WPSH Proposed	WPSH Ratio Proposed/Baseline	Absolute Reduction	BRE Guidance Met	Magnitude of Change
	15	38	17	0.45	6	6	1	21	Below	Medium
	16	45	19	0.42	8	7	0.88	26	Below	Medium
	17	49	18	0.37	9	7	0.78	31	Below	High
	18	45	12	0.27	9	5	0.56	33	Below	High
	19	41	13	0.32	6	4	0.67	28	Below	High
	20	46	11	0.24	14	6	0.43	35	Below	High
	21	27	13	0.48	4	4	1	14	Below	Medium
	22	35	14	0.4	6	5	0.83	21	Below	Medium
	23	40	15	0.38	6	5	0.83	25	Below	High
	24	45	16	0.36	8	5	0.62	29	Below	High
	25	51	18	0.35	10	6	0.6	33	Below	High
	26	43	22	0.51	11	5	0.45	21	Below	Medium
	27	43	16	0.37	17	5	0.29	27	Below	High
	28	35	20	0.57	6	5	0.83	15	Below	Medium
	29	41	21	0.51	8	5	0.62	20	Below	Medium
	30	33	19	0.58	4	4	1	14	Below	Medium

Neil Shankland
Buro Happold Limited
3 Wellington Place
Leeds
LS1 4AP
UK

T: +44 (0)113 204 2200

F: +44 (0)870 787 4144

Email: neil.shankland@burohappold.com