File ref - c:\users\dwalker\onedrive - amey plc\desktop\jun 21\ac-msl-5788d\ac-msl-5788-1300.dwg

0 100



KEY

* ← LANTERN REFERENCE: REFER TO LANTERN SCHEDULE

* ← HEIGHT OF PROPOSED GALVANISED STEEL POST TOP COLUMN

Example of Numbering details:

Column Number → 1(N) ← Service Type

Supply details:
The following denotes supply type and connection detail:

T = DNO Transfer
N = DNO New service
D = DNO Disconnection
PN = Private service
PT = Private transfer
PD = Private disconnection
C = Lantern conversion only to existing lighting column

Lanterns Schedule	
Lantern Reference	**A**
Manufacturer	Signify (Philips)
Range/Family	Luma Micro Gen 2 (MCC308.1P)
LED Output (Total Lamp Flux)	3 Klm
CCT	4000
Optic/Distrinution Setting	DW50
Luminous intensity Class	G3
Lantern Spigot Inclination	0°
Control Gear Type	Electronic DALI Driver
Control	Philips Citytouch OLC
Quantity	3

© Crown Copyright and database right 2015. Ordnance Survey 100023172.

DESIGN HAZARDS

(The following information has been collected from Preconstruction Information and Amey Process CDM Hazard Management Process.)

1. Lantern Dimming Profiles to be applied;
 Column 1: 100%
 Column 2: 100%
 Column 3: 100%

Rev	Revision details	Chkd	Appd	Date

Designed: DJW		Date: JUN 2021
Drawn: DJW		Date: JUN 2021
Checked: CR		Date: JUN 2021
Approved: CR		Date: JUN 2021

Copyright © Amey

ameyconsulting
www.amey.co.uk

Client
PLP CONSTRUCTION

Project Name
DOB BROOK CLOSE
MILES PLATTING
MANCHESTER

Drawing Title
Street Lighting
PROPOSED ROAD
LIGHTING LAYOUT

Original Drg Size : A3	Scale : 1:500
Dimensions : m	Tile No : -

Drawing Status	Suitability
SUITABLE FOR CONSTRUCTION	A1

Drawing No	Revision
AC-MSL-5788-1301	C01