





NOTES:

1. MATERIAL - MILD STEEL
2. COLOUR - LIGHT GREY (RAL7035)
3. IP RATING - IP54 (RECOMMENDED FOR INDOOR USE)
4. TO RESET A THERMAL OVERLOAD TRIP, TURN THE H-O-A TO 'OFF/RESET'.
5. H-O-A SWITCH IS SPRING RETURN TO 'OFF' FROM 'HAND' POSITION.

OPTION:

- ☒ 1. COMMON ALARM BEACON FOR PUMP TRIP & HIGH LEVEL.
- ☒ 2. COMMON AUDIBLE ALARM FOR PUMP TRIP & HIGH LEVEL, C/W MUTE.
- ☒ 3. MCB PUMP PROTECTION.
- ☒ 4. PUMP AMMETER & HOUR RUN COUNTER.
- ☒ 5. FUSED TELEMETRY SUPPLY.



- METER TAILS SUPPLIED LOOSE  
PANEL FITTED INTO M.S. KIOSK  
PANEL FITTED INTO G.R.P. KIOSK  
BEACON SUPPLIED LOOSE  
BEACON FITTED TO KIOSK OR PANEL  
BEACON NOT SUPPLIED



BEACON  
24VAC  
FLASHING RED

ISSUED

EC

DATE

15/09/23

TITLE:

DUAL 3PH DOL LIBRA MAXI CONTROL PANEL  
OPERATED VIA FLOATS  
C/W VARIABLE OPTIONS

CLIENT:

WOLSELEY

SCHEME:

**T.T Controls  
& Automation**

Onneley Works, Newcastle Road, Woore,  
Cheshire, CW3 9RU

A DIVISION OF **T.T PUMPS LTD.**

© COPYRIGHT T-T PUMPS LTD 2023



+44 (0) 1630 647200  
response@ttpumps.com  
www.ttpumps.com

PROJECT NO.

K11875

DRAWN BY

CR

APPROVED BY

GP

DATE:

14/01/21

DRAWING NO.

A4/ES/2103

SHEET NO.

1 of 3

REVISION TABLE



