

COPYRIGHT IN THIS DRAWING REMAINS WITH KITSON ARCHITECTURE LIMITED

DO NOT SCALE TO ASCERTAIN DIMENSIONS

Rev.	Description	Date
A	Updated section a-a to represent elevation	26.03.26



DEAN STREET - SECTION A-A THROUGH AS EXISTING 1:50




DEAN STREET - SECTION A-A THROUGH AS PROPOSED 1:50


NOTE.

Pipes passing through non fire rated building elements (walls, floors, partitions, etc.) shall be enclosed concentrically within purpose made sleeves.
Sleeves shall be cut from the same material as the pipe, one or two sizes larger than the pipe to allow clearance. Install sleeves flush with building finish.
Do not use sleeves as pipe supports. Fit masking plates where visible pipes pass through building elements, including false ceilings and/or walls of occupied rooms.

All services passing through fire rated elements of the building structure shall be provided with fire dampers and/or suitably fire-stopped to maintain the fire integrity and rating of the a associated building element.




GROUND FLOOR PLAN AS PROPOSED




ALL TECHNICAL DETAILS ARE SUBJECT TO BUILDING CONTROL APPROVAL

① PENETRATION THROUGH WALL - EXHAUST PIPE 1:10



ALL TECHNICAL DETAILS ARE SUBJECT TO BUILDING CONTROL APPROVAL

② NEW ACOUSTIC CEILING 1:10



ALL TECHNICAL DETAILS ARE SUBJECT TO BUILDING CONTROL APPROVAL

③ PENETRATION THROUGH WALL - ATTENUATOR / LOUVRE 1:10

500
1000 millimetres

0.5 1 2 3 4 5 metres

Client	JENNOR
Project	THE ASTLEY, MANCHESTER NEW GENERATOR
Drawing Title	SECTION A-A & DETAILS AS PROPOSED
Drawing Number	635-006
Revision	A
Status	PLANNING
Author	TRP
Scale @ A1	1:50 & 1:10
Date	28 01 2026

KITSON Architecture Ltd
Suite 22 Carlton Place
28-32 Greenwood Street
Altrincham
Cheshire
WA14 1RZ
0161 637 2764
mail@kitsonarchitecture.co.uk
www.kitsonarchitecture.co.uk

KITSON ARCHITECTURE