

NOTES:

1. This drawing shall be read in conjunction with all relevant architectural, structural (if applicable), mechanical, electrical, public health drawings, schedules, and specifications.
2. All MEP services work shall comply with the latest relevant guides and engineering standards (such as CIBSE, BSRIA, British Standards, Institute of Plumbing, and ISO), and the project-specific engineering specifications.
3. The Contractor shall allow and provide all necessary supports for equipment, pipework, other associated services, as required.
4. The Contractor shall coordinate all works with other trades on site to avoid conflicts with architectural finishes or services from other disciplines.
5. This drawing has been produced utilising the landlord as-fitted ventilation drawing, indicating the locations of ductwork and louvre for tenant use. The Contractor shall be responsible for reviewing the as-fitted information shown on the drawing against the actual site condition to verify the accuracy and ensure all required works can be carried out accordingly.
6. Ductwork branch to be fitted with variable control damper (VCD).
7. Ductwork shall be installed complete with suitable means of access for cleaning and maintenance in accordance with TR19.
8. The Contractor shall prepare and provide his own working drawings to ensure correct installation.
9. All pipework, ductwork and services passing through fire-rated walls and barriers shall be provided with appropriate fire-protection measures.

LEGEND:

H/L	High level
L/L	Low level
DTB	Drop to below
DFA	Drop from above
DT	Drops to
C/W	Complete with
AP	Access point
EF	Extract fan
EV	Exhaust valve
ATT	Attenuator
MSFD	Motorised smoke fire damper
- - - - -	Ductwork at high level
——,——	Ductwork in bulkhead/ceiling void
AP	Existing access points (serving existing systems)
AP	Indicative new access points for proposed installations

Rev	Date	Description	Prod.	Chk.	Rvd.	App.
L02	13.03.26	LBC Submission	ZL	DK	KB	KB
L01	03.12.25	LBC Submission	ZL	DK	KB	KB

Client:
Government Property Agency

ARCADIS
Registered office: 80 Fenchurch Street, London EC3M 4BT
Coordinating office: 80 Fenchurch Street, London EC3M 4BT
www.arcadis.com

Project: Sunlight House - Floors 7 and 8

Site: Sunlight House, Little Quay Street, Manchester M3 3HP

Drawing Title: Level 07 - Proposed Ventilation Layout

Designed: ARCADIS	Signed: ARCADIS	Date:	03.12.2025
Drawn: ZL	Signed: ZL	Date:	03.12.2025
Checked: DK	Signed: DK	Date:	03.12.2025
Reviewed: KB	Signed: KB	Date:	03.12.2025
Approved: KB	Signed: KB	Date:	03.12.2025
Design Stage: RIBA Stage 3			
Original Size: A1	Grid:	Datum:	
Suitability Code: A3	Scale: 1:100	Project Number:	30279810

Suitability Description: **OFFICIAL-SENSITIVE**

Listed Building Consent Submission

Drawing Number: 30279810-ARC-MAN-07-DR-ME-05700

Revision: L02

100mm on Original

© Copyright reserved