








QA Form - Manholes

Installation of Manhole			Sheet No:	5.
Project	C376 WITHINGTON CDC		Date:	28/04/2025
Location:	SW4	Drawing No:	22182-CCS-WCH006-XX-DR-S-93000	
As built coordinates:	383773.066 392006.090			
Cover Level:	32.830			
Manhole No:	SW4 CATH PIT	Type:	FOUL/SURFACE WATER/COMBINED	
Invert:	31.660 <i>BAM 31.682u.</i>	(circle as appropriate)		
Inverts and Diameter of pipes:	Upstream: 31.675 Dia: 300 Downstream: 31.660 Dia: 300 Inlet 1: 31.675 Dia: 300 Inlet 2: Dia: Inlet 3: Dia: Inlet 4: Dia: Inlet 5: Dia:			
Chamber Details:	Dia. Size: 1500 Overall depth: 1440mm Cover Depth: 100mm Biscuit Depth: 150mm Reducing Slab:			
WORK TO BE INSPECTED	Accepted Yes/ No or N/a	Comments	MW Construction Eng/QA Signed as Checked:-	
Setting out to drawing	Yes	<i>Position good. higher due to inlet connection on a retention tank.</i>	B.H. 	
Trench excavation supported	Yes	Stepped as required	B.H. 	
Installation of concrete to channel	No	Cath pit	B.H. 	

QA Form - Manholes

Installation of drainage channel/first manhole ring	Yes	Catch pit	B.H. 
MWC Signature confirming invert/positioning check	B.H. 		Date
Client Signature confirming invert/positioning check	Daniel Allen		Date 26/6/25

WORK TO BE INSPECTED	Accepted Yes/ No or N/A	Comments	MW Construction Eng/QA Signed as Checked:-
Installation of manhole rings to required levels	yes	Depths and No's of rings: 2 no 1500 x 500 rings	B.H. 
Installation of dropshafts/inlets above manhole invert	yes		B.H. 
Manhole Surround	yes	Details: concrete	B.H. 
Backfilling to manhole to required level and layers as instructed in spec	yes		B.H. 
Biscuit Installation	yes	Type: PCC	B.H. 
Benching/Water proofing to Manhole	yes		B.H. 
Installation of Step Irons	yes	Type & Numbers:	B.H. 
Brickwork		No of courses:	
Lid and Frame	yes	Cover Type: 600 x 1200	B.H. 

QA Form - Manholes

Client Signature confirming Handover of Manhole:-		Date	24/06/2025
MWC Signature confirming Handover of Manhole:-		Date	19-9-25









