

Plan View on
Rack Wash Condense Hood



Plan View on Main Canopy
Installation



Plan View on Main Canopy
Installation



Plan View on Main Canopy
Installation

Disclaimer Notice

PLEASE DO NOT SCALE FROM DRAWING

All dimensions / sizes shown are for reference purposes only.
All contractors are to carry out site surveys to determine correct measurements for all shopfitting / fabrication works.

No responsibility shall be bourne by RDA Limited should contractors fail to carry out site surveys to determine their requirements.

This drawing and any subsequent related drawings constitute an outline conceptual scheme only and may be subject to revision after completion of a full measured and structural survey and approval. No local authorities have yet been consulted regarding town planning, building control, emergency services, licensing and other relevant approvals, this scheme must be considered as possibly subject to consequent revision after this consultation process has been completed.

Copyright Notice

This drawing was created in AutoCAD LT 2020 and is the property of RDA Limited. No part of this drawing may be reproduced without the express and written consent of Restaurant Design Associates Ltd.

INSTALLATION NOTES.
EXTRACT.
- EXTRACT AIR FLOW RATE CALCULATED AT 0.241m³/s
- CANOPY TO BE SUPPLIED C/W 1off EXTRACT SPIGOT CONNECTIONS Ø250 x H100mm, TO BE INSTALLED COMPLETE WITH 2off 300 x 300mm EGG CRATE GRILLS THESE ARE SUPPLIED LOOSE WITH CANOPY FOR INSTALLATION AT TIME OF HOOD.
- ANTICIPATED PRESSURE LOSS ACROSS EXTRACT 150Pa.

AIR SUPPLY.
- AIR SUPPLY FLOW RATE CALCULATED AT 0.205m³/s BASED ON 85% SUPPLY AIR DIRECT TO HOOD.
- AIR SUPPLY VALUE INCLUDED FOR INFORMATION ONLY, M&E CONTRACTOR TO TAKE INTO ACCOUNT.

CANOPY FABRICATION NOTES.
- APPROXIMATE CANOPY WEIGHT 125Kg's
- CANOPY TO BE FABRICATED IN 2off SECTIONS.



Installation on
Elevation E - E



Installation on
Elevation F - F

rev	description	date	by
A	Initial issue released for comments	30.07.25	JH

Client
BNY

Project Number	Project Title
4607–6	4 Angel Square Manchester

Site Address	Area
4 Angle Square City Centre Manchester M60 0AG	Dish Wash Area
	Drawing Title Canopy Fabrication and Installation Drawing

Drawing No	Revision
BAC–13328C3	A

Project Status	Drawn By	Drawing Date	Scale	Size
Provisional	JH	30.07.25	1:20	A1

DESIGN > SUPPLY > INSTALL

Tel: 0844 873 4993
E–mail: info@rdalimited.co.uk