


NOTE: SEE GENERAL
ARRANGEMENT DRAWINGS
FOR DOOR HINGE SIDE

DOOR TYPE J: FIRE ESCAPE
DOOR No. 2D.26, 3D. 22, 4D.20 / TOTAL No. OF DOORS = 2



DESCRIPTION: TYPE J

STRUCTURAL OPENING: EXISTING x EXISTING
LEAF SIZE: EXISTING x EXISTING

FINISH: PAINTED FINISH REPLICA DOOR.
COLOUR TBC.
DOOR EDGES PAINTED TO MATCH DOOR
FACE.

FIRE RATING: FD60S
GLAZING: TO BE 30-60 INTEGRITY -
INSULATION.

ACOUSTIC RATING: N/A

IRONMONGERY :
1.5 x PAIR BALL BEARING BUTT HINGES.
1 x CAM ACTION OVERHEAD DOOR CLOSER.
1 x WALL MOUNTED DOOR STOP
1 x PULL HANDLE (TBC)
1 x PUSH PLATE (TBC)

DOOR DOES NOT REQUIRE ELECTRONIC
LOCKING

DOOR SEALS = LORIENT LP1504 INTUMESCENT
STRIP SEAL TO HEAD AND JAMBS.
LORIENT LAS1010 BATWING SEAL TO HEAD
AND JAMBS.
COLOUR: TBC

SIGNAGE = 2 x FIRE DOOR KEEP CLEAR SIGN



DO NOT SCALE FROM THE DRAWING. IF IN DOUBT ASK.

FIRE DOOR INSTALLATION NOTES:

NOTE: IN ALL CASES, ALL FRAME, JOINERY AND IRONMONGERY MATERIALS TO BE SUPPLIED AND INSTALLED IN ACCORDANCE WITH THE APPLICABLE FIRE CERTIFICATE TEST DETAILS.

GAPS BETWEEN DOOR LIPPING AND FRAME AT BOTH JAMBS AND HEAD TO BE 3-4mm. WHERE DROP-DOWN SEAL TO BASE OF DOOR IS TO BE PROVIDED, GAP BETWEEN THRESHOLD AND DOOR TO BE MAX 13mm, IF NO DROP-SEAL IS PROPOSED, GAP TO BE AS SPECIFIED IN THE FIRE CERTIFICATE TEST DETAILS.

ALLOW FOR INTUMESCENT HINGE LINERS TO BE INSTALLED IN ACCORDANCE WITH THE TEST CERTIFICATE DETAILS, AND ALLOW FOR INTUMESCENT LINERS TO ANY DOOR LOCK SETS AND KEEP.

BATWING SEALS TO BE TIGHTLY MITRED AT TOP CORNER JUNCTIONS AND FITTED IN STRICT ACCORDANCE WITH LORIENT INSTRUCTIONS.

INSTALLING CONTRACTOR TO REFER TO BWF-CERTIFIRE BEST PRACTICE GUIDE (FIRE DOORS AND DOORSETS) FOR FURTHER DETAILED GUIDANCE.

WHERE REPAIR AND UPGRADE WORKS ARE BEING DONE TO EXISTING DOORS, THE INSTITUTION OF FIRE ENGINEERS 'GUIDE TO THE FIRE RESISTANCE OF HISTORIC TIMBER PANEL DOORS' AND REPORT 'TBC' BY FRMA ARE TO BE USED FOR GUIDANCE AND INFORMATION.

GLAZING NOTE:
GLAZING SHOULD BE DESIGNED TO RESIST HUMAN IMPACT AS SET OUT IN BS 6262-4:2018, WHERE ALL OR PART, OF A PANE IS:

- WITHIN 800mm OF FLOOR LEVEL, OR,
- PART OF A DOOR LEAF,
- OR WITHIN 300mm OF A DOOR LEAF,
- AND WITHIN 1.5M OF FLOOR LEVEL

TO BE LAMINATED SAFETY GLASS TO BS 6206 1981
SPECIFICATION FOR IMPACT PERFORMANCE REQUIREMENTS FOR FLAT SAFETY GLASS AND SAFETY PLASTICS FOR USE IN BUILDINGS AND MARKED WITH THE BS KITE MARK ACCORDINGLY.

FOR NGS	RSB DRAWN	DRAWN REVISION	DEC 25 DATE	PC VER
	<div style="text-align: center;">  <p>ALLISON PIKE</p> </div> <div style="text-align: center; border: 1px solid black; padding: 5px; margin: 10px 0;"> <p>ARCHITECTS & DESIGNERS</p> </div> <div style="display: flex; justify-content: space-between; margin-top: 20px;"> <div> <p>7 Buxton Road West, Disley, Stockport, Cheshire, SK12 2AE. Website: www.allisonpike.com</p> </div> <div> <p>Telephone: 01663 763000 Facsimile: 01663 766772 Email: studio@allisonpike.com</p> </div> </div> <div style="text-align: center; margin-top: 10px;"> <p>© Allison Pike Partnership Limited.</p> </div>			
TENDER ISSUE	<p>PROJECT</p> <p>INNKEEPERS COLLECTION 1-3 YORK STREET (BROWNS) MANCHESTER</p>			
	<p>TITLE</p> <p>DOOR TYPE J SCHEDULE AND DETAILS</p>			
	<p>SCALE</p> <p>1:20, AND 1:5 @ A3</p>			
	<p>JOB No</p> <p>MAB46</p>	<p>DRAWING No</p> <p>AZ70</p>	<p>REV</p> <p>/</p>	