

Risk Register Reference	Hazard Description	Hazard Colour	Servery	Risk Rating	Risk Active at Approval	Risk Active at Construction
		Red - Major (Seek Advice)				
		Amber - Review Risk Assessment				
		Green - Caution				
SCALE	LEVEL OF RISK	SCALE	CONSEQUENCE	SCALE	LIKELIHOOD	
EXCEPTIONAL		CATASTROPHIC		VERY PROBABLE		
MAJOR		MAJOR		PROBABLE OR FREQUENT		
MODERATE	TYPICAL OR NORMAL	MODERATE	SERIOUS	POSSIBLE		
LOW	BELOW MODERATE	LOW	MINOR	UNLIKELY OR REMOTE		
VERY LOW		VERY LOW		REMOTE		

THIS RISK BOX IS FOR **GUIDANCE ONLY**. THE CONTENT HAS BEEN PRODUCED BY THE SES TEAM. IT IS IMPERATIVE THAT THE READER OF THIS DOCUMENT REVIEW ALL **BASIS RISK ASSESSMENTS** / **TECHNICAL DOCUMENTATION & METHOD STATEMENTS** BEFORE PROCEEDING.

001	Working At Height To Install Services	AMBER	3	1	N	N
002	Slip, Trip & Falls	AMBER	2	1	N	N
003	Mechanical Isolations	AMBER	2	1	N	N
004	Electrical Isolations	AMBER	4	1	N	N

LEGEND	
	13A DOUBLE SWITCHED SOCKET OUTLET C/W USB A&C
	13A SINGLE SOCKET OUTLET
	5A SINGLE LAMP SOCKET OUTLET
	13A SWITCHED FUSED CONNECTION UNIT
	20A DOUBLE POLE SWITCHED CONNECTION UNIT
	ISOLATOR TYPE - SINGLE PHASE/THREE PHASE
	ISOLATOR RATING
	POWER DISTRIBUTION BOX
	10 WAY METAL CLAD DISTRIBUTION BOARD C/N RECESSING KIT
	SECURITY DATA OUTLET
	TEMPORARY WIFI DATA OUTLET
	CNS DATA OUTLET CEILING MOUNTED
	SECURITY DATA OUTLET CEILING MOUNTED
	COMMANDO OUTLET
	CNS DATA OUTLET
	CORPORATE DATA OUTLET
	CORPORATE DATA OUTLET CEILING MOUNTED

ABBREVIATIONS	
AC	ACCESS CONTROL
AHU	AIR HANDLING UNIT
AI	TWIN SOCKET FOR AH, HL
BMS	BUILDING MANAGEMENT SYSTEM
CL	CLEANERS SOCKET, LL
CM	COFFEE MACHINE, ML
CV	CEILING VOID
AKAP	ACCESSIBLE REFUGE ALARM PANEL, ML
AWC	ACCESSIBLE ALARM ARRANGEMENT, HL
DW	DISHWASHER, LL
EAC	ELECTRONIC ACCESS CONTROL
EF	EXTRACT FAN, CV
ELB	ELECTRIC BLINDS, CV
FAP	FIRE ALARM PANEL, ML
FARP	FIRE ALARM REPEATER PANEL, ML
FCU	FAN COIL UNIT, CV
FR	FRIDGE (SOCKET AT LL CONNECTION UNIT AT HL)
FZ	FREEZER, LL
GD	GENERAL DISTRIBUTION
GW	GLASS WASHER, LL
HDR	HEATED DRAWER/CABINET, LL
HD	HAND DRYER, HL
HL	HIGH LEVEL (2000mm)
HP	HOT/COLD PLATE, ML
HBU	HEAT RECOVERY UNIT, CV
HS	HEATED SHELF, HL
IP	IP65 RATED, ALL EXTERNAL
IPTV	IP TV LOCATION
K	DOUBLE POLE KEY LOCK
LL	LOW LEVEL (450mm)
MC	METAL CLAD
MVHR	MECHANICAL VENTILATION HEAT RECOVERY, CV
PD	POWERED DOOR, CV
SP	SUPPLY FAN, CV
ST	SENSOR TAP, LL
SVS	SMOKE VENT SYSTEM
SPN	SINGLE PHASE & NEUTRAL
TPN	THREE PHASE & NEUTRAL
USB	USB SOCKET OUTLET
WH	WATER HEATER, LL
WP	WEATHERPROOF
DC	DOOR AIR CURTAINS
PUMPS	PUMPS
HWG	HOT WATER GENERATION PUMP
DX	DIRECT EXPANSION COIL
VSS	VIDEO SURVEILLANCE SYSTEM
ML	WALL MOUNTED MIRROR LIGHTING, HL

THIS DRAWING IS CONFIDENTIAL AND MAY NOT BE USED, COPIED OR DISCLOSED TO ANYONE WITHOUT PERMISSION OF SES (ENGINEERING SERVICES)

DO NOT SCALE OFF THIS DRAWING

DRAWING STAGE DEFINITIONS (BSRIA BG62014)

STAGE 2	CONCEPT
STAGE 3B	DEVELOPED DESIGN
STAGE 4A	TECHNICAL DESIGN
STAGE 4B	COORDINATED WORKING
STAGE 5	INSTALLATION DRAWING/RECORD

For full definitions refer to BSRIA BG62014 Table 1

KEY PLAN

CLIENT DIRECT FIT OUT - WHITEBOX AREAS

- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL RELEVANT STRUCTURAL, ARCHITECTURAL & CONSULTANTS DRAWINGS.
- THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE SERVICES SPECIFICATION.
- DO NOT SCALE THIS DRAWING. ALL DIMENSIONS TO BE VERIFIED ON SITE.
- THIS DRAWING SHALL ONLY BE USED FOR THE SPECIFIC SERVICES INDICATED.
- REFRIGERANT PIPEWORK CONTAINMENT TRAYS TO BE FULLY COORDINATED WITH ALL SERVICES, STRUCTURE, CEILINGS & ARCHITECTURAL FEATURES.
- ALL PENETRATIONS THROUGH FIRE COMPARTMENTS SHALL BE SEALED WITH AN APPROPRIATE SEAL.

- SMALL POWER NOTES**
- USB SOCKETS ARE TO BE PROVIDED WITH BOTH TYPE A & C OUTLETS.
 - ALL DIMENSIONS ARE TO BE CHECKED ON SITE PRIOR TO CONSTRUCTION. MANUFACTURE OF ANY COMPONENTS AND ORDERING OF MATERIALS AND EQUIPMENT.
 - ANY DISCREPANCIES ARE TO BE REPORTED TO THE ENGINEER FOR CLARIFICATION.
 - THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER RELATED DRAWINGS AND SPECIFICATIONS.
 - OUTLETS SHALL BE SELECTED TO COMPLY WITH BUILDING REGULATIONS PART M, EQUALITY ACT 2010 AND BS 6800.
 - ALL FUSE CONNECTION UNITS SHALL BE ENGRAVED TO IDENTIFY WHAT EQUIPMENT THEY CONTROL.
 - ALL BACK BOXES SHALL BE FINISHED WITH 3mm OF THE FACE FINISH OF THE WALL.
 - ALL ACOUSTIC AND FIRE PROTECTION FOR ALL BACK BOXES, ARE TO BE PROVIDED TO MAINTAIN THE RATING OF THE WALL.
 - ALL DISTRIBUTION BOARDS SHALL BE MOUNTED SO THAT DEVICES CAN BE OPERATED BY AN OPERATIVE STANDING ON THE FLOOR.
 - ALL SWITCH PANELS, PANELBOARDS AND DISTRIBUTION BOARDS SHALL BE LOCATED AND MOUNTED SO THAT ACCESS DOORS FULLY OPEN AND COVERS CAN SAFELY BE REMOVED.
 - A MINIMUM 1m SAFETY CLEARANCE SHALL BE MAINTAINED IN FRONT OF ALL SWITCHGEAR, AS DETAILLED IN THE ELECTRICITY AT WORK REGULATIONS.
 - SECONDARY CONTAINMENT SHALL BE PROVIDED TO ALL DROPS BY MEANS OF RECESSED GALVANISED STEEL CONDUITS.
 - REFER TO THE DRAINWALE EQUIPMENT SCHEDULES FOR FULL & FINAL INFORMATION IN RESPECT TO SMALL POWER REQUIREMENTS.
 - ALL HAND DRIVERS C/W FINAL CONNECTIONS ARE TO BE PROVIDED.
 - ALL BARS, CONCESSIONS AND KITCHENS FINAL CIRCUITS TO BE SUPPLIED VIA CONTACTORS AND KILL SWITCHES FOR THE FOLLOWING:
 - LIFE SAFETY SYSTEMS
 - PRODES
 - FREEZERS

FOR SETTING OUT DETAILS PLEASE REFER TO:
- JUMP SETTING OUT ELEVATION DRAWINGS - SERIES 2500
- POPULOUS SETTING OUT DRAWINGS - SERIES 1300
- POPULOUS TOILET PACKAGE DRAWINGS - SERIES 2700

C05	JM	BG	08.08.25	Off Season Works Issued As-Fitted
C04	JBD	BG	12.08.25	Issued For Construction
C03	JBD	BG	27.05.25	Issued For Construction
C02	RJS	BD	16.04.25	White Box Area Amended
C01	JBD	BG	23.01.25	Issued For Construction
P03	JBD	BG	19.11.24	Issued For Comments
P02	AR	CE	30.08.24	Stage 4 Issue
P01	AR	BG	12.07.24	Stage 4 Issue
Rev	Dm	Ck'd	Date	Description

Scale: As indicated Original Size: A0

Status: A5 - FOR AUTHORISATION AS STAGE COMPLETE

Client:

Project: MCFC

Title: NORTH STAND SMALL POWER AND DATA LAYOUT LEVEL 01 ZONE 4

Drawing No:	Revision:
NSE-SEE-NS-01-DR-E-621441	C05

SES (Engineering Services) Ltd
Think Park
Building Three
Mosley Road
Trafford Park
Manchester
M17 1FQ
(T) 0161 945 5589
(W) www.ses-td.co.uk

1 L01-Club Level Small Power - Zone 4
1 : 50