

Kevin Ma

From: [REDACTED]
Sent: 07 January 2026 17:53
To: Kevin Ma
Cc: [REDACTED]
Subject: FW: Dalton Avenue, Fallowfield, M14 7NR - SC36011
Attachments: doc13030720260107090543.pdf
Follow Up Flag: Follow up
Flag Status: Flagged

Hi Kevin



We attach the window manufacturers confirmation that the glass used on this development achieves the required sound reduction values

Look forward to hearing from you

Should you have any queries regarding the above please do not hesitate to contact us.

Ian Stanyer

Denton Construction, 8 Bexley Square Salford M3 6BZ



Ian

Please find attached the data sheets for the configurations used

Both types achieve the required 29dB Rw (37 & 32) and achieve the 25dB Rw + Ctr (32 & 28)

Regards



Kevin Fletcher

Technical Manager, Sovereign Group Ltd



Vale Street, Nelson, Lancashire, BB9 0TA

Direct: 01282 440416

KFletcher@sov-group.co.uk | sov-group.co.uk

*This electronic transmission is strictly confidential and intended solely for the addressee(s).
If you are not the intended addressee, you must not disclose, copy or take any action in reliance of this email.*

Subject: Dalton Avenue, Fallowfield, M14 7NR - SC36011

Hi Martin / Glen

Please can you put something in writing to confirm that the glazing / frames installed at the above achieve these figures that were taken from the Noise impact Assessment report that we issued – we need it for submission to planning to discharge the noise condition

Glazing:

- All facades: Minimum 29dB R_w and 25dB R_{w+}

Look forward to hearing from you

Should you have any queries regarding the above please do not hesitate to contact us.