MINI • SOIL • SURVEYS

Minisoils Ltd Ridgeway Nurseries, 6 Ridgeway Road, Timperley, Cheshire WA15 7EY
Tel: 0161 980 4937
Fax: 0161 980 0055

Job Number: MIN50852 Borehole No: 2 of 2

Site: 37 Liverpool Road Manchester Crew: A Date Drilled: 21/01/2020

Description	Depth	Leg	Test Depth	Type	Value
150MM Concrete overlying fragmented brick and gravel, MADE GROUND					
Loose brown topsoil with fine gravel, becoming sandy with depth. MADE GROUND	1.00		1.20	SPT	N=5
			1.80	SPT	N=5
Loose brown fine to medium SAND with fine gravel.	2.40		2.40	SPT	N=10
			3.00	SPT	N=5
			3.50	DS	
			3.60	SPT	N=21*
Dense brown SANDSTONE (suspect bedrock)	3.80				
End of Hole	3.90				

S P T @ 1.20M 5/3/2,1,1,1, S P T @ 1.80M 1/1/1,2,1,1 S P T @ 2.40M 2/3/2,3,2,3,
S P T @ 3.00M 2/1/2,1,1,1, S P T @ 3.60M 3/4/4,6,11* REFUSAL
DISTURBED SAMPLES 3.5 - 3.90M/
NO STANDING WATER ON COMPLETION OF BOREHOLE