

M&E GUIDANCE NOTES:

- REFER TO THE M&E DOCUMENT ISSUE SCHEDULE FOR A FULL LIST OF MEP DOCUMENTS APPLICABLE TO THIS PROJECT.
- REFER TO THE DESIGN RISK REGISTER PRIOR TO COMMENCEMENT OF WORKS.
- REFER TO THE MEP SPECIFICATIONS AND SCHEDULES FOR PLANT SPECIFICATIONS, MATERIALS AND WORKMANSHIP STANDARDS.
- DO NOT SCALE FROM THIS DRAWING.

LEGEND

-  WALL MOUNTED LUMINAIRE
-  EMERGENCY WALL MOUNTED LUMINAIRE
-  BOLLARD LUMINAIRE
-  COLUMN LUMINAIRE
-  EMERGENCY BULKHEAD
-  SINGLE 7.4 kW SPN EV CHARGE POINT
M - ROLEC EV
R - BASIC CHAGE (C/W MONTA MANAGEMENT/LOAD MONITORING)
-  DUAL 7.4 kW SPN EV CHARGE POINT
M - ROLEC EV
R - BASIC CHAGE (C/W MONTA MANAGEMENT/ LOAD MONITORING)
-  CCTV INFRASTRUCTURE ONLY, BLANK PLATE TO BE INSTALLED FOR FUTURE CAMERA
-  4MP HIGH RESOLUTION VANDAL RESISTANT DOME CAMERA
MANUFACTURER: ENTROTEC
RANGE:PRO-VRD-IP-A
-  DENOTES LUMINAIRE TYPE
-  DENOTES SWITCHING ARRANGEMENT

