

Timber fire resisting doors – existing doors to be upgraded to achieve half hour fire resistance. Doors to be taken down and stripped to remove existing finishes. Doors to be repaired and Envirograf clear intumescent coating system applied in accordance with manufacturers recommendations.

New cross corridor doors and frames to be installed to reduce travel distance and to provide lobby for kitchen. Doors to be oak frame and glazed with 15mm PyroSTOP

- New door

- New door

Rev	Description	Rev	By	Chk'd	Aut'd
-----	-------------	-----	----	-------	-------



The University of Manchester
Directorate of Estates and Facilities
Beyer Building
The University of Manchester
Oxford Road
Manchester
M13 9PL

Drawing Status

Project IMPROVEMENTS TO MEANS OF ESCAPE

Building Name	HULME HALL HOULDSWORTH	Building No.	045AD
Site Name	VICTORIA PARK		
Sub Site Name			

Drawing Title
FIRST FLOOR PROPOSED

PM JW	Drawn JW	Checked -	Authorised -
Scale @ A3 1:250	Date 20-02-26	Date -	Date -
Drawing No. 9354 - A102			Revision 1