PITSFORD ROAD

Manchester City Council

Proposed Equipment Schedule

30 January 2026

SHD2225-SHD-HLG-PITS-SH-EO-Lighting Schedule-R1

info@shdlighting.co.uk ☎ 07834 490 192 www.shdlighting.co.uk

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Unit Location	Unit Description	Service Connection Type	Primary Isolator	Secondary Isolator	Private Cable Network Termination Type
LC01	385980.8132	400093.8688	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC02	386009.6506	400110.2292	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC03	386041.6109	400103.9126	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC04	386075.6954	400117.2117	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC05	386089.4418	400133.9372	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC06	386111.2591	400115.8226	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC07	386137.8028	400125.6103	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC08	386152.0901	400147.4131	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC09	386142.9598	400168.5402	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC10	386175.5737	400144.5663	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC11	386203.9443	400157.3378	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC12	386237.3099	400173.3908	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC13	386233.5967	400194.1920	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC14	386268.0030	400213.1012	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC15	386298.6417	400228.9538	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC16	386323.7810	400241.8271	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC17	386339.4505	400250.6563	Refer to 'SHD2225-SHD-HLG-PITS-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro (BGP702 DW50 4000 20LED 5.2S CLO L90 730) 4.00klm 24w warm white 3000k LED luminaire, dimmed to 90% lumen output using CMS Complete with Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.