

1. 50902-VE-PS-XX-SH-E-6801 - PICCADILLY STATION UNDERCROFT AREA BMS REQUIREMENTS DOCUMENT
2. 50902-VE-PS-XX-SC-E-6803 - PICCADILLY STATION BOILER ROOM BLOCK CABLE DIAGRAM
3. 50902-VE-PS-XX-SC-E-6001 - PICCADILLY STATION HV & LV SINGLE LINE DIAGRAM
4. 50902-VE-PS-XX-SC-M-5603 - PROPOSED UNDERCROFT P&ID
5. 50902-VE-PS-XX-SH-E-6801 - PICCADILLY STATION BOILER ROOM BMS REQUIREMENTS DOCUMENT
6. 50902-VE-PS-XX-SC-M-5602 - PROPOSED BOILER ROOM P&ID
7. 50902-VE-PS-XX-SC-E-6801 - PICCADILLY STATION UNDERCROFT AREA BLOCK CABLE DIAGRAM

	12F MULTIMODE FIBRE CABLE
	BELDEN 9841 / 9842 MODBUS CABLE
	BS5308 CONTROLS CABLE
	RJ45 CAT 6 UNSHIELDED 23 AWG IP20 PATCHCORD
	LV POWER CONNECTION (SEE LV SLD FOR DETAILS)

