

1 Water penetration: Gutters and rainwater goods should be cleared of any debris and require detailed investigation. Leadwork should be renewed where necessary to an improved standard. Moisture sources should be eliminated prior to any refurbishment

Rainwater outlets to be cleared of debris and checked for blockages
Rainwater goods to be cleaned and prepared for primer and exterior paint in accordance with NBS Specification.
West Elevation - 6no. RWP's
South Elevation - 3 no. RWP's
East Elevation - 3 no. RWP's
North Elevation - 3 no. RWP's

-2456

Job Number 141532	Date NOV'23	Security Classification	Drawn By MTW
Scale@A1 1 : 75	Purpose CONSTRUCTION		Reviewed By RM
Drawing Number 2403-RBUM-ARC-XX-RL-DR-A-2403			Revision C3