

THIS DRAWING IS CONFIDENTIAL AND MAY NOT BE USED, COPIED OR DISCLOSED TO ANYONE WITHOUT PERMISSION OF SES ENGINEERING SERVICES.
DO NOT SCALE OFF THIS DRAWING

DRAWING STAGE DEFINITIONS (BSRIA BGS0214)
STAGE 2 CONCEPT DRAWING
STAGE 3B DEVELOPED DESIGN DRAWING
STAGE 4A TECHNICAL DESIGN DRAWING
STAGE 4B COORDINATED WORKING DRAWING
STAGE 5 INSTALLATION DRAWING/RECORD DRAWING
For full definitions refer to BSRIA BGS0214 Table 1

Notes

PU COLD FILL PRESSURE = 1.4 bar(g)
PU WORKING PRESSURE = 2.1 bar(g)
HIGH PRESSURE SWITCH SETTING = 3.7 bar(g)
LOW PRESSURE SWITCH SETTING = 1.1 bar(g)
SYSTEM MAX WORKING PRESSURE = 4.0 bar(g)
SYSTEM TEST PRESSURE = 6.0 bar(g)

CR1 13.10.25 AS CONSTRUCTED RECORD
C02 12.10.23 PRESSURE SENSOR ADDED TO AHU 5.A.03 PIPEWORK
C01 03.10.23 COMMENTS INCORPORATED. ISSUED FOR COMMENT
P03 29.10.21 ISSUED FOR COMMENT
P02 12.08.21 ELECTRIFICATION OF HEAT
P01 09.08.21 ISSUED FOR COMMENT

Rev	Date	Description	Original Size
Scale			A0
Status			Stage 5
CR		AS CONSTRUCTED RECORD	
Client			
BAM			

Project
CO-OP LIVE

Title
AIR SOURCE HEAT PUMP
LTHW GENERATION SCHEMATIC

Drawing No
BRA-SES-ZZ-ZZ-DR-X-55801

Revision
CR1

SES (Engineering Services) Ltd
Building Three,
Think Park,
Mosley Road,
Manchester M17 1FQ
(T) 0161 945 5589
(W) www.ses-its.co.uk

