

To	Head of Planning	FAO: Janet Lawless
From	Head of Compliance, Enforcement and Community Safety	
Contact Officer:	████████████████████	Our Ref: PR202511-1709086

Date: 25 November 2025	Telephone: 31347
------------------------	------------------

Consultation on Planning Application

Application No: **144279/FO/2025**

Description: Change of use of 1st Floor of Public House (Sui Generis) to a 6-Bed Guest House (Use Class C1)

Location: 65 Grimshaw Lane Manchester M40 2AX

I write in response to your memorandum regarding the above application and to inform you that I have considered the application and recommend that the following conditions are attached to any approval.

NSE4(b)

Residential sound insulation AND overheating

a) Before the development commences a scheme for acoustically insulating the proposed residential accommodation against noise from Grimshaw Lane and the downstairs public house shall be submitted to and approved in writing by the City Council as local planning authority. There may be other actual or potential sources of noise which require consideration on or near the site, including any local commercial/industrial premises.

The potential for overheating shall also be assessed and the noise insulation scheme shall take this into account. The approved noise insulation and ventilation scheme shall be completed before any of the dwelling units are occupied.

Noise survey data shall include measurements taken during a rush-hour period and night time to determine the appropriate sound insulation measures necessary. The following

noise criteria shall be required to be achieved when providing adequate ventilation as defined by Approved Document F of the Building Regulations (whole dwelling ventilation):

Bedrooms (night time - 23.00 - 07.00)	30 dB LAeq (individual noise events shall not exceed 45 dB LAmax,F by more than 10 times)
Living Rooms (daytime - 07.00 - 23.00)	35 dB LAeq
Gardens and terraces (daytime)	55 dB LAeq

Higher internal noise levels than those specified above may be allowed when higher rates of ventilation are required in relation to the overheating condition.

Additionally, where entertainment noise is a factor in the noise climate the sound insulation scheme shall be designed to achieve internal noise levels in the 63Hz and 125Hz octave centre frequency bands so as not to exceed (in habitable rooms) 47dB and 41dB (Leq,5min), respectively.

b) Prior to first occupation of the residential units, a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that the internal noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the internal noise criteria.

Reason: To secure a reduction in noise from traffic or other sources in order to protect future residents from noise disturbance and to reduce the potential for overheating.

EH are in receipt of a Noise Assessment by Nova Acoustics dated August 25.

EH are concerned regarding the permanent residence and therefore must adhere to the above criteria. Furthermore, no overheating assessment has been considered. Further information is required regarding mechanical ventilation and cooling strategies.

Further information is required regarding noise from the public house on the ground floor and mitigation measures to ensure that noise levels are adhered to in the residential property.

NSE6

External plant/equipment/servicing

a) Externally mounted ancillary plant, equipment and servicing shall be selected and/or acoustically treated in accordance with a scheme designed so as to achieve a rating level of 5dB (LAeq) below the typical background (LA90) level at the nearest noise sensitive location. Prior to commencement of the use hereby approved the scheme shall be submitted to and approved in writing by the City Council as local planning authority in order to secure a reduction in the level of noise emanating from the site. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

b) Prior to the operation of the scheme a verification report shall be submitted to and approved in writing by the City Council as local planning authority to validate that the work undertaken throughout the development conforms to the recommendations and

requirements in the approved acoustic report. The report shall also undertake post completion testing to confirm that the noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the agreed noise criteria.

Reason - To minimise the impact of the development and to prevent a general increase in pre-existing background noise levels around the site.

REF*

a) Before the development commences a scheme for the storage and disposal of refuse shall be submitted to and approved in writing by the City Council as local planning authority.

New developments shall have refuse storage space for segregated waste collection and recycling. Internal and external storage areas are required.

b) The details of the approved scheme shall be implemented as part of the development and shall remain in situ whilst the use or development is in operation.

Reason - In the interests of amenity and public health.

*The proforma/ Waste Management Strategy must include the following information:

- Estimated volumes and types of waste produced by the development;
- Details of internal and external stores for both waste and recycling, including any plans and designs;
- Location of the proposed collection point and details of the route the collection vehicle will take;
- Details of how waste will be transferred between stores and to the collection location; and
- Details of number and capacity of bins proposed and collection frequency.
- Other details as per 'Waste Proforma v1.0' - refer to guidance at: http://www.manchester.gov.uk/downloads/download/6048/waste_management_strategy

The guest rooms/hotel aspect is commercial and therefore needs a separate waste stream to the residential flat.

Information for Developers guidance documents can be downloaded using the following link:

http://www.manchester.gov.uk/info/500207/planning_and_regeneration/1962/additional_planning_guidance/3

Should you wish to discuss this matter further please contact [REDACTED].

Samantha Stabler

Head of Compliance, Enforcement and Community Safety