

3, Confirmation that direct and level access is proposed to the site, into the building and through out the building for disabled persons. How and where would this be achieved? Please provide details of how disabled and able-bodied people would enter and move between floors within the building. Where buildings are adapted, provision of access for disabled people will be sought. Indeed, when adapting buildings, full access should be made available, unless practical considerations dictate otherwise. If you believe full access is not going to be possible at the building, you must comprehensively explain all the options you have considered in order to make the building fully accessible and explain and justify the reasons why each option has been discounted. You are advised to provide scaled drawn information to back up your findings.

The Refurbishment Internally is for ground floor only

THERE WILL BE PUSH BUTTON ENTRANCE AND EGRESS ASSISTANT BUTTONS FOR all disabled members of the public CENTER STAFF WILL HELP AS REQUIRED.

There are disabled toilets provided, WITH DISABLED ACCESS AND DISABLED ONLY ACCESS with Large door opening all to disability designed standards assisted seating and assisted wash hand basin as required

The fire alarm system will have disability features , sounders and flashing lights , there will be emergency lighting and illuminated access exit points as required under Building Regulation.

All fire exits will have legal ramps to provide entrance and exits as required

Within Car Park there is the minimum provision for a number of disabled parking spaces which mandatory and are marked on the car park plans mandatory and from the car park there will be a 1.50m width level foot path from the car park into the supermarket and from there you can access all the other internal areas legal width Ramps .

These will be available as it is a ground floor area only access to all the amenities and shops and areas.

The Entrance doors will have press buttons adjacent to the doors located at disabled levels for the doors to open automatically both available from inside and outside with a press button automatic opening system.

There will be no steps anywhere both to and from with no disabled restricted access.

#All shops and services will have a flat level service there are no steps or internal ramps all internal shop units or cubicle spaces with 900mm wide clear door openings as required.