



KITCHEN
1.17
243.66 m²

[illegible]

3425mm canopy

725

1000

Structure/barr

45

45

56

52

52A

55

200mm wide x 5475mm long services distribution unit.

47

48

43

49

50

51

52

650

657

5475mm canopy

45 Twin Fryer.
45 Twin Fryer.
47 Boiling pan.
48 Bench.
49 Bench.

51 Bench.
52 20 grid combi oven.
52A 6 grid combi oven.
55 Bench.
56 Bench.

CANOPY NO2 INFORMATION:

EXTRACT & SUPPLY CANOPY
5475 x 3425 x 500mm

2000mm TO UNDERSIDE OF CANOPY FROM
FINISHED FLOOR LEVEL.

EXTRACT FLOW RATE- 2.66m³/S AT 100 PA
SUPPLY FLOW RATE - 2.26m³/S AT 40 PA

2 x EXTRACT SPIGOTS - 650x350mm
4 x SUPPLY SPIGOTS - 475x300mm

SPIGOTS FIXED IN FACTORY - YES

NUMBER OF BAFFLE FILTERS - 12No

LIGHTING - 8 x LED SPOT LIGHTS.

EACH LED LIGHT REQUIRES 240V SUPPLY
AND WILL BE SUPPLIED WITH A 1.5m TAIL.

FINAL CONNECTION OF CANOPY LIGHTS TO
LIGHTING CIRCUIT TO BE DONE BY
ELECTRICAL CONTRACTOR. 240V REQUIRED.

CLADDING - N/A.

INFILLS - N/A.

CANOPY APPROVED - YES...../NO.....

COMMENTS.....

SIGNED.....

DATE

43	Bratt pan.	50	4 zone induction range
45	Twin fryer.	51	Bench.
45	Twin fryer.	52	20 grid combi oven.
47	Boiling pan.	52A	6 grid combi oven.
48	Bench.	55	Bench.
49	Bench.	56	Bench.

CLIENT: MCFC

PROJECT: NORTH STAND EXTENSION

TITLE: HT-L01-ALL DAY DINING

KITCHEN CANOPY 2 DETAILS	
DWG No:	NSE-DWN-HT-01-DP-X-000011

REVISION:	C01	DATE:	02.07
STATUS:	A5		

SCALE:	1:50 / 1:25	PAPER SIZE:	A1
--------	-------------	-------------	----

--	--	--



DAWNVALE GROUP

RESTAURANT + BAR DESIGN + BUILD

TEL: 0161 634 7379 DAWNVALE.COM

COPYRIGHT © 2017

DAWNVALE AND MAY NOT BE COPIED OR REPRODUCED WITHOUT
CONSENT. ALL RIGHTS RESERVED.

DRAWING IS INTENDED FOR ILLUSTRATIVE PURPOSES ONLY. FINAL TO BE AGREED WITH CLIENT. ALL DIMENSIONS TO BE AGREED WITH

AND/OR CHECKED AGAINST SITE FIGURE TO MANUFACTURER.

REV-C01
(02.07.2025)