THIS DRAWING IS CONFIDENTIAL AND IS THE PROPERTY OF D. R. DESIGN LLP IT MUST NOT BE DISCLOSED TO A THIRD PARTY COPIED OR LENT WITHOUT WRITTEN CONSENT

EXISTING RETAINING WALL

F G H J K L

1 1X 1Y 2 3 4 4X 5 5X 6 7 8

39 40 41 42 43 44 45 46 47 48 49 50 51 52 53

12 11 10 9 8 7 6 5 4 3 2 1

G.10
CARPARK
1120 m²
12051.2 SF

BICYCLES

G.12
LOBBY
2 m²
21.0 SF

G.SS.04
SMOKE SHAFT
2 m²

G.S.02
STAIR 02
15 m²
163.0 SF

G.R.02
SERVICE RISER
2 m²

G.04
BIKE STORE
90 m²
971.9 SF

G.04b
BIKE STORE LOBBY
11 m²
116.2 SF

G.09
PLANT
39 m²
416.9 SF

G.08
CORRIDOR
7 m² DE
78.2 SF

G.06
ENTRANCE / LOUNGE
41 m²
437.8 SF

G.07
BIN STORE
66 m²
709.3 SF

G.SU.01
SUBSTATION
13 m²
135.0 SF

G.D.05
DUPLEX 05
48 m²
519.5 SF

G.D.06
DUPLEX 06
49 m²
525.4 SF

G.D.07
DUPLEX 07
49 m²
523.1 SF

G.D.05E
EXTERNAL FRONTAGE
8 m²

G.D.06E
EXTERNAL FRONTAGE
8 m²

G.D.07E
EXTERNAL FRONTAGE
8 m²

G.E.03
PLANTER
8 m²

UP

EXTERNAL WALL LIGHTS TO BE OPERATED VIA PHOTOCELL

EXTERNAL WALL LIGHTS TO ENTRANCE AREA TO BE OPERATED VIA PHOTOCELL

TWIN FLUORESCENT FITTING WITH POLYCARBONATE COVER

HELGA STREET

FOR CONTINUATION SEE DRAWING No M2215-63-E-00-01

NOTES

1. ALL LUMINAIRES WITHIN APARTMENTS SHALL BE COMPLETE WITH DIMMABLE DRIVERS.
2. ALL LIGHTING CIRCUITS WITHIN APARTMENTS SHALL BE COMPLETE WITH DIMMER SWITCHES.
3. LUMINAIRE MANUFACTURER TO ENSURE THAT ALL DIMMER SWITCHES ARE COMPATIBLE WITH LED LAMPS.

LEGEND

- A — F TYPE DOWNLIGHT IP65 760LM 8W 4000K DIMMABLE DRIVER
- B — 1500LM 15W 4000K STANDARD DRIVER
- BE — 1500LM 15W 4000K EMERGENCY DRIVER
- B1 — 2000LM 22W 4000K STANDARD DRIVER
- B1E — 2000LM 22W 4000K EMERGENCY DRIVER
- C — BULKHEAD IP65 317mm 2100LM 24W 4000K STANDARD DRIVER
- CE — BULKHEAD IP65 317mm 2100LM 24W 4000K EMERGENCY DRIVER
- D — SINGLE IP65 1540mm 3400LM 24W 4000K STANDARD DRIVER
- DE — SINGLE IP65 1540mm 3400LM 24W 4000K 3HR EMERGENCY PACK
- F — PENDANT LIGHT FITTING (LOW ENERGY)
- EXIT — ILLUMINATED EMERGENCY EXIT SIGN WITH ARROW LEGEND
- SINGLE GANG LIGHT SWITCH 'n' DENOTES GANG
- 2 WAY LIGHT SWITCH 'n' DENOTES GANG
- K — KEYSWITCH & CONTACTOR TO CONTROL LANDLORDS AREA CLEANERS SOCKET RING MAIN
- VU — VANITY UNIT LIGHTING SUPPLIED FROM BATHROOM LIGHTING CIRCUIT
- PIR — CEILING MOUNTED PIR DETECTOR
- MICROWAVE SWITCH FOR CORRIDOR LIGHTING

REV	REVISION	DATE	DRAWN	CHK
C1	CONSTRUCTION ISSUE	NOV 24	DRD	SD
T4	REVISED DUE TO ADDITION OF 2NO. DUPLEX APARTMENTS	NOV 23	DRD	SD
T3	EXTERNAL LIGHTING TO HELGA ST. ELEVATION ADDED	AUG 22	DRD	SD
T2	AMENDED IN ACCORDANCE WITH REVISED ARCHITECTS LAYOUT,	AUG 22	DRD	SD
T1	TENDER ISSUE	AUG 21	DRD	SD
P2	AMENDED IN ACCORDANCE WITH REVISED ARCHITECTS LAYOUT	JUN 21	DRD	SD
P1	PRELIMINARY ISSUE	FEB 21	DRD	SD

CLIENT
MPH ANCOATS LIMITED

PROJECT
RESIDENTIAL DEVELOPMENT
OSBORNE YARD
OLDHAM ROAD

DRAWING TITLE
GROUND FLOOR
LIGHTING AND EMERGENCY LIGHTING
Sheet 2 of 2

DR DESIGN LLP
ENGINEERING - DESIGN - CONSULTANTS
9th FLOOR, IMPERIAL COURT,
BUILDING 2, EXCHANGE QUAY,
MANCHESTER, M5 3EB
Tel: 0161-457-2430 Fax: 0161-457-2001
e-mail: enquiries@dr-design.co.uk
web: www.dr-design.co.uk

DATE	FEB 2021	SCALE	1:50
DRAWN	DRD	ORIGINAL DRAWING SIZE A0	
CHECKED	SD	DRAWING NUMBER	M2215-63-E-00-02
		REV	C1