THIS DRAWING IS CONFIDENTIAL AND IS THE PROPERTY OF D. R. DESIGN LLP IT MUST NOT BE DISCLOSED TO A THIRD PARTY COPIED OR LENT WITHOUT WRITTEN CONSENT

NOTES

1. ALL LUMINAIRES WITHIN APARTMENTS SHALL BE COMPLETE WITH DIMMABLE DRIVERS.
2. ALL LIGHTING CIRCUITS WITHIN APARTMENTS SHALL BE COMPLETE WITH DIMMER SWITCHES.
3. LUMINAIRE MANUFACTURER TO ENSURE THAT ALL DIMMER SWITCHES ARE COMPATIBLE WITH LED LAMPS.

LEGEND

A	F TYPE DOWNLIGHT IP65 760LM 8W 4000K DIMMABLE DRIVER
B	1500LM 15W 4000K STANDARD DRIVER
BE	1500LM 15W 4000K EMERGENCY DRIVER
B1	2000LM 22W 4000K STANDARD DRIVER
B1E	2000LM 22W 4000K EMERGENCY DRIVER
C	BULKHEAD IP65 317mm 2100LM 24W 4000K STANDARD DRIVER
CE	BULKHEAD IP65 317mm 2100LM 24W 4000K EMERGENCY DRIVER
D	SINGLE IP65 1540mm 3400LM 24W 4000K STANDARD DRIVER
DE	SINGLE IP65 1540mm 3400LM 24W 4000K 3HR EMERGENCY PACK
F	PENDANT LIGHT FITTING (LOW ENERGY)
EXIT	ILLUMINATED EMERGENCY EXIT SIGN WITH ARROW LEGEND
	SINGLE GANG LIGHT SWITCH 'n' DENOTES GANG
	2 WAY LIGHT SWITCH 'n' DENOTES GANG
	KEYSWITCH & CONTACTOR TO CONTROL LANDLORDS AREA CLEANERS SOCKET RING MAIN
M3	VANITY UNIT LIGHTING SUPPLIED FROM BATHROOM LIGHTING CIRCUIT
PIR	CEILING MOUNTED PIR DETECTOR
	MICROWAVE SWITCH FOR CORRIDOR LIGHTING

G.13 STORE 7 m² 71.8 SF

G.S.03 STAIR 03 8 m² 81.6 SF

G.02 REC'P / POST 49 m² 532.8 SF

G.01 ENT / GARDEN 66 m² 707.6 SF

G.11 LOBBY 2 m² 21.0 SF

G.SS.03 SMOKE SHAFT 2 m²

G.S.01 STAIR 01 15 m² 164.5 SF

G.R.01 SERVICE RISER 2 m² 20.3 SF

G.03 LOBBY 11 m² 118.0 SF

G.04a BIKE STORE LOBBY 11 m² 116.3 SF

G.10 CARPARK 1120 m² 12051.2 SF

G.04 BIKE STORE 90 m² 971.9 SF

G.D.01 DUPLEX 01 49 m² 526.4 SF

G.D.02 DUPLEX 02 49 m² 525.2 SF

G.D.03 DUPLEX 03 48 m² 519.6 SF

G.D.04 DUPLEX 04 49 m² 525.5 SF

G.D.05 DUPLEX 05 48 m² 519.5 SF

G.D.01E EXTERNAL FRONTAGE 9 m²

G.D.02E EXTERNAL FRONTAGE 8 m²

G.D.03E EXTERNAL FRONTAGE 8 m²

G.D.04E EXTERNAL FRONTAGE 8 m²

G.D.05E EXTERNAL FRONTAGE 8 m²

FOR CONTINUATION SEE DRAWING No M2215-63-E-00-02

C1	CONSTRUCTION ISSUE	NOV 24	DRD	SD
T3	REVISED DUE TO ADDITION OF 2NO. DUPLEX APARTMENTS	NOV 23	DRD	SD
T2	AMENDED IN ACCORDANCE WITH REVISED ARCHITECTS LAYOUT.	AUG 22	DRD	SD
T1	TENDER ISSUE	AUG 21	DRD	SD
P2	AMENDED IN ACCORDANCE WITH REVISED ARCHITECTS LAYOUT	JUN 21	DRD	SD
P1	PRELIMINARY ISSUE	FEB 21	DRD	SD
REV	REVISION	DATE	DRAWN	CHK

CLIENT

MPH ANCOATS LIMITED

PROJECT

RESIDENTIAL DEVELOPMENT
OSBORNE YARD
OLDHAM ROAD

DRAWING TITLE

GROUND FLOOR
LIGHTING AND EMERGENCY LIGHTING
Sheet 1 of 2

DR DESIGN LLP
ENGINEERING - DESIGN - CONSULTANTS
5th FLOOR, IMPERIAL COURT,
BUILDING 2, EXCHANGE QUAY,
MANCHESTER, M5 3EB
Tel: 0161-457-0439 Fax: 0161-457-2001
e-mail: enquiries@dr-design.co.uk
web: www.dr-design.co.uk

DATE	FEB 2021	SCALE	1:50
DRAWN	DRD	ORIGINAL DRAWING SIZE: A0	
CHECKED	SD	DRAWING NUMBER	M2215-63-E-00-01 C1