energycounsel
engineering sustainable buildings

Our ref: Z62503.4B
12th February 2026

Julian Hoe
J Greenwood (Builders) Limited
Unit B9 Greengate Industrial Estate,
Greenside Way,
Chadderton,
M24 1SW

Dear Julian,

Building Regulations Part O (2021) Compliance
All Dwelling and Apartments, Alderford Parade, Cheetham Hill

We have completed the following Building Regulations Part O 2021 assessment on the development at the above site. The CIBSE TM59 (2017) methodology is used for the overheating assessment, as required by Part O of the Building Regulations (2021), which is intended for dwellings that will be continuously occupied throughout the year. Modelling and calculations have been carried out against the drawings and specification previously issued to Energy Counsel.

CIBSE TM59 (2017) Results

As per the results below, all spaces of the development comply with the CIBSE TM59 (2017) criteria for the proposed weather scenario listed and therefore comply with the requirements set out within Approved Document O (2021).

Overall

Passed	286 rooms
Failed	0 rooms

Data

Building category	**Category** II (new builds.)		
Weather file	Manchester_DSY1_2020High50_.epw		
Days data	365	01-Jan	31-Dec
Days (summer)	153	01-May	30-Sep
Data OK?	OK	Full summer	

Housing Plots 1-5

All bedrooms, bathrooms, living and kitchen areas are provided with continuous mechanical supply and extract ventilation with heat recovery (MVHR). The bathrooms and kitchens areas are provided with the minimum continuous flow rates in line with Building Regulations Part F (2021), however the flow rates to the Living Rooms and Bedrooms are slightly increased from the minimum.

- Kitchen: 13l/s
- Living: 10 l/s
- Bedroom: 10l/s
- Bathroom / WC: 8l/s

All Remaining Houses

All bathrooms and kitchen areas are provided with continuous mechanical extract ventilation (MEV). The bathrooms and kitchen / living areas are provided with the minimum continuous flow rates in line with Building Regulations Part F (2021).

- Kitchen / living: 13l/s
- Bathroom / En-suite / WC: 8l/s

All Apartments

All bedrooms, bathrooms, living and kitchen areas are provided with continuous mechanical supply and extract ventilation with heat recovery (MVHR). All areas are provided with the minimum continuous flow rates in line with Building Regulations Part F (2021).

- Kitchen / Living: 13l/s
- Bedroom: 6l/s
- Bathroom / WC: 8l/s

Openable windows are also provided to alleviate overheating. Openings to all dwelling areas have been applied in line with the Noise Impact Assessment and the security recommendations detailed within Section 2.6 of Approved Document O (2021). Windows have been modelled to open a maximum distance of 400mm.

The tables below demonstrate the opening profiles.

Plots 1-5

Time	Windows modelled as open or closed
Ground Floor – 8am-11pm	Open
Ground Floor – 11pm-8am	Closed
Upper Floors – 8am–11pm	Open
Upper Floors – 11pm-8am	Closed

Remaining Plots

Time	Windows modelled as open or closed
Ground Floor – 8am-11pm	Open
Ground Floor – 11pm-8am	Closed
Upper Floors – 8am–11pm	Open
Upper Floors – 11pm-8am	Open

Please note that confirmation of Building Regulations Part O (2021) compliance does not automatically confirm that compliance with the purge ventilation requirements of Building Regulations Part F (2021) are achieved. Assessment of any purge ventilation rates required for Building Regulations Part F (2021) are outside the scope of this report and should be reviewed by the design team.

The building envelope fabric performance values used within the analysis are tabulated below:

Component	**U-value (W/m².K)**	**G-value**
Pitched Roof / Sloping Roof / Flat Roof	0.09 / 0.13 / 0.13	N/A
Ground Floor	0.11 / 0.12	N/A
Glazed Windows & Rooflights	1.20	0.40
Doors	1.20	N/A
External Wall	0.19	N/A
Infiltration Rate	0.15 ac/hr	N/A

A full results output report is provided following this summary letter. A combination of the above information and the introduction on the report below cover all information required in Appendix B Part 2b.

No spaces require mechanical cooling.

Part 3 can be found at the rear of the report for Builder and Building Control sign off.

If you have any queries, please do not hesitate to contact us.

Yours sincerely,
On Behalf of Energy Counsel

[redacted]

Matthew Adams

Enc: Part O Compliance Software Output Report

Approved Document O report
Overheating risk in residential buildings
for
Alderford Parade - All Plots

Copyright © 2011-2026 Integrated Environmental Solutions. All rights reserved.

Alderford Parade - All Plots

Building details

Project name: Alderford Parade - All Plots	Date: 12-02-2026 14:02:04
Location: Manchester Ap, United Kingdom	
Address: Cheetham Hill, Manchester	
Building use: Houses and Apartments	
Are there any security, noise, or pollution issues: Security at Ground Floor and Noise Issues with Plots 1-5.	

Designer's details

Designer's name: Matthew Adams
Designer's organisation: Energy Counsel
Designer's address: Viridor House, 3 Bolholt Terrace, Bury, BL8 1PP

Dynamic thermal model

Software: IESVE version 2025.1.0.0	
Weather file: Manchester_DSY1_2020High50_.epw	
Results file: Heatherdale-PartO-1.aps	
Number of rooms analysed: 286	
TM59: summer elevated air speed: 0.1	
TM59: occupant category: Category II (normal)	
Overheating mitigation strategy: MVHR, MEV and Openable Windows.	
Has the building construction proposal been modelled accurately?	YES
Have the analysed rooms passed the assessment for Approved Doc O Dynamic Thermal Modelling Method (CIBSE TM 59)?	YES
Designer's signature:	

Alderford Parade - All Plots

Summary

CIBSE TM59 overheating methodology for predominantly naturally ventilated rooms assesses against two criteria, (a) and (b) (for Category I occupancy, Tmax is reduced by 1K):

- Criterion (a) states that for living rooms, kitchens and bedrooms, the number of hours during which ΔT is greater than or equal to 1K from May to September (or November to March for southern hemisphere locations) shall not exceed 3% of occupied hours
- Criterion (b) states that the operative temperature of the bedrooms from 22:00-07:00 shall not exceed 26°C for more than 1% of annual hours (33 hours is therefore recorded as a fail). Approved document O applies limits to CIBSE TM59 section 3.3 (openings); these requirements are applied by appropriate assignment of MacroFlo types / scripted profiles in the model (see Modelled Openings Section).

CIBSE TM59 overheating methodology for predominantly mechanically ventilated rooms states the operative temperature of all rooms shall not exceed 26°C for more than 3% of annual occupied hours.

CIBSE TM59 also states that the inclusion of corridors in the overheating analysis is mandatory where community heating pipework runs through them. While there is no mandatory target for communal corridors, if an operative temperature of 28°C is exceeded for more than 3% of the total annual hours this should be identified as a significant risk.

Room name	Naturally ventilated Criterion a check	Naturally ventilated Criterion b check	Mechanically ventilated check	Corridor overheating risk check
B2_6_ Living Room	Pass	N/A	-	-
B2_7_ Living Room	Pass	N/A	-	-
B2_6_ Bedroom 4	Pass	Pass	-	-
B2_7_Bedroom 4	Pass	Pass	-	-
B2_7_ Bedroom 3	Pass	Pass	-	-
B2_6_Bedroom 3	Pass	Pass	-	-
B2_6_ Bedroom 2	Pass	Pass	-	-
B2_7_Bedroom 2	Pass	Pass	-	-
B2_7_Bedroom 1	Pass	Pass	-	-
B2_6_Bedroom 1	Pass	Pass	-	-
B6_23_Living	Pass	N/A	-	-
B6_22_Living	Pass	N/A	-	-
B6_23_Kitchen/Dining	Pass	N/A	-	-
B6_22_Kitchen/Dining	Pass	N/A	-	-
B6_23_ Bedroom 1	Pass	Pass	-	-
B6_23_Bedroom 2	Pass	Pass	-	-
B6_23_Bedroom 3	Pass	Pass	-	-
B6_22_Bedroom 1	Pass	Pass	-	-
B6_22_Bedroom 3	Pass	Pass	-	-
B6_22_Bedroom 2	Pass	Pass	-	-
B13_34_ Bedroom 3	Pass	Pass	-	-
B13_34_ Bedroom 2	Pass	Pass	-	-
B13_34_ Bedroom 1	Pass	Pass	-	-
B13_34_ Living Room	Pass	N/A	-	-
B13_34_ Kitchen/Dining	Pass	N/A	-	-
B24_69_Living	Pass	N/A	-	-
B24_69_Kitchen/Dining	Pass	N/A	-	-
B24_70_Living	Pass	N/A	-	-
B24_70_Kitchen/Dining	Pass	N/A	-	-

Alderford Parade - All Plots

Room name	Naturally ventilated Criterion a check	Naturally ventilated Criterion b check	Mechanically ventilated check	Corridor overheating risk check
B24_69_Bedroom 2	Pass	Pass	-	-
B24_70_Bedroom 2	Pass	Pass	-	-
B12_33_Living Room	Pass	N/A	-	-
B12_33_ Bedroom 1	Pass	Pass	-	-
B12_33_ Bedroom 4	Pass	Pass	-	-
B12_33_ Bedroom 2	Pass	Pass	-	-
B16_42_Bedroom 1	Pass	Pass	-	-
B16_40_Bedroom 1	Pass	Pass	-	-
B1_2_Bedroom 1	-	-	Pass	-
B1_1_Bedroom 1	-	-	Pass	-
B1_2_ Bedroom 2	-	-	Pass	-
B1_2_Bedroom 3	-	-	Pass	-
B1_1_ Bedroom 3	-	-	Pass	-
B1_1_Bedroom 2	-	-	Pass	-
B1_2_ Living Room	-	-	Pass	-
B1_1_ Living Room	-	-	Pass	-
B21_57_ Living Room	Pass	N/A	-	-
B21_57_Kitchen/Dining	Pass	N/A	-	-
B21_57_Bedroom 2	Pass	Pass	-	-
B21_57_Bedroom 1	Pass	Pass	-	-
B21_57_Bedroom 3	Pass	Pass	-	-
B20_56_ Living Room	Pass	N/A	-	-
B20_56_ Kitchen/Dining	Pass	N/A	-	-
B20_55_ Living Room	Pass	N/A	-	-
B20_55_ Kitchen/Dining	Pass	N/A	-	-
B20_56_ Bedroom 1	Pass	Pass	-	-
B20_56_ Bedroom 2	Pass	Pass	-	-
B20_55_ Bedroom 1	Pass	Pass	-	-
B20_55_ Bedroom 2	Pass	Pass	-	-
B22_58_ Kitchen/Dining	Pass	N/A	-	-
B22_58_Living Room	Pass	N/A	-	-
B22_58_ Bedroom 3	Pass	Pass	-	-
B22_58_ Bedroom 2	Pass	Pass	-	-
B14_35_Living Room	Pass	N/A	-	-
B14_35_Kitchen/Dining	Pass	N/A	-	-
B14_35_Bedroom 1	Pass	Pass	-	-
B14_35_Bedroom 2	Pass	Pass	-	-
B12_33_ Bedroom 3	Pass	Pass	-	-
B12_33_Kitchen/dining	Pass	N/A	-	-
B1_1_ Kitchen/Dining	-	-	Pass	-
B1_2_ Kitchen/Dining	-	-	Pass	-
B2_6_ Kitchen/Dining	Pass	N/A	-	-

Alderford Parade - All Plots

Room name	Naturally ventilated Criterion a check	Naturally ventilated Criterion b check	Mechanically ventilated check	Corridor overheating risk check
B2_7_ Kitchen/Dining	Pass	N/A	-	-
B16_41_ Living/Dining/Kitchen	-	-	Pass	-
B16_39_ Living/Dining/Kitchen	-	-	Pass	-
B16_42_Living/dining/Kitchen	Pass	N/A	-	-
B16_40_Living/dining/Kitchen	Pass	N/A	-	-
B23_ 59_Living/Dining/Kitchen	-	-	Pass	-
B23_59_Bedroom	-	-	Pass	-
B23_ 63_Living/Dining/Kitchen	-	-	Pass	-
B23_63_Bedroom	-	-	Pass	-
B16_41_Bedroom 1	-	-	Pass	-
B16_39_Bedroom 1	-	-	Pass	-
B1_3_Bedroom 1	-	-	Pass	-
B1_3_ Bedroom 2	-	-	Pass	-
B1_3_Bedroom 3	-	-	Pass	-
B1_3_ Living Room	-	-	Pass	-
B1_3_ Kitchen/Dining	-	-	Pass	-
B1_4_Bedroom 1	-	-	Pass	-
B1_4_ Bedroom 2	-	-	Pass	-
B1_4_Bedroom 3	-	-	Pass	-
B1_4_ Living Room	-	-	Pass	-
B1_4_ Kitchen/Dining	-	-	Pass	-
B1_5_Bedroom 1	-	-	Pass	-
B1_5_ Bedroom 2	-	-	Pass	-
B1_5_Bedroom 3	-	-	Pass	-
B1_5_ Living Room	-	-	Pass	-
B1_5_ Kitchen/Dining	-	-	Pass	-
B2_9_ Living Room	Pass	N/A	-	-
B2_8_ Living Room	Pass	N/A	-	-
B2_9_ Bedroom 4	Pass	Pass	-	-
B2_8_Bedroom 4	Pass	Pass	-	-
B2_8_ Bedroom 3	Pass	Pass	-	-
B2_9_Bedroom 3	Pass	Pass	-	-
B2_9_ Bedroom 2	Pass	Pass	-	-
B2_8_Bedroom 2	Pass	Pass	-	-
B2_8_Bedroom 1	Pass	Pass	-	-
B2_9_Bedroom 1	Pass	Pass	-	-
B2_9_ Kitchen/Dining	Pass	N/A	-	-

Alderford Parade - All Plots

Room name	Naturally ventilated Criterion a check	Naturally ventilated Criterion b check	Mechanically ventilated check	Corridor overheating risk check
B2_8_ Kitchen/Dining	Pass	N/A	-	-
B2_10_ Living Room	Pass	N/A	-	-
B2_11_ Living Room	Pass	N/A	-	-
B2_10_ Bedroom 4	Pass	Pass	-	-
B2_11_Bedroom 4	Pass	Pass	-	-
B2_11_ Bedroom 3	Pass	Pass	-	-
B2_10_Bedroom 3	Pass	Pass	-	-
B2_10_ Bedroom 2	Pass	Pass	-	-
B2_11_Bedroom 2	Pass	Pass	-	-
B2_11_Bedroom 1	Pass	Pass	-	-
B2_10_Bedroom 1	Pass	Pass	-	-
B2_10_ Kitchen/Dining	Pass	N/A	-	-
B2_11_ Kitchen/Dining	Pass	N/A	-	-
B2_13_ Living Room	Pass	N/A	-	-
B2_12_ Living Room	Pass	N/A	-	-
B2_13_ Bedroom 4	Pass	Pass	-	-
B2_12_Bedroom 4	Pass	Pass	-	-
B2_12_ Bedroom 3	Pass	Pass	-	-
B2_13_Bedroom 3	Pass	Pass	-	-
B2_13_ Bedroom 2	Pass	Pass	-	-
B2_12_Bedroom 2	Pass	Pass	-	-
B2_12_Bedroom 1	Pass	Pass	-	-
B2_13_Bedroom 1	Pass	Pass	-	-
B2_13_ Kitchen/Dining	Pass	N/A	-	-
B2_12_ Kitchen/Dining	Pass	N/A	-	-
B2_14_ Living Room	Pass	N/A	-	-
B2_15_ Living Room	Pass	N/A	-	-
B2_14_ Bedroom 4	Pass	Pass	-	-
B2_15_Bedroom 4	Pass	Pass	-	-
B2_15_ Bedroom 3	Pass	Pass	-	-
B2_14_Bedroom 3	Pass	Pass	-	-
B2_14_ Bedroom 2	Pass	Pass	-	-
B2_15_Bedroom 2	Pass	Pass	-	-
B2_15_Bedroom 1	Pass	Pass	-	-
B2_14_Bedroom 1	Pass	Pass	-	-
B2_14_ Kitchen/Dining	Pass	N/A	-	-
B2_15_ Kitchen/Dining	Pass	N/A	-	-
B2_17_ Living Room	Pass	N/A	-	-
B2_16_ Living Room	Pass	N/A	-	-
B2_17_ Bedroom 4	Pass	Pass	-	-
B2_16_Bedroom 4	Pass	Pass	-	-
B2_16_ Bedroom 3	Pass	Pass	-	-

Alderford Parade - All Plots

Room name	Naturally ventilated Criterion a check	Naturally ventilated Criterion b check	Mechanically ventilated check	Corridor overheating risk check
B2_17_Bedroom 3	Pass	Pass	-	-
B2_17_ Bedroom 2	Pass	Pass	-	-
B2_16_Bedroom 2	Pass	Pass	-	-
B2_16_Bedroom 1	Pass	Pass	-	-
B2_17_Bedroom 1	Pass	Pass	-	-
B2_17_ Kitchen/Dining	Pass	N/A	-	-
B2_16_ Kitchen/Dining	Pass	N/A	-	-
B2_18_ Living Room	Pass	N/A	-	-
B2_19_ Living Room	Pass	N/A	-	-
B2_18_ Bedroom 4	Pass	Pass	-	-
B2_19_Bedroom 4	Pass	Pass	-	-
B2_19_ Bedroom 3	Pass	Pass	-	-
B2_18_Bedroom 3	Pass	Pass	-	-
B2_18_ Bedroom 2	Pass	Pass	-	-
B2_19_Bedroom 2	Pass	Pass	-	-
B2_19_Bedroom 1	Pass	Pass	-	-
B2_18_Bedroom 1	Pass	Pass	-	-
B2_18_ Kitchen/Dining	Pass	N/A	-	-
B2_19_ Kitchen/Dining	Pass	N/A	-	-
B2_21_ Living Room	Pass	N/A	-	-
B2_20_ Living Room	Pass	N/A	-	-
B2_21_ Bedroom 4	Pass	Pass	-	-
B2_20_Bedroom 4	Pass	Pass	-	-
B2_20_ Bedroom 3	Pass	Pass	-	-
B2_21_Bedroom 3	Pass	Pass	-	-
B2_21_ Bedroom 2	Pass	Pass	-	-
B2_20_Bedroom 2	Pass	Pass	-	-
B2_20_Bedroom 1	Pass	Pass	-	-
B2_21_Bedroom 1	Pass	Pass	-	-
B2_21_ Kitchen/Dining	Pass	N/A	-	-
B2_20_ Kitchen/Dining	Pass	N/A	-	-
B6_28_Living	Pass	N/A	-	-
B6_27_Living	Pass	N/A	-	-
B6_28_Kitchen/Dining	Pass	N/A	-	-
B6_27_Kitchen/Dining	Pass	N/A	-	-
B6_28_ Bedroom 1	Pass	Pass	-	-
B6_28_Bedroom 2	Pass	Pass	-	-
B6_28_Bedroom 3	Pass	Pass	-	-
B6_27_Bedroom 1	Pass	Pass	-	-
B6_27_Bedroom 3	Pass	Pass	-	-
B6_27_Bedroom 2	Pass	Pass	-	-
B6_30_Living	Pass	N/A	-	-

Alderford Parade - All Plots

Room name	Naturally ventilated Criterion a check	Naturally ventilated Criterion b check	Mechanically ventilated check	Corridor overheating risk check
B6_29_Living	Pass	N/A	-	-
B6_30_Kitchen/Dining	Pass	N/A	-	-
B6_29_Kitchen/Dining	Pass	N/A	-	-
B6_30_ Bedroom 1	Pass	Pass	-	-
B6_30_Bedroom 2	Pass	Pass	-	-
B6_30_Bedroom 3	Pass	Pass	-	-
B6_29_Bedroom 1	Pass	Pass	-	-
B6_29_Bedroom 3	Pass	Pass	-	-
B6_29_Bedroom 2	Pass	Pass	-	-
B14_36_Living Room	Pass	N/A	-	-
B14_36_Kitchen/Dining	Pass	N/A	-	-
B14_36_Bedroom 1	Pass	Pass	-	-
B14_36_Bedroom 2	Pass	Pass	-	-
B8_26_Living Room	Pass	N/A	-	-
B8_26_Kitchen/Dining	Pass	N/A	-	-
B8_26_Bedroom 1	Pass	Pass	-	-
B8_26_Bedroom 2	Pass	Pass	-	-
B11_32_Living	Pass	N/A	-	-
B11_31_Living	Pass	N/A	-	-
B11_32_Kitchen/Dining	Pass	N/A	-	-
B11_31_Kitchen/Dining	Pass	N/A	-	-
B11_32_ Bedroom 1	Pass	Pass	-	-
B11_32_Bedroom 2	Pass	Pass	-	-
B11_32_Bedroom 3	Pass	Pass	-	-
B11_31_Bedroom 1	Pass	Pass	-	-
B11_31_Bedroom 3	Pass	Pass	-	-
B11_31_Bedroom 2	Pass	Pass	-	-
B15_37_Living Room	Pass	N/A	-	-
B15_37_Kitchen/Dining	Pass	N/A	-	-
B15_37_Bedroom 1	Pass	Pass	-	-
B15_37_Bedroom 2	Pass	Pass	-	-
B15_38_Living Room	Pass	N/A	-	-
B15_38_Kitchen/Dining	Pass	N/A	-	-
B15_38_Bedroom 1	Pass	Pass	-	-
B15_38_Bedroom 2	Pass	Pass	-	-
B17_44_Bedroom 1	Pass	Pass	-	-
B17_44_Bedroom 2	Pass	Pass	-	-
B17_46_Bedroom 1	Pass	Pass	-	-
B17_46_Bedroom 2	Pass	Pass	-	-
B17_43_Living/Dining/Kitchen	-	-	Pass	-

Alderford Parade - All Plots

Room name	Naturally ventilated Criterion a check	Naturally ventilated Criterion b check	Mechanically ventilated check	Corridor overheating risk check
B17_45_Living/Dining/Kitchen	-	-	Pass	-
B17_46_Living/Dining/Kitchen	Pass	N/A	-	-
B17_44_Living/Dining/Kitchen	Pass	N/A	-	-
B17_45_Bedroom 2	-	-	Pass	-
B17_43_Bedroom 2	-	-	Pass	-
B17_45_Bedroom 1	-	-	Pass	-
B17_43_Bedroom 1	-	-	Pass	-
B18_47_Bedroom 1	-	-	Pass	-
B18_47_Living/Dining/Kitchen	-	-	Pass	-
B18_48_Living/Dining/Kitchen	Pass	N/A	-	-
B18_48_Bedroom 2	Pass	Pass	-	-
B18_48_Bedroom 1	Pass	Pass	-	-
B18_49_Bedroom 1	-	-	Pass	-
B18_49_Living/Dining/Kitchen	-	-	Pass	-
B18_50_Living/Dining/Kitchen	Pass	N/A	-	-
B18_50_Bedroom 2	Pass	Pass	-	-
B18_50_Bedroom 1	Pass	Pass	-	-
B19_51_Bedroom 1	-	-	Pass	-
B19_51_Living/Dining/Kitchen	-	-	Pass	-
B19_52_Living/Dining/Kitchen	Pass	N/A	-	-
B19_52_Bedroom 2	Pass	Pass	-	-
B19_52_Bedroom 1	Pass	Pass	-	-
B19_53_Bedroom 1	-	-	Pass	-
B19_53_Living/Dining/Kitchen	-	-	Pass	-
B19_54_Living/Dining/Kitchen	Pass	N/A	-	-
B19_54_Bedroom 2	Pass	Pass	-	-
B19_54_Bedroom 1	Pass	Pass	-	-
B7_25_Living Room	Pass	N/A	-	-
B7_25_Kitchen/Dining	Pass	N/A	-	-
B7_25_Bedroom 1	Pass	Pass	-	-
B7_25_Bedroom 2	Pass	Pass	-	-
B7_24_Living Room	Pass	N/A	-	-
B7_24_Kitchen/Dining	Pass	N/A	-	-

Alderford Parade - All Plots

Room name	Naturally ventilated Criterion a check	Naturally ventilated Criterion b check	Mechanically ventilated check	Corridor overheating risk check
B7_24_Bedroom 1	Pass	Pass	-	-
B7_24_Bedroom 2	Pass	Pass	-	-
B22_58_Bedroom 1	Pass	Pass	-	-
B23_ 60_Living/Kitchen	Pass	N/A	-	-
B23_60_Bedroom	Pass	Pass	-	-
B23_ 64_Living	Pass	N/A	-	-
B23_64_Bedroom	Pass	Pass	-	-
B23_ 61_Living/Dining/Kitchen	-	-	Pass	-
B23_61_Bedroom	-	-	Pass	-
B23_ 62_Living/Kitchen	Pass	N/A	-	-
B23_62_Bedroom	Pass	Pass	-	-
B23_ 65_Living/Dining/Kitchen	-	-	Pass	-
B23_65_Bedroom	-	-	Pass	-
B23_ 66_Living	Pass	N/A	-	-
B23_66_Bedroom	Pass	Pass	-	-
B23_ 67_Living/Dining/Kitchen	-	-	Pass	-
B23_67_Bedroom	-	-	Pass	-
B23_ 68_Living/Kitchen	Pass	N/A	-	-
B23_68_Bedroom	Pass	Pass	-	-
B24_69_Bedroom 1	Pass	Pass	-	-
B24_70_Bedroom 1	Pass	Pass	-	-

Naturally ventilated rooms – criterion (a)

Criterion (a) states that for living rooms, kitchens and bedrooms, the number of hours during which ΔT is greater than or equal to 1K from May to September (or November to March for southern hemisphere locations) shall not exceed 3% of occupied hours.

Room name	Occupied hours	No. hours ΔT ≥ 1°K	% Occupied hours ΔT ≥ 1°K	Criterion a check
B2_6_ Living Room	1989	17	0.9	Pass
B2_7_ Living Room	1989	23	1.2	Pass
B2_6_ Bedroom 4	3672	20	0.5	Pass
B2_7_Bedroom 4	3672	28	0.8	Pass
B2_7_ Bedroom 3	3672	9	0.2	Pass
B2_6_Bedroom 3	3672	5	0.1	Pass
B2_6_ Bedroom 2	3672	29	0.8	Pass
B2_7_Bedroom 2	3672	35	1.0	Pass
B2_7_Bedroom 1	3672	9	0.2	Pass
B2_6_Bedroom 1	3672	5	0.1	Pass
B6_23_Living	1989	14	0.7	Pass
B6_22_Living	1989	18	0.9	Pass
B6_23_Kitchen/Dining	1989	16	0.8	Pass
B6_22_Kitchen/Dining	1989	17	0.9	Pass
B6_23_ Bedroom 1	3672	7	0.2	Pass
B6_23_Bedroom 2	3672	12	0.3	Pass
B6_23_Bedroom 3	3672	14	0.4	Pass
B6_22_Bedroom 1	3672	0	0.0	Pass
B6_22_Bedroom 3	3672	14	0.4	Pass
B6_22_Bedroom 2	3672	13	0.4	Pass
B13_34_ Bedroom 3	3672	14	0.4	Pass
B13_34_ Bedroom 2	3672	15	0.4	Pass
B13_34_ Bedroom 1	3672	17	0.5	Pass
B13_34_ Living Room	1989	21	1.1	Pass
B13_34_ Kitchen/Dining	1989	16	0.8	Pass
B24_69_Living	1989	17	0.9	Pass
B24_69_Kitchen/Dining	1989	11	0.6	Pass
B24_70_Living	1989	17	0.9	Pass
B24_70_Kitchen/Dining	1989	10	0.5	Pass
B24_69_Bedroom 2	3672	17	0.5	Pass
B24_70_Bedroom 2	3672	16	0.4	Pass
B12_33_Living Room	1989	13	0.7	Pass
B12_33_ Bedroom 1	3672	12	0.3	Pass
B12_33_ Bedroom 4	3672	8	0.2	Pass
B12_33_ Bedroom 2	3672	8	0.2	Pass
B16_42_Bedroom 1	3672	13	0.4	Pass
B16_40_Bedroom 1	3672	9	0.2	Pass

Alderford Parade - All Plots

Room name	Occupied hours	No. hours ΔT ≥ 1°K	% Occupied hours ΔT ≥ 1°K	Criterion a check
B21_57_ Living Room	1989	25	1.3	Pass
B21_57_Kitchen/Dining	1989	13	0.7	Pass
B21_57_Bedroom 2	3672	16	0.4	Pass
B21_57_Bedroom 1	3672	18	0.5	Pass
B21_57_Bedroom 3	3672	15	0.4	Pass
B20_56_ Living Room	1989	12	0.6	Pass
B20_56_ Kitchen/Dining	1989	12	0.6	Pass
B20_55_ Living Room	1989	18	0.9	Pass
B20_55_ Kitchen/Dining	1989	15	0.8	Pass
B20_56_ Bedroom 1	3672	14	0.4	Pass
B20_56_ Bedroom 2	3672	12	0.3	Pass
B20_55_ Bedroom 1	3672	14	0.4	Pass
B20_55_ Bedroom 2	3672	3	0.1	Pass
B22_58_ Kitchen/Dining	1989	14	0.7	Pass
B22_58_Living Room	1989	15	0.8	Pass
B22_58_ Bedroom 3	3672	21	0.6	Pass
B22_58_ Bedroom 2	3672	22	0.6	Pass
B14_35_Living Room	1989	18	0.9	Pass
B14_35_Kitchen/Dining	1989	9	0.5	Pass
B14_35_Bedroom 1	3672	13	0.4	Pass
B14_35_Bedroom 2	3672	25	0.7	Pass
B12_33_ Bedroom 3	3672	12	0.3	Pass
B12_33_Kitchen/dining	1989	12	0.6	Pass
B2_6_ Kitchen/Dining	1989	19	1.0	Pass
B2_7_ Kitchen/Dining	1989	22	1.1	Pass
B16_42_Living/dining/Kitchen	1989	19	1.0	Pass
B16_40_Living/dining/Kitchen	1989	13	0.7	Pass
B2_9_ Living Room	1989	15	0.8	Pass
B2_8_ Living Room	1989	23	1.2	Pass
B2_9_ Bedroom 4	3672	20	0.5	Pass
B2_8_Bedroom 4	3672	28	0.8	Pass
B2_8_ Bedroom 3	3672	9	0.2	Pass
B2_9_Bedroom 3	3672	5	0.1	Pass
B2_9_ Bedroom 2	3672	29	0.8	Pass
B2_8_Bedroom 2	3672	35	1.0	Pass
B2_8_Bedroom 1	3672	8	0.2	Pass
B2_9_Bedroom 1	3672	6	0.2	Pass
B2_9_ Kitchen/Dining	1989	19	1.0	Pass
B2_8_ Kitchen/Dining	1989	22	1.1	Pass
B2_10_ Living Room	1989	17	0.9	Pass

Alderford Parade - All Plots

Room name	Occupied hours	No. hours ΔT ≥ 1°K	% Occupied hours ΔT ≥ 1°K	Criterion a check
B2_11_ Living Room	1989	23	1.2	Pass
B2_10_ Bedroom 4	3672	20	0.5	Pass
B2_11_Bedroom 4	3672	28	0.8	Pass
B2_11_ Bedroom 3	3672	9	0.2	Pass
B2_10_Bedroom 3	3672	5	0.1	Pass
B2_10_ Bedroom 2	3672	29	0.8	Pass
B2_11_Bedroom 2	3672	35	1.0	Pass
B2_11_Bedroom 1	3672	9	0.2	Pass
B2_10_Bedroom 1	3672	5	0.1	Pass
B2_10_ Kitchen/Dining	1989	19	1.0	Pass
B2_11_ Kitchen/Dining	1989	22	1.1	Pass
B2_13_ Living Room	1989	15	0.8	Pass
B2_12_ Living Room	1989	23	1.2	Pass
B2_13_ Bedroom 4	3672	20	0.5	Pass
B2_12_Bedroom 4	3672	28	0.8	Pass
B2_12_ Bedroom 3	3672	9	0.2	Pass
B2_13_Bedroom 3	3672	5	0.1	Pass
B2_13_ Bedroom 2	3672	29	0.8	Pass
B2_12_Bedroom 2	3672	35	1.0	Pass
B2_12_Bedroom 1	3672	8	0.2	Pass
B2_13_Bedroom 1	3672	6	0.2	Pass
B2_13_ Kitchen/Dining	1989	19	1.0	Pass
B2_12_ Kitchen/Dining	1989	22	1.1	Pass
B2_14_ Living Room	1989	17	0.9	Pass
B2_15_ Living Room	1989	23	1.2	Pass
B2_14_ Bedroom 4	3672	20	0.5	Pass
B2_15_Bedroom 4	3672	28	0.8	Pass
B2_15_ Bedroom 3	3672	9	0.2	Pass
B2_14_Bedroom 3	3672	5	0.1	Pass
B2_14_ Bedroom 2	3672	29	0.8	Pass
B2_15_Bedroom 2	3672	35	1.0	Pass
B2_15_Bedroom 1	3672	9	0.2	Pass
B2_14_Bedroom 1	3672	5	0.1	Pass
B2_14_ Kitchen/Dining	1989	19	1.0	Pass
B2_15_ Kitchen/Dining	1989	22	1.1	Pass
B2_17_ Living Room	1989	15	0.8	Pass
B2_16_ Living Room	1989	23	1.2	Pass
B2_17_ Bedroom 4	3672	20	0.5	Pass
B2_16_Bedroom 4	3672	28	0.8	Pass
B2_16_ Bedroom 3	3672	9	0.2	Pass
B2_17_Bedroom 3	3672	5	0.1	Pass
B2_17_ Bedroom 2	3672	29	0.8	Pass

Alderford Parade - All Plots

Room name	Occupied hours	No. hours ΔT ≥ 1°K	% Occupied hours ΔT ≥ 1°K	Criterion a check
B2_16_Bedroom 2	3672	35	1.0	Pass
B2_16_Bedroom 1	3672	8	0.2	Pass
B2_17_Bedroom 1	3672	6	0.2	Pass
B2_17_ Kitchen/Dining	1989	19	1.0	Pass
B2_16_ Kitchen/Dining	1989	22	1.1	Pass
B2_18_ Living Room	1989	17	0.9	Pass
B2_19_ Living Room	1989	23	1.2	Pass
B2_18_ Bedroom 4	3672	20	0.5	Pass
B2_19_Bedroom 4	3672	28	0.8	Pass
B2_19_ Bedroom 3	3672	9	0.2	Pass
B2_18_Bedroom 3	3672	5	0.1	Pass
B2_18_ Bedroom 2	3672	29	0.8	Pass
B2_19_Bedroom 2	3672	35	1.0	Pass
B2_19_Bedroom 1	3672	9	0.2	Pass
B2_18_Bedroom 1	3672	5	0.1	Pass
B2_18_ Kitchen/Dining	1989	19	1.0	Pass
B2_19_ Kitchen/Dining	1989	22	1.1	Pass
B2_21_ Living Room	1989	20	1.0	Pass
B2_20_ Living Room	1989	24	1.2	Pass
B2_21_ Bedroom 4	3672	20	0.5	Pass
B2_20_Bedroom 4	3672	28	0.8	Pass
B2_20_ Bedroom 3	3672	9	0.2	Pass
B2_21_Bedroom 3	3672	9	0.2	Pass
B2_21_ Bedroom 2	3672	30	0.8	Pass
B2_20_Bedroom 2	3672	35	1.0	Pass
B2_20_Bedroom 1	3672	9	0.2	Pass
B2_21_Bedroom 1	3672	7	0.2	Pass
B2_21_ Kitchen/Dining	1989	19	1.0	Pass
B2_20_ Kitchen/Dining	1989	22	1.1	Pass
B6_28_Living	1989	18	0.9	Pass
B6_27_Living	1989	14	0.7	Pass
B6_28_Kitchen/Dining	1989	17	0.9	Pass
B6_27_Kitchen/Dining	1989	16	0.8	Pass
B6_28_ Bedroom 1	3672	8	0.2	Pass
B6_28_Bedroom 2	3672	15	0.4	Pass
B6_28_Bedroom 3	3672	14	0.4	Pass
B6_27_Bedroom 1	3672	8	0.2	Pass
B6_27_Bedroom 3	3672	14	0.4	Pass
B6_27_Bedroom 2	3672	15	0.4	Pass
B6_30_Living	1989	20	1.0	Pass
B6_29_Living	1989	14	0.7	Pass
B6_30_Kitchen/Dining	1989	17	0.9	Pass

Alderford Parade - All Plots

Room name	Occupied hours	No. hours ΔT ≥ 1°K	% Occupied hours ΔT ≥ 1°K	Criterion a check
B6_29_Kitchen/Dining	1989	16	0.8	Pass
B6_30_ Bedroom 1	3672	8	0.2	Pass
B6_30_Bedroom 2	3672	15	0.4	Pass
B6_30_Bedroom 3	3672	14	0.4	Pass
B6_29_Bedroom 1	3672	8	0.2	Pass
B6_29_Bedroom 3	3672	14	0.4	Pass
B6_29_Bedroom 2	3672	15	0.4	Pass
B14_36_Living Room	1989	23	1.2	Pass
B14_36_Kitchen/Dining	1989	12	0.6	Pass
B14_36_Bedroom 1	3672	14	0.4	Pass
B14_36_Bedroom 2	3672	29	0.8	Pass
B8_26_Living Room	1989	16	0.8	Pass
B8_26_Kitchen/Dining	1989	15	0.8	Pass
B8_26_Bedroom 1	3672	16	0.4	Pass
B8_26_Bedroom 2	3672	11	0.3	Pass
B11_32_Living	1989	14	0.7	Pass
B11_31_Living	1989	15	0.8	Pass
B11_32_Kitchen/Dining	1989	16	0.8	Pass
B11_31_Kitchen/Dining	1989	17	0.9	Pass
B11_32_ Bedroom 1	3672	5	0.1	Pass
B11_32_Bedroom 2	3672	15	0.4	Pass
B11_32_Bedroom 3	3672	14	0.4	Pass
B11_31_Bedroom 1	3672	12	0.3	Pass
B11_31_Bedroom 3	3672	14	0.4	Pass
B11_31_Bedroom 2	3672	19	0.5	Pass
B15_37_Living Room	1989	18	0.9	Pass
B15_37_Kitchen/Dining	1989	10	0.5	Pass
B15_37_Bedroom 1	3672	13	0.4	Pass
B15_37_Bedroom 2	3672	26	0.7	Pass
B15_38_Living Room	1989	23	1.2	Pass
B15_38_Kitchen/Dining	1989	12	0.6	Pass
B15_38_Bedroom 1	3672	14	0.4	Pass
B15_38_Bedroom 2	3672	33	0.9	Pass
B17_44_Bedroom 1	3672	29	0.8	Pass
B17_44_Bedroom 2	3672	14	0.4	Pass
B17_46_Bedroom 1	3672	29	0.8	Pass
B17_46_Bedroom 2	3672	14	0.4	Pass
B17_46_Living/Dining/Kitchen	1989	10	0.5	Pass
B17_44_Living/Dining/Kitchen	1989	15	0.8	Pass

Alderford Parade - All Plots

Room name	Occupied hours	No. hours ΔT ≥ 1°K	% Occupied hours ΔT ≥ 1°K	Criterion a check
B18_48_Living/Dining/Kitchen	1989	9	0.5	Pass
B18_48_Bedroom 2	3672	15	0.4	Pass
B18_48_Bedroom 1	3672	26	0.7	Pass
B18_50_Living/Dining/Kitchen	1989	10	0.5	Pass
B18_50_Bedroom 2	3672	17	0.5	Pass
B18_50_Bedroom 1	3672	34	0.9	Pass
B19_52_Living/Dining/Kitchen	1989	9	0.5	Pass
B19_52_Bedroom 2	3672	15	0.4	Pass
B19_52_Bedroom 1	3672	26	0.7	Pass
B19_54_Living/Dining/Kitchen	1989	11	0.6	Pass
B19_54_Bedroom 2	3672	15	0.4	Pass
B19_54_Bedroom 1	3672	28	0.8	Pass
B7_25_Living Room	1989	13	0.7	Pass
B7_25_Kitchen/Dining	1989	15	0.8	Pass
B7_25_Bedroom 1	3672	20	0.5	Pass
B7_25_Bedroom 2	3672	10	0.3	Pass
B7_24_Living Room	1989	13	0.7	Pass
B7_24_Kitchen/Dining	1989	16	0.8	Pass
B7_24_Bedroom 1	3672	19	0.5	Pass
B7_24_Bedroom 2	3672	8	0.2	Pass
B22_58_Bedroom 1	3672	14	0.4	Pass
B23_ 60_Living/Kitchen	1989	15	0.8	Pass
B23_60_Bedroom	3672	16	0.4	Pass
B23_ 64_Living	1989	17	0.9	Pass
B23_64_Bedroom	3672	16	0.4	Pass
B23_ 62_Living/Kitchen	1989	15	0.8	Pass
B23_62_Bedroom	3672	16	0.4	Pass
B23_ 66_Living	1989	17	0.9	Pass
B23_66_Bedroom	3672	17	0.5	Pass
B23_ 68_Living/Kitchen	1989	15	0.8	Pass
B23_68_Bedroom	3672	14	0.4	Pass
B24_69_Bedroom 1	3672	20	0.5	Pass
B24_70_Bedroom 1	3672	15	0.4	Pass

Naturally ventilated rooms – criterion (b)

Criterion (b) states that the operative temperature of the bedrooms from 22:00-07:00 shall not exceed 26°C for more than 1% of annual hours (33 hours is therefore recorded as a fail). Any rooms that are not bedrooms are therefore not assessed, hence the corresponding N/A values.

Room name	No. hours > 26°C 22:00-24:00	No. hours > 26°C 00:00-07:00	Total hours > 26°C	Criterion b check
B2_6_ Living Room	N/A	N/A	N/A	N/A
B2_7_ Living Room	N/A	N/A	N/A	N/A
B2_6_ Bedroom 4	14	1	15	Pass
B2_7_Bedroom 4	14	1	15	Pass
B2_7_ Bedroom 3	13	0	13	Pass
B2_6_Bedroom 3	11	0	11	Pass
B2_6_ Bedroom 2	14	1	15	Pass
B2_7_Bedroom 2	14	1	15	Pass
B2_7_Bedroom 1	4	0	4	Pass
B2_6_Bedroom 1	2	0	2	Pass
B6_23_Living	N/A	N/A	N/A	N/A
B6_22_Living	N/A	N/A	N/A	N/A
B6_23_Kitchen/Dining	N/A	N/A	N/A	N/A
B6_22_Kitchen/Dining	N/A	N/A	N/A	N/A
B6_23_ Bedroom 1	1	0	1	Pass
B6_23_Bedroom 2	12	2	14	Pass
B6_23_Bedroom 3	2	0	2	Pass
B6_22_Bedroom 1	9	0	9	Pass
B6_22_Bedroom 3	2	0	2	Pass
B6_22_Bedroom 2	1	0	1	Pass
B13_34_ Bedroom 3	4	0	4	Pass
B13_34_ Bedroom 2	11	0	11	Pass
B13_34_ Bedroom 1	3	0	3	Pass
B13_34_ Living Room	N/A	N/A	N/A	N/A
B13_34_ Kitchen/Dining	N/A	N/A	N/A	N/A
B24_69_Living	N/A	N/A	N/A	N/A
B24_69_Kitchen/Dining	N/A	N/A	N/A	N/A
B24_70_Living	N/A	N/A	N/A	N/A
B24_70_Kitchen/Dining	N/A	N/A	N/A	N/A
B24_69_Bedroom 2	3	0	3	Pass
B24_70_Bedroom 2	3	0	3	Pass
B12_33_Living Room	N/A	N/A	N/A	N/A
B12_33_ Bedroom 1	1	0	1	Pass
B12_33_ Bedroom 4	20	9	29	Pass
B12_33_ Bedroom 2	1	0	1	Pass
B16_42_Bedroom 1	4	0	4	Pass
B16_40_Bedroom 1	4	0	4	Pass

Alderford Parade - All Plots

Room name	No. hours > 26°C 22:00-24:00	No. hours > 26°C 00:00-07:00	Total hours > 26°C	Criterion b check
B21_57_ Living Room	N/A	N/A	N/A	N/A
B21_57_Kitchen/Dining	N/A	N/A	N/A	N/A
B21_57_Bedroom 2	14	2	16	Pass
B21_57_Bedroom 1	5	0	5	Pass
B21_57_Bedroom 3	21	8	29	Pass
B20_56_ Living Room	N/A	N/A	N/A	N/A
B20_56_ Kitchen/Dining	N/A	N/A	N/A	N/A
B20_55_ Living Room	N/A	N/A	N/A	N/A
B20_55_ Kitchen/Dining	N/A	N/A	N/A	N/A
B20_56_ Bedroom 1	14	2	16	Pass
B20_56_ Bedroom 2	1	0	1	Pass
B20_55_ Bedroom 1	14	3	17	Pass
B20_55_ Bedroom 2	13	2	15	Pass
B22_58_ Kitchen/Dining	N/A	N/A	N/A	N/A
B22_58_Living Room	N/A	N/A	N/A	N/A
B22_58_ Bedroom 3	5	0	5	Pass
B22_58_ Bedroom 2	9	0	9	Pass
B14_35_Living Room	N/A	N/A	N/A	N/A
B14_35_Kitchen/Dining	N/A	N/A	N/A	N/A
B14_35_Bedroom 1	14	2	16	Pass
B14_35_Bedroom 2	11	0	11	Pass
B12_33_ Bedroom 3	1	0	1	Pass
B12_33_Kitchen/dining	N/A	N/A	N/A	N/A
B2_6_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_7_ Kitchen/Dining	N/A	N/A	N/A	N/A
B16_42_Living/dining/Kitchen	N/A	N/A	N/A	N/A
B16_40_Living/dining/Kitchen	N/A	N/A	N/A	N/A
B2_9_ Living Room	N/A	N/A	N/A	N/A
B2_8_ Living Room	N/A	N/A	N/A	N/A
B2_9_ Bedroom 4	14	1	15	Pass
B2_8_Bedroom 4	14	1	15	Pass
B2_8_ Bedroom 3	13	0	13	Pass
B2_9_Bedroom 3	11	0	11	Pass
B2_9_ Bedroom 2	14	1	15	Pass
B2_8_Bedroom 2	14	1	15	Pass
B2_8_Bedroom 1	4	0	4	Pass
B2_9_Bedroom 1	2	0	2	Pass
B2_9_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_8_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_10_ Living Room	N/A	N/A	N/A	N/A

Alderford Parade - All Plots

Room name	No. hours > 26°C 22:00-24:00	No. hours > 26°C 00:00-07:00	Total hours > 26°C	Criterion b check
B2_11_ Living Room	N/A	N/A	N/A	N/A
B2_10_ Bedroom 4	14	2	16	Pass
B2_11_Bedroom 4	14	1	15	Pass
B2_11_ Bedroom 3	13	1	14	Pass
B2_10_Bedroom 3	11	0	11	Pass
B2_10_ Bedroom 2	14	1	15	Pass
B2_11_Bedroom 2	14	1	15	Pass
B2_11_Bedroom 1	4	0	4	Pass
B2_10_Bedroom 1	2	0	2	Pass
B2_10_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_11_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_13_ Living Room	N/A	N/A	N/A	N/A
B2_12_ Living Room	N/A	N/A	N/A	N/A
B2_13_ Bedroom 4	14	2	16	Pass
B2_12_Bedroom 4	14	1	15	Pass
B2_12_ Bedroom 3	13	0	13	Pass
B2_13_Bedroom 3	11	0	11	Pass
B2_13_ Bedroom 2	14	1	15	Pass
B2_12_Bedroom 2	14	1	15	Pass
B2_12_Bedroom 1	4	0	4	Pass
B2_13_Bedroom 1	2	0	2	Pass
B2_13_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_12_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_14_ Living Room	N/A	N/A	N/A	N/A
B2_15_ Living Room	N/A	N/A	N/A	N/A
B2_14_ Bedroom 4	14	1	15	Pass
B2_15_Bedroom 4	14	1	15	Pass
B2_15_ Bedroom 3	13	0	13	Pass
B2_14_Bedroom 3	11	0	11	Pass
B2_14_ Bedroom 2	14	1	15	Pass
B2_15_Bedroom 2	14	1	15	Pass
B2_15_Bedroom 1	4	0	4	Pass
B2_14_Bedroom 1	2	0	2	Pass
B2_14_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_15_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_17_ Living Room	N/A	N/A	N/A	N/A
B2_16_ Living Room	N/A	N/A	N/A	N/A
B2_17_ Bedroom 4	14	2	16	Pass
B2_16_Bedroom 4	14	1	15	Pass
B2_16_ Bedroom 3	13	1	14	Pass
B2_17_Bedroom 3	11	0	11	Pass
B2_17_ Bedroom 2	14	1	15	Pass

Alderford Parade - All Plots

Room name	No. hours > 26°C 22:00-24:00	No. hours > 26°C 00:00-07:00	Total hours > 26°C	Criterion b check
B2_16_Bedroom 2	14	1	15	Pass
B2_16_Bedroom 1	4	0	4	Pass
B2_17_Bedroom 1	2	0	2	Pass
B2_17_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_16_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_18_ Living Room	N/A	N/A	N/A	N/A
B2_19_ Living Room	N/A	N/A	N/A	N/A
B2_18_ Bedroom 4	14	1	15	Pass
B2_19_Bedroom 4	14	1	15	Pass
B2_19_ Bedroom 3	13	0	13	Pass
B2_18_Bedroom 3	11	0	11	Pass
B2_18_ Bedroom 2	14	1	15	Pass
B2_19_Bedroom 2	14	1	15	Pass
B2_19_Bedroom 1	4	0	4	Pass
B2_18_Bedroom 1	2	0	2	Pass
B2_18_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_19_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_21_ Living Room	N/A	N/A	N/A	N/A
B2_20_ Living Room	N/A	N/A	N/A	N/A
B2_21_ Bedroom 4	14	2	16	Pass
B2_20_Bedroom 4	14	1	15	Pass
B2_20_ Bedroom 3	13	1	14	Pass
B2_21_Bedroom 3	13	2	15	Pass
B2_21_ Bedroom 2	14	2	16	Pass
B2_20_Bedroom 2	14	1	15	Pass
B2_20_Bedroom 1	4	0	4	Pass
B2_21_Bedroom 1	2	0	2	Pass
B2_21_ Kitchen/Dining	N/A	N/A	N/A	N/A
B2_20_ Kitchen/Dining	N/A	N/A	N/A	N/A
B6_28_Living	N/A	N/A	N/A	N/A
B6_27_Living	N/A	N/A	N/A	N/A
B6_28_Kitchen/Dining	N/A	N/A	N/A	N/A
B6_27_Kitchen/Dining	N/A	N/A	N/A	N/A
B6_28_ Bedroom 1	1	0	1	Pass
B6_28_Bedroom 2	2	0	2	Pass
B6_28_Bedroom 3	2	0	2	Pass
B6_27_Bedroom 1	1	0	1	Pass
B6_27_Bedroom 3	2	0	2	Pass
B6_27_Bedroom 2	1	0	1	Pass
B6_30_Living	N/A	N/A	N/A	N/A
B6_29_Living	N/A	N/A	N/A	N/A
B6_30_Kitchen/Dining	N/A	N/A	N/A	N/A

Alderford Parade - All Plots

Room name	No. hours > 26°C 22:00-24:00	No. hours > 26°C 00:00-07:00	Total hours > 26°C	Criterion b check
B6_29_Kitchen/Dining	N/A	N/A	N/A	N/A
B6_30_ Bedroom 1	1	0	1	Pass
B6_30_Bedroom 2	1	0	1	Pass
B6_30_Bedroom 3	2	0	2	Pass
B6_29_Bedroom 1	1	0	1	Pass
B6_29_Bedroom 3	2	0	2	Pass
B6_29_Bedroom 2	1	0	1	Pass
B14_36_Living Room	N/A	N/A	N/A	N/A
B14_36_Kitchen/Dining	N/A	N/A	N/A	N/A
B14_36_Bedroom 1	15	2	17	Pass
B14_36_Bedroom 2	12	0	12	Pass
B8_26_Living Room	N/A	N/A	N/A	N/A
B8_26_Kitchen/Dining	N/A	N/A	N/A	N/A
B8_26_Bedroom 1	15	4	19	Pass
B8_26_Bedroom 2	4	0	4	Pass
B11_32_Living	N/A	N/A	N/A	N/A
B11_31_Living	N/A	N/A	N/A	N/A
B11_32_Kitchen/Dining	N/A	N/A	N/A	N/A
B11_31_Kitchen/Dining	N/A	N/A	N/A	N/A
B11_32_ Bedroom 1	1	0	1	Pass
B11_32_Bedroom 2	1	0	1	Pass
B11_32_Bedroom 3	2	0	2	Pass
B11_31_Bedroom 1	1	0	1	Pass
B11_31_Bedroom 3	2	0	2	Pass
B11_31_Bedroom 2	1	0	1	Pass
B15_37_Living Room	N/A	N/A	N/A	N/A
B15_37_Kitchen/Dining	N/A	N/A	N/A	N/A
B15_37_Bedroom 1	14	2	16	Pass
B15_37_Bedroom 2	11	0	11	Pass
B15_38_Living Room	N/A	N/A	N/A	N/A
B15_38_Kitchen/Dining	N/A	N/A	N/A	N/A
B15_38_Bedroom 1	15	2	17	Pass
B15_38_Bedroom 2	12	0	12	Pass
B17_44_Bedroom 1	11	0	11	Pass
B17_44_Bedroom 2	6	0	6	Pass
B17_46_Bedroom 1	11	0	11	Pass
B17_46_Bedroom 2	6	0	6	Pass
B17_46_Living/Dining/Kitchen	N/A	N/A	N/A	N/A
B17_44_Living/Dining/Kitchen	N/A	N/A	N/A	N/A

Alderford Parade - All Plots

Room name	No. hours > 26°C 22:00-24:00	No. hours > 26°C 00:00-07:00	Total hours > 26°C	Criterion b check
B18_48_Living/Dining/Kitchen	N/A	N/A	N/A	N/A
B18_48_Bedroom 2	8	0	8	Pass
B18_48_Bedroom 1	11	0	11	Pass
B18_50_Living/Dining/Kitchen	N/A	N/A	N/A	N/A
B18_50_Bedroom 2	9	0	9	Pass
B18_50_Bedroom 1	14	0	14	Pass
B19_52_Living/Dining/Kitchen	N/A	N/A	N/A	N/A
B19_52_Bedroom 2	8	0	8	Pass
B19_52_Bedroom 1	11	0	11	Pass
B19_54_Living/Dining/Kitchen	N/A	N/A	N/A	N/A
B19_54_Bedroom 2	8	0	8	Pass
B19_54_Bedroom 1	11	0	11	Pass
B7_25_Living Room	N/A	N/A	N/A	N/A
B7_25_Kitchen/Dining	N/A	N/A	N/A	N/A
B7_25_Bedroom 1	15	3	18	Pass
B7_25_Bedroom 2	6	0	6	Pass
B7_24_Living Room	N/A	N/A	N/A	N/A
B7_24_Kitchen/Dining	N/A	N/A	N/A	N/A
B7_24_Bedroom 1	14	3	17	Pass
B7_24_Bedroom 2	7	0	7	Pass
B22_58_Bedroom 1	5	0	5	Pass
B23_ 60_Living/Kitchen	N/A	N/A	N/A	N/A
B23_60_Bedroom	4	0	4	Pass
B23_ 64_Living	N/A	N/A	N/A	N/A
B23_64_Bedroom	21	8	29	Pass
B23_ 62_Living/Kitchen	N/A	N/A	N/A	N/A
B23_62_Bedroom	4	0	4	Pass
B23_ 66_Living	N/A	N/A	N/A	N/A
B23_66_Bedroom	21	8	29	Pass
B23_ 68_Living/Kitchen	N/A	N/A	N/A	N/A
B23_68_Bedroom	4	0	4	Pass
B24_69_Bedroom 1	5	0	5	Pass
B24_70_Bedroom 1	4	0	4	Pass

Mechanically ventilated rooms

CIBSE TM59 overheating methodology for predominantly mech. vent. rooms states the operative temperature of all rooms shall not exceed 26°C for more than 3% of annual occupied hours.

Room name	No. hours > 26°C	% Annual hours > 26°C	Mechanically ventilated check
B1_2_Bedroom 1	138	1.6	Pass
B1_1_Bedroom 1	177	2.0	Pass
B1_2_ Bedroom 2	96	1.1	Pass
B1_2_Bedroom 3	213	2.4	Pass
B1_1_ Bedroom 3	170	1.9	Pass
B1_1_Bedroom 2	104	1.2	Pass
B1_2_ Living Room	125	2.6	Pass
B1_1_ Living Room	111	2.3	Pass
B1_1_ Kitchen/Dining	106	2.2	Pass
B1_2_ Kitchen/Dining	114	2.4	Pass
B16_41_ Living/Dining/Kitchen	91	1.9	Pass
B16_39_ Living/Dining/Kitchen	84	1.8	Pass
B23_ 59_Living/Dining/Kitchen	88	1.9	Pass
B23_59_Bedroom	222	2.5	Pass
B23_ 63_Living/Dining/Kitchen	87	1.8	Pass
B23_63_Bedroom	234	2.7	Pass
B16_41_Bedroom 1	136	1.6	Pass
B16_39_Bedroom 1	209	2.4	Pass
B1_3_Bedroom 1	134	1.5	Pass
B1_3_ Bedroom 2	91	1.0	Pass
B1_3_Bedroom 3	210	2.4	Pass
B1_3_ Living Room	128	2.7	Pass
B1_3_ Kitchen/Dining	112	2.4	Pass
B1_4_Bedroom 1	134	1.5	Pass
B1_4_ Bedroom 2	90	1.0	Pass
B1_4_Bedroom 3	211	2.4	Pass
B1_4_ Living Room	126	2.7	Pass
B1_4_ Kitchen/Dining	113	2.4	Pass
B1_5_Bedroom 1	126	1.4	Pass
B1_5_ Bedroom 2	84	1.0	Pass
B1_5_Bedroom 3	205	2.3	Pass
B1_5_ Living Room	118	2.5	Pass
B1_5_ Kitchen/Dining	107	2.3	Pass
B17_43_Living/Dining/Kitchen	62	1.3	Pass
B17_45_Living/Dining/Kitchen	48	1.0	Pass
B17_45_Bedroom 2	70	0.8	Pass
B17_43_Bedroom 2	71	0.8	Pass

Alderford Parade - All Plots

Room name	No. hours > 26°C	% Annual hours > 26°C	Mechanically ventilated check
B17_45_Bedroom 1	58	0.7	Pass
B17_43_Bedroom 1	58	0.7	Pass
B18_47_Bedroom 1	149	1.7	Pass
B18_47_Living/Dining/Kitchen	71	1.5	Pass
B18_49_Bedroom 1	152	1.7	Pass
B18_49_Living/Dining/Kitchen	71	1.5	Pass
B19_51_Bedroom 1	149	1.7	Pass
B19_51_Living/Dining/Kitchen	71	1.5	Pass
B19_53_Bedroom 1	147	1.7	Pass
B19_53_Living/Dining/Kitchen	82	1.7	Pass
B23_ 61_Living/Dining/Kitchen	87	1.8	Pass
B23_61_Bedroom	224	2.6	Pass
B23_ 65_Living/Dining/Kitchen	87	1.8	Pass
B23_65_Bedroom	231	2.6	Pass
B23_ 67_Living/Dining/Kitchen	87	1.8	Pass
B23_67_Bedroom	232	2.6	Pass

Communal corridors

CIBSE TM59 states that whilst there is no mandatory target for communal corridors, if an operative temperature of 28°C is exceeded for more than 3% of annual hours, then this should be identified as a significant risk within the TM59 overheating report.

Room name	No. hours > 28°C	% Annual hours > 28°C	Corridor overheating risk check
No corridors	N/A	N/A	N/A

Modelled details & overheating mitigation strategy

Approved document O: Providing Information & Appendix B requires information about the model and the overheating mitigation strategy. The following tables detail the modelling method and mitigation strategies applied to each analysed room. Where multiple active openings per space (windows & louvres) exist they are all listed. Occupancy, equipment and lighting profiles for occupied rooms comply with TM59 section 5.

Modelled occupancy

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B2_6_ Living Room	16.6	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_7_ Living Room	17.41	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_6_ Bedroom 4	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_7_Bedroom 4	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_7_ Bedroom 3	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_6_Bedroom 3	13.69	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_6_ Bedroom 2	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_7_Bedroom 2	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_7_Bedroom 1	14.03	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_6_Bedroom 1	13.4	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_23_Living	16.77	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B6_22_Living	16.81	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B6_23_Kitchen/Dining	15.61	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B6_22_Kitchen/Dining	15.49	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B6_23_ Bedroom 1	12.72	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_23_Bedroom 2	10.67	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_23_Bedroom 3	9.19	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B6_22_Bedroom 1	12.94	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_22_Bedroom 3	9.15	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B6_22_Bedroom 2	10.76	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B13_34_ Bedroom 3	8.26	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B13_34_ Bedroom 2	12.22	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B13_34_ Bedroom 1	14.23	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B13_34_ Living Room	15.07	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B13_34_ Kitchen/Dining	16.49	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B24_69_Living	13.98	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B24_69_Kitchen/Dining	17.47	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B24_70_Living	13.84	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B24_70_Kitchen/Dining	17.53	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B24_69_Bedroom 2	14.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B24_70_Bedroom 2	14.32	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B12_33_Living Room	24.22	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B12_33_ Bedroom 1	14.01	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B12_33_ Bedroom 4	8.51	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B12_33_ Bedroom 2	12.54	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B16_42_Bedroom 1	15.04	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B16_40_Bedroom 1	15.04	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_2_Bedroom 1	15.0	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_1_Bedroom 1	16.24	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_2_ Bedroom 2	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_2_Bedroom 3	9.85	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B1_1_ Bedroom 3	9.39	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B1_1_Bedroom 2	15.67	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_2_ Living Room	17.41	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B1_1_ Living Room	16.6	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B21_57_ Living Room	17.07	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B21_57_Kitchen/Dining	17.46	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B21_57_Bedroom 2	10.56	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B21_57_Bedroom 1	13.0	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B21_57_Bedroom 3	9.54	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B20_56_ Living Room	14.68	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B20_56_ Kitchen/Dining	17.27	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B20_55_ Living Room	14.68	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B20_55_ Kitchen/Dining	17.27	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B20_56_ Bedroom 1	14.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B20_56_ Bedroom 2	15.55	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B20_55_ Bedroom 1	14.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B20_55_ Bedroom 2	15.55	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B22_58_ Kitchen/Dining	16.47	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B22_58_Living Room	15.74	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B22_58_ Bedroom 3	8.51	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B22_58_ Bedroom 2	12.65	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B14_35_Living Room	12.14	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B14_35_Kitchen/Dining	16.74	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B14_35_Bedroom 1	14.13	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B14_35_Bedroom 2	11.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B12_33_ Bedroom 3	11.89	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B12_33_Kitchen/dining	21.86	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B1_1_ Kitchen/Dining	19.58	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B1_2_ Kitchen/Dining	20.53	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_6_ Kitchen/Dining	19.58	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_7_ Kitchen/Dining	20.53	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B16_41_ Living/Dining/Kitchen	24.46	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B16_39_ Living/Dining/Kitchen	24.46	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B16_42_Living/dining/Kitchen	24.73	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B16_40_Living/dining/Kitchen	24.73	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_ 59_Living/Dining/Kitchen	25.48	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_59_Bedroom	12.33	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 63_Living/Dining/Kitchen	25.48	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_63_Bedroom	12.33	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B16_41_Bedroom 1	13.76	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B16_39_Bedroom 1	13.76	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_3_Bedroom 1	15.0	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_3_ Bedroom 2	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_3_Bedroom 3	9.85	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B1_3_ Living Room	17.41	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B1_3_ Kitchen/Dining	20.53	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B1_4_Bedroom 1	15.0	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_4_ Bedroom 2	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_4_Bedroom 3	9.85	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B1_4_ Living Room	17.41	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B1_4_ Kitchen/Dining	20.53	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B1_5_Bedroom 1	15.0	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_5_ Bedroom 2	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B1_5_Bedroom 3	9.85	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B1_5_ Living Room	17.41	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B1_5_ Kitchen/Dining	20.53	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_9_ Living Room	16.6	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_8_ Living Room	17.41	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_9_ Bedroom 4	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_8_Bedroom 4	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_8_ Bedroom 3	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_9_Bedroom 3	13.69	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B2_9_ Bedroom 2	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_8_Bedroom 2	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_8_Bedroom 1	14.03	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_9_Bedroom 1	13.4	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_9_ Kitchen/Dining	19.58	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_8_ Kitchen/Dining	20.53	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_10_ Living Room	16.6	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_11_ Living Room	17.41	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_10_ Bedroom 4	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_11_Bedroom 4	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_11_ Bedroom 3	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_10_Bedroom 3	13.69	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_10_ Bedroom 2	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_11_Bedroom 2	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_11_Bedroom 1	14.03	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_10_Bedroom 1	13.4	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_10_ Kitchen/Dining	19.58	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_11_ Kitchen/Dining	20.53	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_13_ Living Room	16.6	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_12_ Living Room	17.41	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_13_ Bedroom 4	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_12_Bedroom 4	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B2_12_ Bedroom 3	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_13_Bedroom 3	13.69	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_13_ Bedroom 2	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_12_Bedroom 2	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_12_Bedroom 1	14.03	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_13_Bedroom 1	13.4	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_13_ Kitchen/Dining	19.58	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_12_ Kitchen/Dining	20.53	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_14_ Living Room	16.6	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_15_ Living Room	17.41	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_14_ Bedroom 4	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_15_Bedroom 4	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_15_ Bedroom 3	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_14_Bedroom 3	13.69	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_14_ Bedroom 2	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_15_Bedroom 2	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_15_Bedroom 1	14.03	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_14_Bedroom 1	13.4	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_14_ Kitchen/Dining	19.58	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_15_ Kitchen/Dining	20.53	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_17_ Living Room	16.6	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_16_ Living Room	17.41	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B2_17_ Bedroom 4	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_16_Bedroom 4	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_16_ Bedroom 3	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_17_Bedroom 3	13.69	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_17_ Bedroom 2	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_16_Bedroom 2	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_16_Bedroom 1	14.03	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_17_Bedroom 1	13.4	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_17_ Kitchen/Dining	19.58	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_16_ Kitchen/Dining	20.53	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_18_ Living Room	16.6	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_19_ Living Room	17.41	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_18_ Bedroom 4	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_19_Bedroom 4	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_19_ Bedroom 3	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_18_Bedroom 3	13.69	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_18_ Bedroom 2	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_19_Bedroom 2	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_19_Bedroom 1	14.03	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_18_Bedroom 1	13.4	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_18_ Kitchen/Dining	19.58	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_19_ Kitchen/Dining	20.53	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B2_21_ Living Room	16.6	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_20_ Living Room	17.41	TM59 - 4 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B2_21_ Bedroom 4	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_20_Bedroom 4	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_20_ Bedroom 3	14.37	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_21_Bedroom 3	13.69	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_21_ Bedroom 2	9.39	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_20_Bedroom 2	9.85	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_20_Bedroom 1	14.03	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_21_Bedroom 1	13.4	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B2_21_ Kitchen/Dining	19.58	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B2_20_ Kitchen/Dining	20.53	TM59 - 4 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B6_28_Living	16.77	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B6_27_Living	16.81	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B6_28_Kitchen/Dining	15.61	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B6_27_Kitchen/Dining	15.49	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B6_28_ Bedroom 1	12.72	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_28_Bedroom 2	10.67	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_28_Bedroom 3	9.19	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B6_27_Bedroom 1	12.94	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_27_Bedroom 3	9.15	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B6_27_Bedroom 2	10.76	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B6_30_Living	16.77	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B6_29_Living	16.81	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B6_30_Kitchen/Dining	15.61	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B6_29_Kitchen/Dining	15.49	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B6_30_ Bedroom 1	12.72	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_30_Bedroom 2	10.67	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_30_Bedroom 3	9.19	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B6_29_Bedroom 1	12.94	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B6_29_Bedroom 3	9.15	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B6_29_Bedroom 2	10.76	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B14_36_Living Room	12.14	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B14_36_Kitchen/Dining	16.74	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B14_36_Bedroom 1	14.13	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B14_36_Bedroom 2	11.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B8_26_Living Room	12.14	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B8_26_Kitchen/Dining	16.74	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B8_26_Bedroom 1	14.13	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B8_26_Bedroom 2	11.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B11_32_Living	16.77	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B11_31_Living	16.81	TM59 - 3 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B11_32_Kitchen/Dining	15.61	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B11_31_Kitchen/Dining	15.49	TM59 - 3 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B11_32_ Bedroom 1	12.72	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B11_32_Bedroom 2	10.67	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B11_32_Bedroom 3	9.19	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B11_31_Bedroom 1	12.94	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B11_31_Bedroom 3	9.15	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B11_31_Bedroom 2	10.76	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B15_37_Living Room	12.14	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B15_37_Kitchen/Dining	16.74	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B15_37_Bedroom 1	14.13	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B15_37_Bedroom 2	11.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B15_38_Living Room	12.14	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B15_38_Kitchen/Dining	16.74	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B15_38_Bedroom 1	14.13	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B15_38_Bedroom 2	11.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B17_44_Bedroom 1	11.97	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B17_44_Bedroom 2	8.49	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B17_46_Bedroom 1	11.97	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B17_46_Bedroom 2	8.49	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B17_43_Living/Dining/Kitchen	23.38	TM59 - 2 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B17_45_Living/Dining/Kitchen	23.33	TM59 - 2 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B17_46_Living/Dining/Kitchen	24.51	TM59 - 2 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B17_44_Living/Dining/Kitchen	24.51	TM59 - 2 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B17_45_Bedroom 2	8.39	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B17_43_Bedroom 2	8.31	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B17_45_Bedroom 1	12.43	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B17_43_Bedroom 1	12.55	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B18_47_Bedroom 1	16.8	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B18_47_Living/Dining/Kitchen	33.14	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B18_48_Living/Dining/Kitchen	24.23	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B18_48_Bedroom 2	8.64	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B18_48_Bedroom 1	13.02	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B18_49_Bedroom 1	16.8	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B18_49_Living/Dining/Kitchen	33.14	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B18_50_Living/Dining/Kitchen	24.24	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B18_50_Bedroom 2	8.64	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B18_50_Bedroom 1	13.02	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B19_51_Bedroom 1	16.8	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B19_51_Living/Dining/Kitchen	33.14	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B19_52_Living/Dining/Kitchen	24.23	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B19_52_Bedroom 2	8.64	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B19_52_Bedroom 1	13.02	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B19_53_Bedroom 1	16.8	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B19_53_Living/Dining/Kitchen	33.14	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B19_54_Living/Dining/Kitchen	24.23	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B19_54_Bedroom 2	8.64	TM59 - Single Bedroom	Single Bedroom Occupancy	Single Bedroom Equipment	18-23h
B19_54_Bedroom 1	13.02	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B7_25_Living Room	12.14	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B7_25_Kitchen/Dining	16.74	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B7_25_Bedroom 1	14.13	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B7_25_Bedroom 2	11.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B7_24_Living Room	12.14	TM59 - 2 Bedroom - Living	Living Occupancy	Living Equipment	18-23h
B7_24_Kitchen/Dining	16.74	TM59 - 2 Bedroom - Kitchen	Kitchen Occupancy	Kitchen Equipment	18-23h
B7_24_Bedroom 1	14.13	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B7_24_Bedroom 2	11.58	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B22_58_Bedroom 1	13.77	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 60_Living/Kitchen	28.4	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_60_Bedroom	12.62	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 64_Living	28.4	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_64_Bedroom	13.52	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 61_Living/Dining/Kitchen	25.48	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h

Alderford Parade - All Plots

Room name	Floor area m²	Thermal template	Occupancy profile	Equipment profile	Lighting profile
B23_61_Bedroom	12.33	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 62_Living/Kitchen	28.4	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_62_Bedroom	12.62	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 65_Living/Dining/Kitchen	25.48	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_65_Bedroom	12.33	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 66_Living	28.4	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_66_Bedroom	13.52	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 67_Living/Dining/Kitchen	25.48	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_67_Bedroom	12.33	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B23_ 68_Living/Kitchen	28.4	TM59 - 1 Bedroom - Living / Kitchen	Living / Kitchen Occupancy	Living / Kitchen Equipment	18-23h
B23_68_Bedroom	12.62	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B24_69_Bedroom 1	14.6	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h
B24_70_Bedroom 1	14.5	TM59 - Double Bedroom	Double Bedroom Occupancy	Double Bedroom Equipment	18-23h

Modelled openings

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B2_6_ Living Room	9.28	0.4	0.45, 1.3	0.0, 90.0	7.05	off continuously, ADO.Section_26a
B2_7_ Living Room	38.51	0.4	0.45, 1.3	0.0, 90.0	6.72	off continuously, ADO.Section_26a
B2_6_ Bedroom 4	10.81	0.4	0.53, 0.89	90.0, 90.0	13.61	ADO.Section_26ab
B2_7_Bedroom 4	26.83	0.4	0.53, 0.89	90.0, 90.0	12.97	ADO.Section_26ab
B2_7_ Bedroom 3	24.59	0.4	1.0, 0.53, 0.43, 0.22	90.0, 90.0, 0.0, 0.0	9.58	off continuously, ADO.Section_26ab
B2_6_Bedroom 3	10.48	0.4	1.0, 0.52, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.99	off continuously, ADO.Section_26ab
B2_6_ Bedroom 2	13.21	0.4	0.89, 0.53, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	13.61	off continuously, ADO.Section_26ab
B2_7_Bedroom 2	24.54	0.4	0.89, 0.53, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	12.97	off continuously, ADO.Section_26ab
B2_7_Bedroom 1	37.17	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	16.49	off continuously, ADO.Section_26ab
B2_6_Bedroom 1	14.94	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	17.26	off continuously, ADO.Section_26ab
B6_23_Living	17.57	0.4, 0.4	0.35, 0.87, 1.06, 0.62, 0.25, 0.42	0.0, 90.0, 90.0, 90.0, 0.0, 0.0	13.69	off continuously, ADO.Section_26a
B6_22_Living	17.54	0.4, 0.4	0.35, 0.88, 1.06, 0.63, 0.25, 0.43	0.0, 90.0, 90.0, 90.0, 0.0, 0.0	13.76	off continuously, ADO.Section_26a

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B6_23_Kitchen/Dining	17.61	0.4, 0.4	0.72, 0.38, 0.56, 2.1	90.0, 0.0, 90.0, 90.0	19.49	off continuously, ADO.Section_26a
B6_22_Kitchen/Dining	17.67	0.4, 0.4	2.1, 0.56, 0.38, 0.72	90.0, 90.0, 0.0, 90.0	19.64	off continuously, ADO.Section_26a
B6_23_ Bedroom 1	10.3	0.4	0.89, 0.52, 0.23, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	23.35	off continuously, on continuously, ADO.Section_26ab
B6_23_Bedroom 2	11.41	0.4	0.89, 0.53, 0.23, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	27.92	off continuously, on continuously, ADO.Section_26ab
B6_23_Bedroom 3	13.03	0.4	0.31, 0.74, 1.89	0.0, 90.0, 90.0	25.76	off continuously, on continuously, ADO.Section_26ab
B6_22_Bedroom 1	10.23	0.4	0.89, 0.53, 0.22, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	23.02	off continuously, on continuously, ADO.Section_26ab
B6_22_Bedroom 3	13.17	0.4	0.31, 0.73, 1.89	0.0, 90.0, 90.0	25.77	off continuously, on continuously, ADO.Section_26ab
B6_22_Bedroom 2	11.38	0.4	0.89, 0.52, 0.22, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	27.6	off continuously, on continuously, ADO.Section_26ab
B13_34_ Bedroom 3	18.39	0.4, 0.4	0.73, 0.31, 1.05, 0.45	90.0, 0.0, 90.0, 0.0	19.39	off continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B13_34_ Bedroom 2	17.02	0.4	1.05, 0.45, 0.73, 0.31	90.0, 0.0, 90.0, 0.0	13.11	off continuously, ADO.Section_ 26ab
B13_34_ Bedroom 1	14.51	0.4, 0.4	1.0, 0.52, 0.43, 0.22, 1.05, 0.45	90.0, 90.0, 0.0, 0.0, 90.0, 0.0	16.25	off continuously, ADO.Section_ 26ab
B13_34_ Living Room	20.29	0.4, 0.4, 0.4	0.38, 0.87, 2.1, 0.56, 0.38, 1.25, 0.5	0.0, 90.0, 90.0, 90.0, 0.0, 90.0, 0.0	28.55	off continuously, ADO.Section_ 26a
B13_34_ Kitchen/Dining	21.68	0.4, 0.4, 0.4	2.1, 0.56, 0.38, 0.38, 0.87, 1.25, 0.5	90.0, 90.0, 0.0, 0.0, 90.0, 90.0, 0.0	26.09	off continuously, ADO.Section_ 26a
B24_69_Living	12.94	0.4, 0.4, 0.4	0.38, 0.88, 0.38, 0.87, 0.38, 0.87	0.0, 90.0, 0.0, 90.0, 0.0, 90.0	16.87	off continuously, ADO.Section_ 26a
B24_69_Kitchen/Dining	21.61	0.4, 0.4	2.1, 0.56, 0.38, 0.52, 0.89	90.0, 90.0, 0.0, 90.0, 90.0	20.97	off continuously, ADO.Section_ 26a
B24_70_Living	13.02	0.4, 0.4, 0.4	0.38, 0.87, 0.38, 0.87, 0.38, 0.87	0.0, 90.0, 0.0, 90.0, 0.0, 90.0	16.97	off continuously, ADO.Section_ 26a
B24_70_Kitchen/Dining	21.74	0.4, 0.4	2.1, 0.47, 0.52, 0.89, 0.53	90.0, 0.0, 90.0, 90.0, 90.0	20.74	off continuously, ADO.Section_ 26a
B24_69_Bedroom 2	22.26	0.4, 0.4	1.05, 0.53, 0.89, 0.52, 0.22, 0.38	90.0, 90.0, 90.0, 90.0, 0.0, 0.0	18.7	off continuously, ADO.Section_ 26ab
B24_70_Bedroom 2	22.37	0.4, 0.4	1.05, 0.52, 0.89, 0.52, 0.23, 0.38	90.0, 90.0, 90.0, 90.0, 0.0, 0.0	18.73	off continuously, ADO.Section_ 26ab
B12_33_Living Room	20.26	0.4, 0.4, 0.4	2.1, 0.56, 0.38, 1.06, 0.62, 0.27, 0.47, 0.27, 0.96, 0.73	90.0, 90.0, 0.0, 90.0, 90.0, 0.0, 0.0, 0.0, 90.0, 90.0	22.41	off continuously, ADO.Section_ 26a

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B12_33_ Bedroom 1	28.5	0.4, 0.4	0.94, 0.41, 0.53, 0.22, 0.95, 0.41, 0.52, 0.22, 0.73, 0.31, 1.89, 1.89	90.0, 0.0, 90.0, 0.0, 90.0, 0.0, 90.0, 0.0, 90.0, 0.0, 90.0, 90.0	47.86	off continuously, on continuously, ADO.Section_26ab
B12_33_ Bedroom 4	6.92	0.4	0.73, 0.32, 1.89	90.0, 0.0, 90.0	27.71	off continuously, on continuously, ADO.Section_26ab
B12_33_ Bedroom 2	22.5	0.4, 0.4	0.73, 0.31, 0.73, 0.31, 1.89	90.0, 0.0, 90.0, 0.0, 90.0	24.04	off continuously, on continuously, ADO.Section_26ab
B16_42_Bedroom 1	14.9	0.4, 0.4	0.74, 0.32, 0.73, 0.77, 0.28	90.0, 0.0, 90.0, 90.0, 0.0	13.4	off continuously, ADO.Section_26ab
B16_40_Bedroom 1	17.35	0.4, 0.4	0.74, 0.32, 1.05, 0.53, 0.45, 0.23	90.0, 0.0, 90.0, 90.0, 0.0, 0.0	13.88	off continuously, ADO.Section_26ab
B1_2_Bedroom 1	38.46	0.4	2.21, 0.47, 0.47	90.0, 90.0, 0.0	16.08	off continuously, ADO.Section_26a
B1_1_Bedroom 1	11.84	0.4, 0.4	0.38, 0.9, 0.39, 0.89, 0.2, 0.47	0.0, 90.0, 0.0, 90.0, 0.0, 90.0	12.52	off continuously, ADO.Section_26a
B1_2_ Bedroom 2	25.43	0.4, 0.871	1.05, 0.53, 0.22, 0.45, 0.73	90.0, 90.0, 0.0, 0.0, 0.0	9.9	off continuously, ADO.Section_26ab
B1_2_Bedroom 3	27.04	0.4	0.89, 0.52	90.0, 90.0	12.88	ADO.Section_26a
B1_1_ Bedroom 3	16.36	0.4, 0.4	0.36, 0.84, 0.95	0.0, 90.0, 90.0	17.16	off continuously, ADO.Section_26a
B1_1_Bedroom 2	13.84	0.4, 0.4, 0.871	0.36, 0.84, 0.36, 0.84, 1.05, 0.45, 0.73	0.0, 90.0, 0.0, 90.0, 90.0, 0.0, 0.0	15.68	off continuously, ADO.Section_26a, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B1_2_ Living Room	38.51	0.4	1.3, 0.45	90.0, 0.0	6.72	off continuously, ADO.Section_26a
B1_1_ Living Room	20.0	0.4, 0.4	0.89, 0.38, 0.23, 0.52, 1.31, 0.45	90.0, 0.0, 0.0, 90.0, 90.0, 0.0	14.75	off continuously, ADO.Section_26a
B21_57_ Living Room	17.94	0.4, 0.4	0.95, 0.27, 1.06, 0.47, 0.63, 0.27	90.0, 0.0, 90.0, 0.0, 90.0, 0.0	13.92	off continuously, ADO.Section_26a
B21_57_Kitchen/Dining	17.96	0.4, 0.4	0.89, 0.52, 2.1, 0.56, 0.38, 2.1, 0.56, 0.38	90.0, 90.0, 0.0, 90.0, 0.0, 90.0, 90.0, 0.0	23.87	off continuously, ADO.Section_26a
B21_57_Bedroom 2	11.88	0.4	0.89, 0.53, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	12.1	off continuously, ADO.Section_26ab
B21_57_Bedroom 1	14.47	0.4, 0.4	0.89, 0.53, 0.22, 0.38, 0.73	90.0, 90.0, 0.0, 0.0, 90.0	14.88	off continuously, ADO.Section_26ab
B21_57_Bedroom 3	8.07	0.4	0.95, 0.41	90.0, 0.0	8.96	off continuously, ADO.Section_26ab
B20_56_ Living Room	12.66	0.4	0.47, 0.28, 0.62, 1.06	0.0, 0.0, 90.0, 90.0	10.3	off continuously, ADO.Section_26a
B20_56_ Kitchen/Dining	14.87	0.4, 0.4	0.73, 0.73, 2.1	90.0, 90.0, 90.0	18.55	ADO.Section_26a
B20_55_ Living Room	19.04	0.4, 0.4	0.87, 0.35, 0.47, 0.27, 0.63, 1.06	90.0, 0.0, 0.0, 0.0, 90.0, 90.0	15.69	off continuously, ADO.Section_26a
B20_55_ Kitchen/Dining	14.87	0.4, 0.4	0.73, 0.73, 2.1	90.0, 90.0, 0.0	7.61	off continuously, ADO.Section_26a
B20_56_ Bedroom 1	9.58	0.4	0.31, 0.73, 0.74	0.0, 90.0, 90.0	9.07	off continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B20_56_ Bedroom 2	27.38	0.4, 0.4	1.1, 0.53, 0.47, 0.22, 0.3, 0.71, 0.52, 0.22, 0.89, 0.38	90.0, 90.0, 0.0, 0.0, 0.0, 90.0, 90.0, 0.0, 90.0, 0.0	21.7	off continuously, ADO.Section_ 26ab
B20_55_ Bedroom 1	9.58	0.4	0.73, 0.31, 0.73	90.0, 0.0, 90.0	9.01	off continuously, ADO.Section_ 26ab
B20_55_ Bedroom 2	10.34	0.4	0.52, 0.89, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	8.16	off continuously, ADO.Section_ 26ab
B22_58_ Kitchen/Dining	15.68	0.4, 0.4, 0.4	0.38, 0.87, 1.89, 0.38, 0.87	0.0, 90.0, 90.0, 0.0, 90.0	19.84	off continuously, ADO.Section_ 26a
B22_58_Living Room	21.93	0.4, 0.4, 0.4	1.89, 0.56, 0.38, 0.47, 1.06, 0.75, 0.33, 0.38, 0.87	90.0, 90.0, 0.0, 0.0, 90.0, 90.0, 0.0, 0.0, 90.0	29.33	off continuously, ADO.Section_ 26a
B22_58_ Bedroom 3	14.72	0.4, 0.4	0.74, 0.27, 0.74, 0.27	90.0, 0.0, 90.0, 0.0	15.65	off continuously, ADO.Section_ 26ab
B22_58_ Bedroom 2	20.28	0.4	0.74, 0.27, 0.52, 0.22, 0.89, 0.38	90.0, 0.0, 90.0, 0.0, 90.0, 0.0	15.3	off continuously, ADO.Section_ 26ab
B14_35_Living Room	18.22	0.4, 0.4	0.73, 0.64, 0.25, 1.13, 0.43	90.0, 90.0, 0.0, 90.0, 0.0	18.53	off continuously, ADO.Section_ 26a
B14_35_Kitchen/Dining	17.22	0.4, 0.4, 0.871	0.72, 2.15, 0.48, 0.73, 0.73	90.0, 90.0, 0.0, 90.0, 0.0	19.35	off continuously, ADO.Section_ 26a
B14_35_Bedroom 1	11.18	0.4	0.72, 0.72, 0.31, 0.31	90.0, 90.0, 0.0, 0.0	9.17	off continuously, ADO.Section_ 26ab
B14_35_Bedroom 2	15.88	0.4	0.53, 0.89, 0.38, 0.23, 0.73	90.0, 90.0, 0.0, 0.0, 90.0	16.71	off continuously, ADO.Section_ 26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B12_33_ Bedroom 3	18.15	0.4, 0.4	0.74, 0.31, 0.87, 0.37, 0.52, 0.22, 1.89	90.0, 0.0, 90.0, 0.0, 90.0, 0.0, 90.0	30.43	off continuously, on continuously, ADO.Section_ 26ab
B12_33_Kitchen/dining	15.72	0.4, 0.4, 0.4	2.1, 0.56, 0.38, 0.73, 1.05, 0.36	90.0, 90.0, 0.0, 90.0, 90.0, 90.0	19.76	off continuously, ADO.Section_ 26a
B1_1_ Kitchen/Dining	18.67	0.4, 0.4002, 0.4	2.1, 0.95, 1.04, 0.89, 0.38, 0.23, 0.53	90.0, 90.0, 90.0, 90.0, 0.0, 0.0, 90.0	25.33	off continuously, ADO.Section_ 26a
B1_2_ Kitchen/Dining	34.42	0.4, 0.4002	2.1, 0.94, 1.04	90.0, 90.0, 90.0	17.89	ADO.Section_ 26a
B2_6_ Kitchen/Dining	10.95	0.4, 0.4002	2.1, 0.87, 1.04	90.0, 90.0, 90.0	18.43	ADO.Section_ 26a
B2_7_ Kitchen/Dining	33.39	0.4, 0.4002	2.1, 0.89, 1.04	90.0, 90.0, 90.0	17.67	ADO.Section_ 26a
B16_41_ Living/Dining/Kitchen	18.24	0.4, 0.4, 0.4	0.41, 0.94, 0.5, 1.13, 0.88, 0.39, 0.73	0.0, 90.0, 0.0, 90.0, 90.0, 0.0, 90.0	13.54	off continuously, ADO.Section_ 26a
B16_39_ Living/Dining/Kitchen	15.32	0.4, 0.4, 0.4	0.73, 0.55, 1.25, 0.62, 0.28, 0.74	90.0, 0.0, 90.0, 90.0, 0.0, 90.0	12.29	off continuously, ADO.Section_ 26a
B16_42_Living/dining/Kitchen	22.81	0.4, 0.4, 0.4	2.1, 0.84, 0.84, 0.74, 0.73, 0.32, 0.7	90.0, 90.0, 0.0, 90.0, 90.0, 0.0, 90.0	18.6	off continuously, ADO.Section_ 26ab
B16_40_Living/dining/Kitchen	24.09	0.4, 0.4, 0.4	0.74, 0.31, 0.73, 2.1, 0.47, 0.47, 0.73, 0.32, 0.73	90.0, 0.0, 90.0, 90.0, 90.0, 0.0, 90.0, 0.0, 90.0	20.02	off continuously, ADO.Section_ 26ab
B23_ 59_Living/Dining/Kitchen	21.4	0.4, 0.4, 0.4	0.88, 0.39, 1.12, 0.49, 2.1, 0.56, 0.38, 0.88, 0.39, 0.84, 0.87, 0.39	90.0, 0.0, 90.0, 0.0, 90.0, 90.0, 0.0, 90.0, 0.0, 90.0, 90.0, 0.0	25.61	off continuously, ADO.Section_ 26a
B23_59_Bedroom	23.08	0.4, 0.871	0.27, 0.52, 1.19, 0.63, 0.84	0.0, 0.0, 90.0, 90.0, 0.0	13.28	off continuously, ADO.Section_ 26a

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B23_ 63_Living/Dining/Kitchen	29.08	0.4, 0.4	1.19, 0.52, 0.63, 0.28, 2.1, 0.56, 0.38	90.0, 0.0, 90.0, 0.0, 90.0, 90.0, 0.0	15.82	off continuously, ADO.Section_ 26a
B23_63_Bedroom	23.07	0.4	1.19, 0.52, 0.63, 0.28	90.0, 0.0, 90.0, 0.0	13.28	off continuously, ADO.Section_ 26a
B16_41_Bedroom 1	15.08	0.4, 0.4	0.55, 1.25, 0.62, 0.27, 0.73	0.0, 90.0, 90.0, 0.0, 90.0	17.01	off continuously, ADO.Section_ 26a
B16_39_Bedroom 1	11.85	0.4	0.55, 1.25, 0.63, 0.27	0.0, 90.0, 90.0, 0.0	12.3	off continuously, ADO.Section_ 26a
B1_3_Bedroom 1	38.46	0.4	2.21, 0.47, 0.47	90.0, 90.0, 0.0	16.08	off continuously, ADO.Section_ 26a
B1_3_ Bedroom 2	25.43	0.4	1.05, 0.53, 0.23, 0.45	90.0, 90.0, 0.0, 0.0	9.9	off continuously, ADO.Section_ 26ab
B1_3_Bedroom 3	27.04	0.4	0.89, 0.53	90.0, 90.0	12.97	ADO.Section_ 26a
B1_3_ Living Room	38.51	0.4	1.3, 0.45	90.0, 0.0	6.72	off continuously, ADO.Section_ 26a
B1_3_ Kitchen/Dining	34.42	0.4, 0.4002	2.1, 0.94, 1.04	90.0, 90.0, 90.0	17.89	ADO.Section_ 26a
B1_4_Bedroom 1	38.46	0.4	2.2, 0.47, 0.47	90.0, 90.0, 0.0	16.02	off continuously, ADO.Section_ 26a
B1_4_ Bedroom 2	25.43	0.4	1.05, 0.53, 0.23, 0.45	90.0, 90.0, 0.0, 0.0	9.9	off continuously, ADO.Section_ 26ab
B1_4_Bedroom 3	27.04	0.4	0.89, 0.52	90.0, 90.0	12.88	ADO.Section_ 26a
B1_4_ Living Room	38.51	0.4	1.3, 0.45	90.0, 0.0	6.72	off continuously, ADO.Section_ 26a
B1_4_ Kitchen/Dining	34.42	0.4, 0.4002	2.1, 0.95, 1.04	90.0, 90.0, 90.0	17.93	ADO.Section_ 26a

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B1_5_Bedroom 1	16.7	0.4	2.2, 0.47, 0.47	90.0, 90.0, 0.0	16.02	off continuously, ADO.Section_26a
B1_5_ Bedroom 2	11.05	0.4	1.05, 0.52, 0.22, 0.45	90.0, 90.0, 0.0, 0.0	9.83	off continuously, ADO.Section_26ab
B1_5_Bedroom 3	10.61	0.4	0.89, 0.52	90.0, 90.0	12.88	ADO.Section_26a
B1_5_ Living Room	9.28	0.4	1.31, 0.45	90.0, 0.0	6.77	off continuously, ADO.Section_26a
B1_5_ Kitchen/Dining	11.05	0.4, 0.4002	2.1, 0.95, 1.04	90.0, 90.0, 90.0	17.93	ADO.Section_26a
B2_9_ Living Room	9.28	0.4	0.45, 1.3	0.0, 90.0	7.05	off continuously, ADO.Section_26a
B2_8_ Living Room	38.51	0.4	0.45, 1.3	0.0, 90.0	6.72	off continuously, ADO.Section_26a
B2_9_ Bedroom 4	10.81	0.4	0.53, 0.89	90.0, 90.0	13.61	ADO.Section_26ab
B2_8_Bedroom 4	27.04	0.4	0.52, 0.89	90.0, 90.0	12.88	ADO.Section_26ab
B2_8_ Bedroom 3	24.4	0.4	1.0, 0.52, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.52	off continuously, ADO.Section_26ab
B2_9_Bedroom 3	10.48	0.4	1.0, 0.52, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.99	off continuously, ADO.Section_26ab
B2_9_ Bedroom 2	13.21	0.4	0.89, 0.53, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	13.61	off continuously, ADO.Section_26ab
B2_8_Bedroom 2	24.72	0.4	0.89, 0.52, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	12.88	off continuously, ADO.Section_26ab
B2_8_Bedroom 1	36.89	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	16.49	off continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B2_9_Bedroom 1	14.94	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	17.26	off continuously, ADO.Section_26ab
B2_9_ Kitchen/Dining	10.95	0.4, 0.4002	2.1, 0.87, 1.04	90.0, 90.0, 90.0	18.43	ADO.Section_26a
B2_8_ Kitchen/Dining	33.74	0.4, 0.4002	2.1, 0.89, 1.04	90.0, 90.0, 90.0	17.67	ADO.Section_26a
B2_10_ Living Room	9.28	0.4	0.45, 1.31	0.0, 90.0	7.1	off continuously, ADO.Section_26a
B2_11_ Living Room	38.51	0.4	0.45, 1.31	0.0, 90.0	6.77	off continuously, ADO.Section_26a
B2_10_ Bedroom 4	10.81	0.4	0.53, 0.89	90.0, 90.0	13.61	ADO.Section_26ab
B2_11_Bedroom 4	26.83	0.4	0.52, 0.89	90.0, 90.0	12.88	ADO.Section_26ab
B2_11_ Bedroom 3	24.59	0.4	1.0, 0.53, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.58	off continuously, ADO.Section_26ab
B2_10_Bedroom 3	10.48	0.4	1.0, 0.53, 0.43, 0.22	90.0, 90.0, 0.0, 0.0	10.06	off continuously, ADO.Section_26ab
B2_10_ Bedroom 2	13.21	0.4	0.89, 0.53, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	13.61	off continuously, ADO.Section_26ab
B2_11_Bedroom 2	24.54	0.4	0.89, 0.53, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	12.97	off continuously, ADO.Section_26ab
B2_11_Bedroom 1	37.17	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	16.49	off continuously, ADO.Section_26ab
B2_10_Bedroom 1	14.94	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	17.26	off continuously, ADO.Section_26ab
B2_10_ Kitchen/Dining	10.95	0.4, 0.4002	2.1, 0.87, 1.04	90.0, 90.0, 90.0	18.43	ADO.Section_26a
B2_11_ Kitchen/Dining	33.39	0.4, 0.4002	2.1, 0.89, 1.04	90.0, 90.0, 90.0	17.67	ADO.Section_26a

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B2_13_ Living Room	9.28	0.4	0.45, 1.3	0.0, 90.0	7.05	off continuously, ADO.Section_26a
B2_12_ Living Room	38.51	0.4	0.45, 1.3	0.0, 90.0	6.72	off continuously, ADO.Section_26a
B2_13_ Bedroom 4	10.81	0.4	0.53, 0.89	90.0, 90.0	13.61	ADO.Section_26ab
B2_12_Bedroom 4	27.04	0.4	0.53, 0.89	90.0, 90.0	12.97	ADO.Section_26ab
B2_12_ Bedroom 3	24.4	0.4	1.0, 0.52, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.52	off continuously, ADO.Section_26ab
B2_13_Bedroom 3	10.48	0.4	1.0, 0.53, 0.43, 0.22	90.0, 90.0, 0.0, 0.0	10.06	off continuously, ADO.Section_26ab
B2_13_ Bedroom 2	13.21	0.4	0.89, 0.53, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	13.61	off continuously, ADO.Section_26ab
B2_12_Bedroom 2	24.72	0.4	0.89, 0.53, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	12.97	off continuously, ADO.Section_26ab
B2_12_Bedroom 1	36.89	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	16.49	off continuously, ADO.Section_26ab
B2_13_Bedroom 1	14.94	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	17.26	off continuously, ADO.Section_26ab
B2_13_ Kitchen/Dining	10.95	0.4, 0.4002	2.1, 0.87, 1.04	90.0, 90.0, 90.0	18.43	ADO.Section_26a
B2_12_ Kitchen/Dining	33.74	0.4, 0.4002	2.1, 0.89, 1.04	90.0, 90.0, 90.0	17.67	ADO.Section_26a
B2_14_ Living Room	9.28	0.4	0.45, 1.3	0.0, 90.0	7.05	off continuously, ADO.Section_26a
B2_15_ Living Room	38.51	0.4	0.45, 1.3	0.0, 90.0	6.72	off continuously, ADO.Section_26a

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B2_14_ Bedroom 4	10.81	0.4	0.52, 0.89	90.0, 90.0	13.51	ADO.Section_ 26ab
B2_15_Bedroom 4	26.83	0.4	0.53, 0.89	90.0, 90.0	12.97	ADO.Section_ 26ab
B2_15_ Bedroom 3	24.59	0.4	1.0, 0.53, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.58	off continuously, ADO.Section_ 26ab
B2_14_Bedroom 3	10.48	0.4	1.0, 0.53, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	10.06	off continuously, ADO.Section_ 26ab
B2_14_ Bedroom 2	13.21	0.4	0.89, 0.53, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	13.61	off continuously, ADO.Section_ 26ab
B2_15_Bedroom 2	24.54	0.4	0.89, 0.53, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	12.97	off continuously, ADO.Section_ 26ab
B2_15_Bedroom 1	37.17	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	16.49	off continuously, ADO.Section_ 26ab
B2_14_Bedroom 1	14.94	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	17.26	off continuously, ADO.Section_ 26ab
B2_14_ Kitchen/Dining	10.95	0.4, 0.4002	2.1, 0.87, 1.04	90.0, 90.0, 90.0	18.43	ADO.Section_ 26a
B2_15_ Kitchen/Dining	33.39	0.4, 0.4002	2.1, 0.89, 1.04	90.0, 90.0, 90.0	17.67	ADO.Section_ 26a
B2_17_ Living Room	9.28	0.4	0.45, 1.3	0.0, 90.0	7.05	off continuously, ADO.Section_ 26a
B2_16_ Living Room	38.51	0.4	0.45, 1.31	0.0, 90.0	6.77	off continuously, ADO.Section_ 26a
B2_17_ Bedroom 4	10.81	0.4	0.52, 0.89	90.0, 90.0	13.51	ADO.Section_ 26ab
B2_16_Bedroom 4	27.04	0.4	0.53, 0.89	90.0, 90.0	12.97	ADO.Section_ 26ab
B2_16_ Bedroom 3	24.4	0.4	1.0, 0.52, 0.43, 0.22	90.0, 90.0, 0.0, 0.0	9.52	off continuously, ADO.Section_ 26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B2_17_Bedroom 3	10.48	0.4	1.0, 0.53, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	10.06	off continuously, ADO.Section_ 26ab
B2_17_ Bedroom 2	13.21	0.4	0.89, 0.53, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	13.61	off continuously, ADO.Section_ 26ab
B2_16_Bedroom 2	24.72	0.4	0.89, 0.53, 0.22, 0.38	90.0, 90.0, 0.0, 0.0	12.97	off continuously, ADO.Section_ 26ab
B2_16_Bedroom 1	36.89	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	16.49	off continuously, ADO.Section_ 26ab
B2_17_Bedroom 1	14.94	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	17.26	off continuously, ADO.Section_ 26ab
B2_17_ Kitchen/Dining	10.95	0.4, 0.4002	2.1, 0.87, 1.04	90.0, 90.0, 90.0	18.43	ADO.Section_ 26a
B2_16_ Kitchen/Dining	33.74	0.4, 0.4002	2.1, 0.89, 1.04	90.0, 90.0, 90.0	17.67	ADO.Section_ 26a
B2_18_ Living Room	9.28	0.4	0.45, 1.3	0.0, 90.0	7.05	off continuously, ADO.Section_ 26a
B2_19_ Living Room	38.51	0.4	0.45, 1.3	0.0, 90.0	6.72	off continuously, ADO.Section_ 26a
B2_18_ Bedroom 4	10.81	0.4	0.52, 0.89	90.0, 90.0	13.51	ADO.Section_ 26ab
B2_19_Bedroom 4	26.83	0.4	0.53, 0.89	90.0, 90.0	12.97	ADO.Section_ 26ab
B2_19_ Bedroom 3	24.59	0.4	1.0, 0.53, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.58	off continuously, ADO.Section_ 26ab
B2_18_Bedroom 3	10.48	0.4	1.0, 0.52, 0.43, 0.22	90.0, 90.0, 0.0, 0.0	9.99	off continuously, ADO.Section_ 26ab
B2_18_ Bedroom 2	13.21	0.4	0.89, 0.53, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	13.61	off continuously, ADO.Section_ 26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B2_19_Bedroom 2	24.54	0.4	0.89, 0.53, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	12.97	off continuously, ADO.Section_26ab
B2_19_Bedroom 1	37.17	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	16.49	off continuously, ADO.Section_26ab
B2_18_Bedroom 1	14.94	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	17.26	off continuously, ADO.Section_26ab
B2_18_ Kitchen/Dining	10.95	0.4, 0.4002	2.1, 0.87, 1.04	90.0, 90.0, 90.0	18.43	ADO.Section_26a
B2_19_ Kitchen/Dining	33.39	0.4, 0.4002	2.1, 0.89, 1.04	90.0, 90.0, 90.0	17.67	ADO.Section_26a
B2_21_ Living Room	9.28	0.4	0.45, 1.3	0.0, 90.0	7.05	off continuously, ADO.Section_26a
B2_20_ Living Room	38.51	0.4	0.45, 1.3	0.0, 90.0	6.72	off continuously, ADO.Section_26a
B2_21_ Bedroom 4	10.81	0.4	0.52, 0.89	90.0, 90.0	13.51	ADO.Section_26ab
B2_20_Bedroom 4	27.04	0.4	0.53, 0.89	90.0, 90.0	12.97	ADO.Section_26ab
B2_20_ Bedroom 3	24.4	0.4	1.0, 0.53, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.58	off continuously, ADO.Section_26ab
B2_21_Bedroom 3	10.48	0.4	1.0, 0.52, 0.43, 0.23	90.0, 90.0, 0.0, 0.0	9.99	off continuously, ADO.Section_26ab
B2_21_ Bedroom 2	13.21	0.4	0.89, 0.53, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	13.61	off continuously, ADO.Section_26ab
B2_20_Bedroom 2	24.72	0.4	0.89, 0.53, 0.23, 0.38	90.0, 90.0, 0.0, 0.0	12.97	off continuously, ADO.Section_26ab
B2_20_Bedroom 1	36.89	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	16.49	off continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B2_21_Bedroom 1	14.94	0.4	2.1, 0.47, 0.47	90.0, 90.0, 0.0	17.26	off continuously, ADO.Section_26ab
B2_21_ Kitchen/Dining	10.95	0.4, 0.4002	2.1, 0.87, 1.04	90.0, 90.0, 90.0	18.43	ADO.Section_26a
B2_20_ Kitchen/Dining	33.74	0.4, 0.4002	2.1, 0.89, 1.04	90.0, 90.0, 90.0	17.67	ADO.Section_26a
B6_28_Living	17.57	0.4, 0.4	0.35, 0.87, 1.06, 0.63, 0.25, 0.42	0.0, 90.0, 90.0, 90.0, 0.0, 0.0	13.74	off continuously, ADO.Section_26a
B6_27_Living	17.54	0.4, 0.4	0.35, 0.87, 1.06, 0.63, 0.25, 0.42	0.0, 90.0, 90.0, 90.0, 0.0, 0.0	13.71	off continuously, ADO.Section_26a
B6_28_Kitchen/Dining	17.61	0.4, 0.4	0.72, 0.38, 0.56, 2.1	90.0, 0.0, 90.0, 90.0	19.49	off continuously, ADO.Section_26a
B6_27_Kitchen/Dining	17.67	0.4, 0.4	2.1, 0.56, 0.38, 0.72	90.0, 90.0, 0.0, 90.0	19.64	off continuously, ADO.Section_26a
B6_28_ Bedroom 1	10.3	0.4	0.89, 0.52, 0.22, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	23.35	off continuously, on continuously, ADO.Section_26ab
B6_28_Bedroom 2	11.41	0.4	0.89, 0.53, 0.22, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	27.92	off continuously, on continuously, ADO.Section_26ab
B6_28_Bedroom 3	13.03	0.4	0.31, 0.73, 1.89	0.0, 90.0, 90.0	25.66	off continuously, on continuously, ADO.Section_26ab
B6_27_Bedroom 1	10.23	0.4	0.89, 0.52, 0.23, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	22.95	off continuously, on continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B6_27_Bedroom 3	13.17	0.4	0.32, 0.74, 1.89	0.0, 90.0, 90.0	25.87	off continuously, on continuously, ADO.Section_26ab
B6_27_Bedroom 2	11.38	0.4	0.89, 0.53, 0.22, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	27.69	off continuously, on continuously, ADO.Section_26ab
B6_30_Living	17.57	0.4, 0.4	0.35, 0.87, 1.06, 0.63, 0.25, 0.42	0.0, 90.0, 90.0, 90.0, 0.0, 0.0	13.74	off continuously, ADO.Section_26a
B6_29_Living	17.54	0.4, 0.4	0.35, 0.87, 1.06, 0.62, 0.25, 0.43	0.0, 90.0, 90.0, 90.0, 0.0, 0.0	13.65	off continuously, ADO.Section_26a
B6_30_Kitchen/Dining	17.61	0.4, 0.4	0.72, 0.38, 0.56, 2.1	90.0, 0.0, 90.0, 90.0	19.49	off continuously, ADO.Section_26a
B6_29_Kitchen/Dining	17.67	0.4, 0.4	2.1, 0.56, 0.38, 0.72	90.0, 90.0, 0.0, 90.0	19.64	off continuously, ADO.Section_26a
B6_30_ Bedroom 1	10.3	0.4	0.89, 0.52, 0.23, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	23.35	off continuously, on continuously, ADO.Section_26ab
B6_30_Bedroom 2	11.41	0.4	0.89, 0.53, 0.23, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	27.92	off continuously, on continuously, ADO.Section_26ab
B6_30_Bedroom 3	13.03	0.4	0.31, 0.73, 1.89	0.0, 90.0, 90.0	25.66	off continuously, on continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B6_29_Bedroom 1	10.23	0.4	0.89, 0.53, 0.22, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	23.02	off continuously, on continuously, ADO.Section_26ab
B6_29_Bedroom 3	13.17	0.4	0.31, 0.73, 1.89	0.0, 90.0, 90.0	25.77	off continuously, on continuously, ADO.Section_26ab
B6_29_Bedroom 2	11.38	0.4	0.89, 0.53, 0.23, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	27.69	off continuously, on continuously, ADO.Section_26ab
B14_36_Living Room	18.22	0.4, 0.4	0.73, 0.64, 0.25, 1.13, 0.43	90.0, 90.0, 0.0, 90.0, 0.0	18.53	off continuously, ADO.Section_26a
B14_36_Kitchen/Dining	17.22	0.4, 0.4, 0.871	0.72, 2.15, 0.48, 0.73, 0.73	90.0, 90.0, 0.0, 90.0, 0.0	19.35	off continuously, ADO.Section_26a
B14_36_Bedroom 1	11.18	0.4	0.72, 0.72, 0.31, 0.31	90.0, 90.0, 0.0, 0.0	9.17	off continuously, ADO.Section_26ab
B14_36_Bedroom 2	15.88	0.4	0.52, 0.89, 0.38, 0.22, 0.74	90.0, 90.0, 0.0, 0.0, 90.0	16.71	off continuously, ADO.Section_26ab
B8_26_Living Room	29.3	0.4, 0.4	0.73, 0.31, 1.17, 0.45, 0.64, 0.25, 1.13, 0.43	90.0, 0.0, 90.0, 0.0, 90.0, 0.0, 90.0, 0.0	27.21	off continuously, ADO.Section_26a
B8_26_Kitchen/Dining	13.72	0.4, 0.4	0.72, 2.15, 0.48, 0.73	90.0, 90.0, 0.0, 90.0	19.35	off continuously, ADO.Section_26a
B8_26_Bedroom 1	7.98	0.4	0.72, 0.72, 0.31, 0.31	90.0, 90.0, 0.0, 0.0	9.17	off continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B8_26_Bedroom 2	17.54	0.4, 0.4	0.73, 0.31, 0.53, 0.89, 0.38, 0.23, 0.74	90.0, 0.0, 90.0, 90.0, 0.0, 0.0, 90.0	22.46	off continuously, ADO.Section_26ab
B11_32_Living	17.57	0.4, 0.4	0.35, 0.87, 1.06, 0.62, 0.25, 0.42	0.0, 90.0, 90.0, 90.0, 0.0, 0.0	13.69	off continuously, ADO.Section_26a
B11_31_Living	29.09	0.4, 0.4	0.35, 0.88, 1.12, 0.45, 0.38, 0.94, 1.31, 0.53	0.0, 90.0, 90.0, 0.0, 0.0, 90.0, 90.0, 0.0	22.75	off continuously, ADO.Section_26a
B11_32_Kitchen/Dining	17.61	0.4, 0.4	0.72, 0.38, 0.56, 2.1	90.0, 0.0, 90.0, 90.0	19.49	off continuously, ADO.Section_26a
B11_31_Kitchen/Dining	17.67	0.4, 0.4	2.1, 0.56, 0.38, 0.72	90.0, 90.0, 0.0, 90.0	19.64	off continuously, ADO.Section_26a
B11_32_ Bedroom 1	10.3	0.4	0.89, 0.52, 0.22, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	23.35	off continuously, on continuously, ADO.Section_26ab
B11_32_Bedroom 2	11.41	0.4	0.89, 0.52, 0.23, 0.38, 1.89	90.0, 90.0, 0.0, 0.0, 90.0	27.84	off continuously, on continuously, ADO.Section_26ab
B11_32_Bedroom 3	13.03	0.4	0.31, 0.74, 1.89	0.0, 90.0, 90.0	25.76	off continuously, on continuously, ADO.Section_26ab
B11_31_Bedroom 1	15.53	0.4, 0.4	0.31, 0.74, 0.89, 0.53, 0.22, 0.38, 1.89	0.0, 90.0, 90.0, 90.0, 0.0, 0.0, 90.0	28.17	off continuously, on continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B11_31_Bedroom 3	13.17	0.4	0.31, 0.73, 1.89	0.0, 90.0, 90.0	25.77	off continuously, on continuously, ADO.Section_26ab
B11_31_Bedroom 2	17.28	0.4, 0.4	0.89, 0.52, 0.23, 0.38, 0.31, 0.74, 1.89	90.0, 90.0, 0.0, 0.0, 0.0, 90.0, 90.0	33.79	off continuously, on continuously, ADO.Section_26ab
B15_37_Living Room	18.22	0.4, 0.4	0.73, 0.64, 0.25, 1.13, 0.43	90.0, 90.0, 0.0, 90.0, 0.0	18.53	off continuously, ADO.Section_26a
B15_37_Kitchen/Dining	17.22	0.4, 0.4, 0.871	0.72, 2.15, 0.48, 0.74, 0.73	90.0, 90.0, 0.0, 90.0, 0.0	19.41	off continuously, ADO.Section_26a
B15_37_Bedroom 1	11.18	0.4	0.72, 0.72, 0.31, 0.31	90.0, 90.0, 0.0, 0.0	9.17	off continuously, ADO.Section_26ab
B15_37_Bedroom 2	15.88	0.4	0.53, 0.89, 0.38, 0.23, 0.74	90.0, 90.0, 0.0, 0.0, 90.0	16.79	off continuously, ADO.Section_26ab
B15_38_Living Room	18.22	0.4, 0.4	0.73, 0.64, 0.25, 1.13, 0.43	90.0, 90.0, 0.0, 90.0, 0.0	18.53	off continuously, ADO.Section_26a
B15_38_Kitchen/Dining	17.22	0.4, 0.4, 0.871	0.72, 2.15, 0.48, 0.74, 0.73	90.0, 90.0, 0.0, 90.0, 0.0	19.41	off continuously, ADO.Section_26a
B15_38_Bedroom 1	11.18	0.4	0.72, 0.72, 0.31, 0.31	90.0, 90.0, 0.0, 0.0	9.17	off continuously, ADO.Section_26ab
B15_38_Bedroom 2	15.88	0.4	0.53, 0.89, 0.38, 0.23, 0.74	90.0, 90.0, 0.0, 0.0, 90.0	16.79	off continuously, ADO.Section_26ab
B17_44_Bedroom 1	27.11	0.4	1.05, 0.45, 0.73, 0.32	90.0, 0.0, 90.0, 0.0	13.38	off continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B17_44_Bedroom 2	26.04	0.4	1.07, 0.2, 0.47, 0.46	90.0, 0.0, 90.0, 0.0	16.33	off continuously, ADO.Section_26ab
B17_46_Bedroom 1	27.11	0.4	1.05, 0.45, 0.74, 0.32	90.0, 0.0, 90.0, 0.0	13.46	off continuously, ADO.Section_26ab
B17_46_Bedroom 2	26.04	0.4	1.07, 0.2, 0.47, 0.46	90.0, 0.0, 90.0, 0.0	16.33	off continuously, ADO.Section_26ab
B17_43_Living/Dining/Kitchen	14.57	0.4, 0.4, 0.4	1.89, 0.4, 0.44, 1.89, 0.74, 0.74, 0.32, 0.31, 0.73, 0.73	90.0, 0.0, 90.0, 90.0, 90.0, 90.0, 0.0, 0.0, 90.0, 90.0	27.56	off continuously, on continuously, ADO.Section_26a
B17_45_Living/Dining/Kitchen	6.94	0.4, 0.4	2.1, 0.47, 0.47, 1.89, 0.73	90.0, 90.0, 0.0, 90.0, 90.0	20.02	off continuously, on continuously, ADO.Section_26a
B17_46_Living/Dining/Kitchen	10.96	0.4, 0.4	2.1, 0.47, 0.47, 0.73	90.0, 90.0, 0.0, 90.0	12.12	off continuously, ADO.Section_26ab
B17_44_Living/Dining/Kitchen	19.17	0.4, 0.4, 0.4	2.1, 0.47, 0.47, 0.73, 0.73, 0.73, 0.32, 0.31, 0.73	90.0, 90.0, 0.0, 90.0, 90.0, 90.0, 0.0, 0.0, 90.0	20.16	off continuously, ADO.Section_26ab
B17_45_Bedroom 2	17.5	0.4	0.39, 0.88, 1.89	0.0, 90.0, 90.0	29.71	off continuously, on continuously, ADO.Section_26a
B17_43_Bedroom 2	17.44	0.4	0.39, 0.88, 1.89	0.0, 90.0, 90.0	30.0	off continuously, on continuously, ADO.Section_26a

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B17_45_Bedroom 1	26.52	0.4	0.28, 0.55, 0.63, 1.25, 1.89	0.0, 0.0, 90.0, 90.0, 90.0	27.3	off continuously, on continuously, ADO.Section_26a
B17_43_Bedroom 1	26.24	0.4	0.27, 0.55, 0.62, 1.25, 1.89	0.0, 0.0, 90.0, 90.0, 90.0	26.96	off continuously, on continuously, ADO.Section_26a
B18_47_Bedroom 1	21.43	0.4	0.28, 0.55, 0.63, 1.25	0.0, 0.0, 90.0, 90.0	10.07	off continuously, ADO.Section_26a
B18_47_Living/Dining/Kitchen	11.97	0.4, 0.4	2.1, 0.47, 0.47, 0.28, 0.55, 0.63, 1.25	90.0, 90.0, 0.0, 0.0, 0.0, 90.0, 90.0	12.09	off continuously, ADO.Section_26a
B18_48_Living/Dining/Kitchen	10.98	0.4, 0.4	2.1, 0.47, 0.47, 0.73	90.0, 90.0, 0.0, 90.0	12.26	off continuously, ADO.Section_26ab
B18_48_Bedroom 2	26.3	0.4	1.07, 0.2, 0.47, 0.46	90.0, 0.0, 90.0, 0.0	16.04	off continuously, ADO.Section_26ab
B18_48_Bedroom 1	25.3	0.4	1.05, 0.45, 0.74, 0.31	90.0, 0.0, 90.0, 0.0	12.37	off continuously, ADO.Section_26ab
B18_49_Bedroom 1	21.43	0.4	0.28, 0.55, 0.63, 1.25	0.0, 0.0, 90.0, 90.0	10.07	off continuously, ADO.Section_26a
B18_49_Living/Dining/Kitchen	11.97	0.4, 0.4	2.1, 0.47, 0.47, 0.28, 0.55, 0.63, 1.25	90.0, 90.0, 0.0, 0.0, 0.0, 90.0, 90.0	12.09	off continuously, ADO.Section_26a
B18_50_Living/Dining/Kitchen	10.98	0.4, 0.4	2.1, 0.47, 0.47, 0.73	90.0, 90.0, 0.0, 90.0	12.25	off continuously, ADO.Section_26ab
B18_50_Bedroom 2	26.3	0.4	1.07, 0.2, 0.47, 0.46	90.0, 0.0, 90.0, 0.0	16.04	off continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B18_50_Bedroom 1	25.3	0.4	1.05, 0.45, 0.74, 0.31	90.0, 0.0, 90.0, 0.0	12.37	off continuously, ADO.Section_26ab
B19_51_Bedroom 1	21.43	0.4	0.28, 0.55, 0.63, 1.25	0.0, 0.0, 90.0, 90.0	10.07	off continuously, ADO.Section_26a
B19_51_Living/Dining/Kitchen	11.97	0.4, 0.4	2.1, 0.47, 0.47, 0.28, 0.55, 0.63, 1.25	90.0, 90.0, 0.0, 0.0, 0.0, 90.0, 90.0	12.09	off continuously, ADO.Section_26a
B19_52_Living/Dining/Kitchen	10.98	0.4, 0.4	2.1, 0.47, 0.47, 0.74	90.0, 90.0, 0.0, 90.0	12.29	off continuously, ADO.Section_26ab
B19_52_Bedroom 2	26.3	0.4	1.07, 0.2, 0.47, 0.46	90.0, 0.0, 90.0, 0.0	16.04	off continuously, ADO.Section_26ab
B19_52_Bedroom 1	25.3	0.4	1.05, 0.45, 0.73, 0.32	90.0, 0.0, 90.0, 0.0	12.3	off continuously, ADO.Section_26ab
B19_53_Bedroom 1	21.43	0.4	0.28, 0.55, 0.63, 1.25	0.0, 0.0, 90.0, 90.0	10.07	off continuously, ADO.Section_26a
B19_53_Living/Dining/Kitchen	18.97	0.4, 0.4, 0.4	2.1, 0.47, 0.47, 0.28, 0.55, 0.63, 1.25, 0.32, 0.74, 0.73, 1.1, 0.47	90.0, 90.0, 0.0, 0.0, 0.0, 90.0, 90.0, 0.0, 90.0, 90.0, 90.0, 0.0	19.06	off continuously, ADO.Section_26a
B19_54_Living/Dining/Kitchen	15.24	0.4, 0.4, 0.4	2.1, 0.47, 0.47, 0.73, 0.73, 0.73	90.0, 90.0, 0.0, 90.0, 90.0, 90.0	17.68	off continuously, ADO.Section_26ab
B19_54_Bedroom 2	26.3	0.4	1.07, 0.2, 0.47, 0.46	90.0, 0.0, 90.0, 0.0	16.04	off continuously, ADO.Section_26ab
B19_54_Bedroom 1	25.3	0.4	1.05, 0.45, 0.74, 0.31	90.0, 0.0, 90.0, 0.0	12.37	off continuously, ADO.Section_26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B7_25_Living Room	18.22	0.4, 0.4	0.73, 0.64, 0.25, 1.13, 0.43	90.0, 90.0, 0.0, 90.0, 0.0	18.53	off continuously, ADO.Section_ 26a
B7_25_Kitchen/Dining	17.22	0.4, 0.4	0.72, 2.15, 0.48, 0.73	90.0, 90.0, 0.0, 90.0	19.35	off continuously, ADO.Section_ 26a
B7_25_Bedroom 1	11.18	0.4	0.72, 0.72, 0.31, 0.31	90.0, 90.0, 0.0, 0.0	9.17	off continuously, ADO.Section_ 26ab
B7_25_Bedroom 2	15.88	0.4	0.53, 0.89, 0.38, 0.23, 0.74	90.0, 90.0, 0.0, 0.0, 90.0	16.79	off continuously, ADO.Section_ 26ab
B7_24_Living Room	18.22	0.4, 0.4	0.73, 0.64, 0.25, 1.13, 0.43	90.0, 90.0, 0.0, 90.0, 0.0	18.53	off continuously, ADO.Section_ 26a
B7_24_Kitchen/Dining	17.22	0.4, 0.4	0.72, 2.15, 0.48, 0.73	90.0, 90.0, 0.0, 90.0	19.35	off continuously, ADO.Section_ 26a
B7_24_Bedroom 1	11.18	0.4	0.72, 0.72, 0.31, 0.31	90.0, 90.0, 0.0, 0.0	9.17	off continuously, ADO.Section_ 26ab
B7_24_Bedroom 2	15.88	0.4	0.53, 0.89, 0.38, 0.23, 0.74	90.0, 90.0, 0.0, 0.0, 90.0	16.79	off continuously, ADO.Section_ 26ab
B22_58_Bedroom 1	12.86	0.4, 0.4	0.74, 0.27, 0.52, 0.22, 0.89, 0.38	90.0, 0.0, 90.0, 0.0, 90.0, 0.0	14.05	off continuously, ADO.Section_ 26ab
B23_ 60_Living/Kitchen	16.61	0.4, 0.4, 0.4	2.1, 0.47, 0.47, 1.05, 0.35, 0.73, 0.84	90.0, 90.0, 0.0, 90.0, 0.0, 90.0, 90.0	16.45	off continuously, ADO.Section_ 26ab
B23_60_Bedroom	40.46	0.4	1.89, 0.58, 0.58	90.0, 90.0, 0.0	17.61	off continuously, ADO.Section_ 26ab
B23_ 64_Living	23.98	0.4, 0.4	2.1, 0.47, 0.47, 1.05	90.0, 90.0, 0.0, 90.0	11.47	off continuously, ADO.Section_ 26ab

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B23_64_Bedroom	17.34	0.4	0.84, 0.84	0.0, 90.0	5.59	off continuously, ADO.Section_26ab
B23_ 61_Living/Dining/Kitchen	29.08	0.4, 0.4, 0.871	1.19, 0.52, 0.63, 0.28, 2.1, 0.56, 0.38, 0.88, 0.39, 0.84, 0.87, 0.38	90.0, 0.0, 90.0, 0.0, 90.0, 90.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0	15.82	off continuously, ADO.Section_26a
B23_61_Bedroom	23.08	0.4	0.27, 0.52, 1.19, 0.63	0.0, 0.0, 90.0, 90.0	13.28	off continuously, ADO.Section_26a
B23_ 62_Living/Kitchen	23.98	0.4, 0.4, 0.871	2.1, 0.47, 0.47, 1.05, 0.35, 0.73, 0.84	90.0, 90.0, 0.0, 90.0, 0.0, 0.0, 0.0	11.47	off continuously, ADO.Section_26ab
B23_62_Bedroom	40.46	0.4	1.89, 0.58, 0.58	90.0, 90.0, 0.0	17.61	off continuously, ADO.Section_26ab
B23_ 65_Living/Dining/Kitchen	29.08	0.4, 0.4	1.19, 0.52, 0.63, 0.28, 2.1, 0.56, 0.38	90.0, 0.0, 90.0, 0.0, 90.0, 90.0, 0.0	15.82	off continuously, ADO.Section_26a
B23_65_Bedroom	23.08	0.4, 0.871	1.19, 0.52, 0.63, 0.28, 0.84	90.0, 0.0, 90.0, 0.0, 0.0	13.28	off continuously, ADO.Section_26a
B23_ 66_Living	23.98	0.4, 0.4	2.1, 0.47, 0.47, 1.05	90.0, 90.0, 0.0, 90.0	11.47	off continuously, ADO.Section_26ab
B23_66_Bedroom	17.35	0.4	0.84, 0.84	0.0, 90.0	5.59	off continuously, ADO.Section_26ab
B23_ 67_Living/Dining/Kitchen	29.08	0.4, 0.4, 0.871	1.19, 0.52, 0.62, 0.27, 2.1, 0.56, 0.38, 0.88, 0.39, 0.84, 0.87, 0.38	90.0, 0.0, 90.0, 0.0, 90.0, 90.0, 0.0, 0.0, 0.0, 0.0, 0.0, 0.0	15.79	off continuously, ADO.Section_26a
B23_67_Bedroom	12.36	0.4	0.28, 0.52, 1.19, 0.63	0.0, 0.0, 90.0, 90.0	13.28	off continuously, ADO.Section_26a

Alderford Parade - All Plots

Room name	Window to wall ratio %	Window g-value (EN 410)	Opening gross area m²	Opening free area (avg) %	Opening free area / floor area ratio %	Opening profile(s)
B23_ 68_Living/Kitchen	23.98	0.4, 0.4, 0.871	2.1, 0.47, 0.47, 1.05, 0.35, 0.73, 0.84	90.0, 90.0, 0.0, 90.0, 0.0, 0.0, 0.0	11.47	off continuously, ADO.Section_ 26ab
B23_68_Bedroom	17.72	0.4	1.89, 0.58, 0.58	90.0, 90.0, 0.0	17.61	off continuously, ADO.Section_ 26ab
B24_69_Bedroom 1	15.1	0.4, 0.4	0.87, 0.32, 0.89, 0.89, 0.52, 0.52	90.0, 0.0, 0.0, 90.0, 90.0, 0.0	14.05	off continuously, ADO.Section_ 26ab
B24_70_Bedroom 1	15.16	0.4, 0.4	0.88, 0.31, 0.89, 0.89, 0.52, 0.53	90.0, 0.0, 0.0, 90.0, 90.0, 0.0	14.21	off continuously, ADO.Section_ 26ab

Modelled ventilation

Room name	Infiltration rate ACH	Mech vent flow rate ACH
B2_6_ Living Room	0.15	0.0
B2_7_ Living Room	0.15	0.0
B2_6_ Bedroom 4	0.15	0.0
B2_7_Bedroom 4	0.15	0.0
B2_7_ Bedroom 3	0.15	0.0
B2_6_Bedroom 3	0.15	0.0
B2_6_ Bedroom 2	0.15	0.0
B2_7_Bedroom 2	0.15	0.0
B2_7_Bedroom 1	0.15	0.0
B2_6_Bedroom 1	0.15	0.0
B6_23_Living	0.15	0.0
B6_22_Living	0.15	0.0
B6_23_Kitchen/Dining	0.15	1.11
B6_22_Kitchen/Dining	0.15	1.12
B6_23_ Bedroom 1	0.15	0.0
B6_23_Bedroom 2	0.15	0.0
B6_23_Bedroom 3	0.15	0.0
B6_22_Bedroom 1	0.15	0.0
B6_22_Bedroom 3	0.15	0.0
B6_22_Bedroom 2	0.15	0.0
B13_34_ Bedroom 3	0.15	0.0
B13_34_ Bedroom 2	0.15	0.0
B13_34_ Bedroom 1	0.15	0.0
B13_34_ Living Room	0.15	0.0
B13_34_ Kitchen/Dining	0.15	1.05
B24_69_Living	0.15	0.0
B24_69_Kitchen/Dining	0.15	0.99
B24_70_Living	0.15	0.0
B24_70_Kitchen/Dining	0.15	0.99
B24_69_Bedroom 2	0.15	0.0
B24_70_Bedroom 2	0.15	0.0
B12_33_Living Room	0.15	0.0
B12_33_ Bedroom 1	0.15	0.0
B12_33_ Bedroom 4	0.15	0.0
B12_33_ Bedroom 2	0.15	0.0
B16_42_Bedroom 1	0.15	0.6
B16_40_Bedroom 1	0.15	0.6
B1_2_Bedroom 1	0.15	0.96
B1_1_Bedroom 1	0.15	0.89
B1_2_ Bedroom 2	0.15	0.93

Alderford Parade - All Plots

Room name	Infiltration rate ACH	Mech vent flow rate ACH
B1_2_Bedroom 3	0.15	1.35
B1_1_ Bedroom 3	0.15	1.42
B1_1_Bedroom 2	0.15	0.85
B1_2_ Living Room	0.15	0.77
B1_1_ Living Room	0.15	0.8
B21_57_ Living Room	0.15	0.0
B21_57_Kitchen/Dining	0.15	0.99
B21_57_Bedroom 2	0.15	0.0
B21_57_Bedroom 1	0.15	0.0
B21_57_Bedroom 3	0.15	0.0
B20_56_ Living Room	0.15	0.0
B20_56_ Kitchen/Dining	0.15	1.0
B20_55_ Living Room	0.15	0.0
B20_55_ Kitchen/Dining	0.15	1.0
B20_56_ Bedroom 1	0.15	0.0
B20_56_ Bedroom 2	0.15	0.0
B20_55_ Bedroom 1	0.15	0.0
B20_55_ Bedroom 2	0.15	0.0
B22_58_ Kitchen/Dining	0.15	1.05
B22_58_Living Room	0.15	0.0
B22_58_ Bedroom 3	0.15	0.0
B22_58_ Bedroom 2	0.15	0.0
B14_35_Living Room	0.15	0.0
B14_35_Kitchen/Dining	0.15	1.04
B14_35_Bedroom 1	0.15	0.0
B14_35_Bedroom 2	0.15	0.0
B12_33_ Bedroom 3	0.15	0.0
B12_33_Kitchen/dining	0.15	0.79
B1_1_ Kitchen/Dining	0.15	0.8
B1_2_ Kitchen/Dining	0.15	0.76
B2_6_ Kitchen/Dining	0.15	0.8
B2_7_ Kitchen/Dining	0.15	0.76
B16_41_ Living/Dining/Kitchen	0.15	0.64
B16_39_ Living/Dining/Kitchen	0.15	0.64
B16_42_Living/dining/Kitchen	0.15	0.79
B16_40_Living/dining/Kitchen	0.15	0.79
B23_ 59_Living/Dining/Kitchen	0.15	0.61
B23_59_Bedroom	0.15	0.58
B23_ 63_Living/Dining/Kitchen	0.15	0.61
B23_63_Bedroom	0.15	0.58
B16_41_Bedroom 1	0.15	0.52
B16_39_Bedroom 1	0.15	0.52

Alderford Parade - All Plots

Room name	Infiltration rate ACH	Mech vent flow rate ACH
B1_3_Bedroom 1	0.15	0.96
B1_3_ Bedroom 2	0.15	0.93
B1_3_Bedroom 3	0.15	1.35
B1_3_ Living Room	0.15	0.77
B1_3_ Kitchen/Dining	0.15	0.76
B1_4_Bedroom 1	0.15	0.96
B1_4_ Bedroom 2	0.15	0.93
B1_4_Bedroom 3	0.15	1.35
B1_4_ Living Room	0.15	0.77
B1_4_ Kitchen/Dining	0.15	0.76
B1_5_Bedroom 1	0.15	0.96
B1_5_ Bedroom 2	0.15	0.93
B1_5_Bedroom 3	0.15	1.35
B1_5_ Living Room	0.15	0.77
B1_5_ Kitchen/Dining	0.15	0.76
B2_9_ Living Room	0.15	0.0
B2_8_ Living Room	0.15	0.0
B2_9_ Bedroom 4	0.15	0.0
B2_8_Bedroom 4	0.15	0.0
B2_8_ Bedroom 3	0.15	0.0
B2_9_Bedroom 3	0.15	0.0
B2_9_ Bedroom 2	0.15	0.0
B2_8_Bedroom 2	0.15	0.0
B2_8_Bedroom 1	0.15	0.0
B2_9_Bedroom 1	0.15	0.0
B2_9_ Kitchen/Dining	0.15	0.8
B2_8_ Kitchen/Dining	0.15	0.76
B2_10_ Living Room	0.15	0.0
B2_11_ Living Room	0.15	0.0
B2_10_ Bedroom 4	0.15	0.0
B2_11_Bedroom 4	0.15	0.0
B2_11_ Bedroom 3	0.15	0.0
B2_10_Bedroom 3	0.15	0.0
B2_10_ Bedroom 2	0.15	0.0
B2_11_Bedroom 2	0.15	0.0
B2_11_Bedroom 1	0.15	0.0
B2_10_Bedroom 1	0.15	0.0
B2_10_ Kitchen/Dining	0.15	0.8
B2_11_ Kitchen/Dining	0.15	0.76
B2_13_ Living Room	0.15	0.0
B2_12_ Living Room	0.15	0.0
B2_13_ Bedroom 4	0.15	0.0

Alderford Parade - All Plots

Room name	Infiltration rate ACH	Mech vent flow rate ACH
B2_12_Bedroom 4	0.15	0.0
B2_12_ Bedroom 3	0.15	0.0
B2_13_Bedroom 3	0.15	0.0
B2_13_ Bedroom 2	0.15	0.0
B2_12_Bedroom 2	0.15	0.0
B2_12_Bedroom 1	0.15	0.0
B2_13_Bedroom 1	0.15	0.0
B2_13_ Kitchen/Dining	0.15	0.8
B2_12_ Kitchen/Dining	0.15	0.76
B2_14_ Living Room	0.15	0.0
B2_15_ Living Room	0.15	0.0
B2_14_ Bedroom 4	0.15	0.0
B2_15_Bedroom 4	0.15	0.0
B2_15_ Bedroom 3	0.15	0.0
B2_14_Bedroom 3	0.15	0.0
B2_14_ Bedroom 2	0.15	0.0
B2_15_Bedroom 2	0.15	0.0
B2_15_Bedroom 1	0.15	0.0
B2_14_Bedroom 1	0.15	0.0
B2_14_ Kitchen/Dining	0.15	0.8
B2_15_ Kitchen/Dining	0.15	0.76
B2_17_ Living Room	0.15	0.0
B2_16_ Living Room	0.15	0.0
B2_17_ Bedroom 4	0.15	0.0
B2_16_Bedroom 4	0.15	0.0
B2_16_ Bedroom 3	0.15	0.0
B2_17_Bedroom 3	0.15	0.0
B2_17_ Bedroom 2	0.15	0.0
B2_16_Bedroom 2	0.15	0.0
B2_16_Bedroom 1	0.15	0.0
B2_17_Bedroom 1	0.15	0.0
B2_17_ Kitchen/Dining	0.15	0.8
B2_16_ Kitchen/Dining	0.15	0.76
B2_18_ Living Room	0.15	0.0
B2_19_ Living Room	0.15	0.0
B2_18_ Bedroom 4	0.15	0.0
B2_19_Bedroom 4	0.15	0.0
B2_19_ Bedroom 3	0.15	0.0
B2_18_Bedroom 3	0.15	0.0
B2_18_ Bedroom 2	0.15	0.0
B2_19_Bedroom 2	0.15	0.0
B2_19_Bedroom 1	0.15	0.0

Alderford Parade - All Plots

Room name	Infiltration rate ACH	Mech vent flow rate ACH
B2_18_Bedroom 1	0.15	0.0
B2_18_ Kitchen/Dining	0.15	0.8
B2_19_ Kitchen/Dining	0.15	0.76
B2_21_ Living Room	0.15	0.0
B2_20_ Living Room	0.15	0.0
B2_21_ Bedroom 4	0.15	0.0
B2_20_Bedroom 4	0.15	0.0
B2_20_ Bedroom 3	0.15	0.0
B2_21_Bedroom 3	0.15	0.0
B2_21_ Bedroom 2	0.15	0.0
B2_20_Bedroom 2	0.15	0.0
B2_20_Bedroom 1	0.15	0.0
B2_21_Bedroom 1	0.15	0.0
B2_21_ Kitchen/Dining	0.15	0.8
B2_20_ Kitchen/Dining	0.15	0.76
B6_28_Living	0.15	0.0
B6_27_Living	0.15	0.0
B6_28_Kitchen/Dining	0.15	1.11
B6_27_Kitchen/Dining	0.15	1.12
B6_28_ Bedroom 1	0.15	0.0
B6_28_Bedroom 2	0.15	0.0
B6_28_Bedroom 3	0.15	0.0
B6_27_Bedroom 1	0.15	0.0
B6_27_Bedroom 3	0.15	0.0
B6_27_Bedroom 2	0.15	0.0
B6_30_Living	0.15	0.0
B6_29_Living	0.15	0.0
B6_30_Kitchen/Dining	0.15	1.11
B6_29_Kitchen/Dining	0.15	1.12
B6_30_ Bedroom 1	0.15	0.0
B6_30_Bedroom 2	0.15	0.0
B6_30_Bedroom 3	0.15	0.0
B6_29_Bedroom 1	0.15	0.0
B6_29_Bedroom 3	0.15	0.0
B6_29_Bedroom 2	0.15	0.0
B14_36_Living Room	0.15	0.0
B14_36_Kitchen/Dining	0.15	1.04
B14_36_Bedroom 1	0.15	0.0
B14_36_Bedroom 2	0.15	0.0
B8_26_Living Room	0.15	0.0
B8_26_Kitchen/Dining	0.15	1.04
B8_26_Bedroom 1	0.15	0.0

Alderford Parade - All Plots

Room name	Infiltration rate ACH	Mech vent flow rate ACH
B8_26_Bedroom 2	0.15	0.0
B11_32_Living	0.15	0.0
B11_31_Living	0.15	0.0
B11_32_Kitchen/Dining	0.15	1.11
B11_31_Kitchen/Dining	0.15	1.12
B11_32_ Bedroom 1	0.15	0.0
B11_32_Bedroom 2	0.15	0.0
B11_32_Bedroom 3	0.15	0.0
B11_31_Bedroom 1	0.15	0.0
B11_31_Bedroom 3	0.15	0.0
B11_31_Bedroom 2	0.15	0.0
B15_37_Living Room	0.15	0.0
B15_37_Kitchen/Dining	0.15	1.04
B15_37_Bedroom 1	0.15	0.0
B15_37_Bedroom 2	0.15	0.0
B15_38_Living Room	0.15	0.0
B15_38_Kitchen/Dining	0.15	1.04
B15_38_Bedroom 1	0.15	0.0
B15_38_Bedroom 2	0.15	0.0
B17_44_Bedroom 1	0.15	0.75
B17_44_Bedroom 2	0.15	1.06
B17_46_Bedroom 1	0.15	0.75
B17_46_Bedroom 2	0.15	1.06
B17_43_Living/Dining/Kitchen	0.15	0.67
B17_45_Living/Dining/Kitchen	0.15	0.67
B17_46_Living/Dining/Kitchen	0.15	0.8
B17_44_Living/Dining/Kitchen	0.15	0.8
B17_45_Bedroom 2	0.15	0.86
B17_43_Bedroom 2	0.15	0.87
B17_45_Bedroom 1	0.15	0.58
B17_43_Bedroom 1	0.15	0.57
B18_47_Bedroom 1	0.15	0.43
B18_47_Living/Dining/Kitchen	0.15	0.47
B18_48_Living/Dining/Kitchen	0.15	0.8
B18_48_Bedroom 2	0.15	1.04
B18_48_Bedroom 1	0.15	0.69
B18_49_Bedroom 1	0.15	0.43
B18_49_Living/Dining/Kitchen	0.15	0.47
B18_50_Living/Dining/Kitchen	0.15	0.8
B18_50_Bedroom 2	0.15	1.04
B18_50_Bedroom 1	0.15	0.69
B19_51_Bedroom 1	0.15	0.43

Alderford Parade - All Plots

Room name	Infiltration rate ACH	Mech vent flow rate ACH
B19_51_Living/Dining/Kitchen	0.15	0.47
B19_52_Living/Dining/Kitchen	0.15	0.8
B19_52_Bedroom 2	0.15	1.04
B19_52_Bedroom 1	0.15	0.69
B19_53_Bedroom 1	0.15	0.43
B19_53_Living/Dining/Kitchen	0.15	0.47
B19_54_Living/Dining/Kitchen	0.15	0.8
B19_54_Bedroom 2	0.15	1.04
B19_54_Bedroom 1	0.15	0.69
B7_25_Living Room	0.15	0.0
B7_25_Kitchen/Dining	0.15	1.04
B7_25_Bedroom 1	0.15	0.0
B7_25_Bedroom 2	0.15	0.0
B7_24_Living Room	0.15	0.0
B7_24_Kitchen/Dining	0.15	1.04
B7_24_Bedroom 1	0.15	0.0
B7_24_Bedroom 2	0.15	0.0
B22_58_Bedroom 1	0.15	0.0
B23_ 60_Living/Kitchen	0.15	0.69
B23_60_Bedroom	0.15	0.71
B23_ 64_Living	0.15	0.69
B23_64_Bedroom	0.15	0.67
B23_ 61_Living/Dining/Kitchen	0.15	0.61
B23_61_Bedroom	0.15	0.58
B23_ 62_Living/Kitchen	0.15	0.69
B23_62_Bedroom	0.15	0.71
B23_ 65_Living/Dining/Kitchen	0.15	0.61
B23_65_Bedroom	0.15	0.58
B23_ 66_Living	0.15	0.69
B23_66_Bedroom	0.15	0.67
B23_ 67_Living/Dining/Kitchen	0.15	0.61
B23_67_Bedroom	0.15	0.58
B23_ 68_Living/Kitchen	0.15	0.69
B23_68_Bedroom	0.15	0.71
B24_69_Bedroom 1	0.15	0.0
B24_70_Bedroom 1	0.15	0.0

Part 3 – Completion details

3.1 Builders Declaration			
Has the residential building been constructed and completed according to the specifications set out in the above calculations.		Yes	No
Builder's name			
Builder's organisation			
Builder's signature			
Date of signature			

3.2 Building control body inspector's declaration			
Is the residential building's construction consistent with the details provided above in the calculations.		Yes	No
Inspector's name			
Inspector's signature			
Registration number (if applicable)			
Date of inspection			

Directors
M GIBSON C.Eng, C.Env, B. Eng (Hons) M.E.I, M.I.E.T SocEnv | **M ADAMS** B. Eng (Hons) LCEA
Energy Counsel is a Trading Style of EC Energy Ltd.
Registered in England and Wales No: 5615580 VAT No: 803266746
Registered Office: Viridor House, No.3 Bolholt Terrace, Bury, BL8 1PP
Telephone: 0161 762 1055 Fax: 0161 761 1094
E-mail: Matthew.Gibson@energycounsel.co.uk Web: www.energycounsel.co.uk