

Application details:	Application number: 141898/FO/2025 Proposal: Creation of a 3G football pitch, 2no. tennis/multi use courts, 6no. doubles padel courts, 4no. shipping containers to create cafe, terrace and storage facilities, 1no. shipping container to provide changing facilities and associated parking, secure cycle storage, private access road, fencing, lighting posts and canopies following demolition of existing buildings. Location: Wythenshawe Town FC, Timpson Road, Manchester, M23 9LL.
-----------------------------	---

LLFA Comments 01/05/2025

The following Information has been considered:

Planning Portal uploads:	14/01/2025 - 11/02/2025
Further submission emails:	From: David Lawless <[REDACTED]> Sent: 27 March 2025 16:37 To: Flood Risk Management <[REDACTED]> Subject: Fw: Planning application: 141898/FO/2025.
Pre-Application Advice:	NA

Any LLFA Comments to LPA

Records indicate United Utilities public sewer crossing onsite.
 The LPA should ensure United Utilities are consulted on an approvable Master Plan before determining this planning application.

Condition: Prior to the commencement of the development hereby approved, a surface water drainage scheme for the development site, based on sustainable drainage principles, shall be submitted for approval in writing by the City Council, as Local Planning Authority. This shall include:

- For surface water connections, evidence of agreement in principle from the relevant authority/service provider is required to ensure there is adequate spare capacity in the existing system taking future development requirements into account. An email of acceptance of proposed new connection will suffice.

- Details of surface water attenuation that offers a reduction in surface water runoff rate in line with the Manchester Trafford and Salford Strategic Flood Risk Assessment. Provide at least a 50% reduction in brownfield runoff rate or greenfield runoff rate.
- Finalised surface water drainage layout including all components, levels, connectivity and proposed overland flow routes for extreme events.
- Hydraulic calculations of the proposed drainage system, including all design parameters. Results must demonstrate no surcharge for the 1 in 2, no flooding in the 1 in 30 and no flooding of buildings for the 1 in 100 + 45% Climate Change.
- Where flows less than 5 l/s are proposed, a blockage risk assessment must be undertaken. If the risk cannot be adequately managed, a higher minimum discharge rate should be considered / agreed with relevant authority.
- A plan indicating easements. SuDS features (including attenuation tanks) should be appropriately positioned, including a 2.5m easement from the existing highway and a 5m easement from any dwellings, guaranteeing accessibility for future maintenance and contingency for asset failure. This practice is in accordance with SuDS Manual (C753).
- Construction details of flow control and SuDS components.
- Details of how the scheme shall be maintained and managed after completion.

The development shall be constructed and completed in accordance with the approved details prior to the first occupation/use of the development.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution. This condition is imposed in light of national policies within the NPPF and NPPG and local policies EN08 and EN14.