From: Tom Kelly
To: Tom Kelly
Subject: FW: 3916 Plant Hill - Planning Condition 15: Noise
Date: 28 April 2026 14:46:46
Attachments: image011.png
c114dc5a-80d1-42b2-a97e-1b53bd2d3fc2.png

From: Lise Tjellesen [redacted]
Sent: 24 April 2026 11:46
To: Michael Berrie <[redacted]>; Scott Angus [redacted]
Cc: Tom Kelly [redacted]>; Jenni Pocsai <[redacted]; Andy Chorlton [redacted]>; Jordan Whelan [redacted] Ben Richardson [redacted]
Subject: RE: 3916 Plant Hill - Planning Condition 15: Noise

Hi Michael,

Further to our telephone conversation yesterday, I have looked into this a little further.

The details, as requested by the LPA, have partly been given in table 1 in our report.

I have elaborated a little further on the table below, adding in the criteria and the exceedances. With regards to the LAFmax, the listed values show the number of exceedances of 45 dBA each night. The exceedances are between 3 to 8 dB.

I hope that answers your question.

@Scott Angus, our technician is just sorting out the measurement equipment now before heading over to site.

Kind regards,
Lise

Measurement Location	Period	Start Date	Criteria, $L_{Aeq,T}$ (dB)	$L_{Aeq,T}$ (dB) *)	Exceedance (dB)	No. of exceedances of 45 dB $L_{AF,max}$ (dB)
	Daytime	04/12/2025	35	34	-	N/A
	Night-time	04/12/2025	30	30	-	74
	Daytime	05/12/2025	35	39	+4	N/A

First Floor Room, facing Plant Hill Road	Night-time	05/12/2025	30	29	-	55
	Daytime	06/12/2025	35	37	+2	N/A
	Night-time	06/12/2025	30	29	-	57
	Daytime	07/12/2025	35	37	+2	N/A
	Night-time	07/12/2025	30	28	-	40
	Daytime	08/12/2025	35	38	+3	N/A
	Night-time	08/12/2025	30	37	+7	286
	Daytime	09/12/2025	35	40	+5	N/A
Ground Floor Room, facing away from Plant Hill Road	Daytime	04/12/2025	35	31	-	N/A
	Daytime	05/12/2025		32	-	N/A
	Daytime	06/12/2025		30	-	N/A
	Daytime	07/12/2025		28	-	N/A
	Daytime	08/12/2025		30	-	N/A

**) red denotes non-compliance*

From: Michael Berrie <[redacted]>
Sent: 17 April 2026 11:51
To: Lise Tjellesen <[redacted]>
Cc: Tom Kelly [redacted]; Jenni Pocsai [redacted] Andy Chorlton [redacted]>; Jordan Whelan <[redacted] Scott Angus <[redacted]>; Ben Richardson [redacted]
Subject: RE: 3916 Plant Hill - Planning Condition 15: Noise

CAUTION: This email originated from outside your organization. Exercise caution when opening attachments or clicking links, especially from unknown senders.

Hi Lise,

Please could you assist with the nature and extend of the exceedances encountered at Plant Hill Road during the testing? See below in yellow.

Your earliest attention to this would be hugely appreciated.

Regards

Michael Berrie

Quantity Surveyor

[redacted] | tysonconstruction.co.uk
A: 1 Mitcham Road, Blackpool, FY4 4QN

