ODOUR IMPACT ASSESSMENT

EMAQ, (2018) Control of Odour and Noise from Commercial Kitchen Exhaust Systems, (amendment DEFRA, 2005)

Commercial Odour



NOISE ASSESSMENTS LTD
YOUR LOCAL ACOUSTIC SPECIALIST

REPORT DETAILS

Report Title	Odour Assessment: Restaurant and Shisha Bar
Site Address	450 Barlow Moor Rd, Chorlton-cum-Hardy, Manchester, M21 0BQ
Project No.	NALPRO080126.01a
Consultant Contact	[redacted]

QUALITY ASSURANCE

Issue No.	Status	Issue Date	Comments	Author	Approved
1	FINAL	24/01/26	-	[redacted]	[redacted]
				J Mape BSc (Hons) PgDip, IOA Cert. Environ. Noise, **Consultant**	D Warren **Director**

This report has been prepared by Noise Assessments the trading name of Noise Assessments Limited, with all reasonable skill, care and diligence within the terms of the Contract with the client, incorporating our General Terms and Conditions of Business and taking account of the resources devoted to it by agreement with the client.

We disclaim any responsibility to the client and others in respect of any matters outside the scope of the above.

This report is confidential to the client and we accept no responsibility of whatsoever nature to third parties to whom this report, or any part thereof, is made known. Any such party relies on the report at their own risk.

Noise Assessments Limited – Companies House Registered No. 12207511

Contents

Assessment Summary 1
1. Proposal 2
2. Existing Context 2
3. Policy and Guidance 2
4. Nearest Sensitive Receptor Locations 3
5. Odour Assessment 3
6. Odour Impact Assessment 5
7. The Odour Management Plan 6
8. Summary 9
APPENDIX A – Site Location 10
APPENDIX B – Classification of Odour and Grease Content of Extract Air from Commercial Kitchens 11
APPENDIX C – EMAQ Odour Impact Risk Assessment Methodology 13
APPENDIX D – Specifications 14

Assessment Summary

A commercial ground floor property (herein referred to as the site) is applying for planning permission for the installation of an extraction system to the rear elevation of the property to facilitate making of coffee, grilling, frying of Middle Eastern Style cuisine, and is required to confirm their external venting complies with external odour guidance. The client has completed an odour assessment 450 Barlow Moor Rd, Chorlton-cum-Hardy, Manchester, M21 0BQ

An odour assessment is required to assess the likely impact from odour generated during the cooking process from an extraction system to be installed. The ducting will exit on the ground floor at the rear of the property. However, the ducting will be taken vertically up the side of the building to above the eaves.

The environmental health department of the local planning authority is likely to have concerns of odour emissions from the use of the extraction fan unit on neighbouring sensitive residential properties during the daytime and night-time.

With respect to odour, it has been identified that providing that the recommendations are taken into account, there should not be a loss of amenity at the existing residential receptors in the vicinity of the extraction vent and as long as a system similar to the one recommended in the OMP are implemented, this would consist of using the “best practicable means” and would prevent statutory nuisance occurring.

As long as the proposed extraction system is properly maintained on a regular basis, it is highly unlikely that odour would become an issue in the future.

1. Proposal

1.1 A commercial ground floor property (herein referred to as the site) is applying for planning permission for the installation of an extraction system to the rear elevation of the property to facilitate making of coffee, grilling, frying of Middle Eastern Style cuisine, and is required to confirm their external venting complies with external odour guidance. The client has completed an odour assessment 450 Barlow Moor Rd, Chorlton-cum-Hardy, Manchester, M21 0BQ

1.2 An odour assessment is required to assess the likely impact from odour generated during the cooking process from an extraction system to be installed. The ducting will exit on the ground floor at the rear of the property. However, the ducting will be taken vertically up the side of the building to above the eaves.

1.3 The environmental health department of the local planning authority is likely to have concerns of odour emissions from the use of the extraction fan unit on neighbouring sensitive residential properties during the daytime and night-time.

2. Existing Context

2.1 The site (two storey detached) is set within a commercial/residential row of two storey detached buildings located along a main shopping road for pedestrians and some vehicle traffic to the rear. The site is surrounded by a mixture of commercial, restaurants, residential buildings, and apartments on the top floors.

2.2 The environmental health department of the local planning authority raised concerns of odour emissions from the use of the fan extraction units venting on neighbouring sensitive residential properties around the site during the daytime and night-time.

3. Policy and Guidance

Odour Technical Guidance

- EMAQ, (2018) Control of Odour and Noise from Commercial Kitchen Exhaust Systems, an amendment of the original DEFRA document published in 2005, deals specifically with the control of kitchen odours.

- Guidance on the Assessment of Odour for Planning, Version 1.1 Institute of Air Quality Management (IAQM), 2018. The IAQM published the 'Guidance on the Assessment of Odour for Planning' document in July 2018. This guidance specifically deals with assessing odour impacts for planning purposes, namely potential effects on amenity.

3.1 The magnitude of odour impact depends on a number of factors and the potential for adverse impacts varies due to the subjective nature of odour perception. The FIDOL acronym is a useful reminder of the factors that can be used to help determine the degree of odour pollution:

- Frequency of detection - frequent odour incidents are more likely to result in adverse impacts;
- Intensity as perceived - intense odour incidents are more likely to result in adverse impacts;
- Duration of exposure - prolonged exposure is more likely to result in adverse impacts;
- Offensiveness - more offensive odours have a higher risk of resulting in adverse impacts; and,
- Receptor sensitivity - (The type of land use and nature of human activities in the vicinity of an odour source. Tolerance and expectation of the receptor.)

3.2 It is important to note that even infrequent emissions of odours may cause loss of amenity if odours are perceived to be particularly intense or offensive.

4. Nearest Sensitive Receptor Locations

4.1 The nearest sensitive receptors (NSRs) have been identified as residential apartments and 2-storey dwellings around the site to the rear.

5. Odour Assessment

Introduction

5.1 This odour assessment relates to the potential future odour emanating from any kitchen extraction system associated with the change of use development, and the potential odour impacts on any sensitive receptors in close proximity to the extract vent.

Nature and Effect of Odour

5.2 Odour is perceived by our brains in response to chemicals present in the air we breathe. Odour is the effect that those chemicals have upon us. Humans have sensitive senses of smell, and they can detect odour even when chemicals are present in very low concentrations. Most odours are a mixture of many chemicals that interact to produce what we detect as an odour.

5.3 Different life experiences and natural variation in the population can result in different sensations and emotional responses by individuals to the same odorous compounds. Because the response to odour is synthesised in our brains, other senses such as sight and taste, and even our upbringing, can influence our perception of odour and whether we find it acceptable, objectionable, or offensive.

Assessment Methodology

5.4 The assessment of odour takes on the following aspects:

- A qualitative assessment of proposed odour emissions from the change of use development;
- An assessment taking into account the nature of the premises;
- The height and position of any proposed flue;

- The recommended exit velocity from the flue; and
- The distance between the proposed flue and the potential odorous emissions and the distance to the sensitive receptor.

Guidance on Control of Odours from Kitchens

5.5 The Department for Environment Food and Rural Affairs (DEFRA) originally published Guidance (now withdrawn) on the control of odours from kitchens. That guidance has been subsequently updated by 'Control of Odour and Noise from Commercial Kitchen Exhaust Systems' (EMAQ, July 2018).

5.6 Although the guidance is not statutory, it provides very useful information on best practice techniques for the minimisation of odour nuisance from kitchen exhaust systems. This source of guidance and ACCON's own experience form the basis of the assessment to determine whether nearby occupiers of existing residential properties would consider that odour emanating from the kitchen extract flue is acceptable or not.

General Principles in Controlling Odour

5.7 The guidance is generally used for premises where food is cooked for patrons on or off the premises and where a kitchen is used to prepare and cook food. In these instances, a kitchen canopy extract system, are invariably present.

5.8 The main purpose of a kitchen canopy is to extract excess heat, steam, fats, smoke and odour arising from cooking processes. Removal of these unwelcome by-products of kitchen activity helps to achieve a reasonably comfortable and safe working environment, protect the working environment, as well as preventing the spread of the products from the kitchen area to other parts of the building.

5.9 Odours from cooking are contained both within the solid, liquid and gaseous material which is extracted by the kitchen canopy, and these different phases generally require different abatement techniques to reduce levels of odour to those levels which are acceptable to those in the vicinity. The extent to which any odour mitigation is required is dependent on the type of foods being prepared and cooked.

5.10 Commonly the kitchen extract canopy will contain the first line of odour control through the incorporation of coarse grease filters, which take out the largest grease particles from the extracted air stream. Such coarse grease filters tend to be a common feature of almost all kitchen canopy systems.

5.11 The type and levels of odour control required downstream of the canopy is very much dependent on a number of factors. The principle ones are:

- Type of food prepared. This is probably the most dominant factor as the type of food, and particularly any spices used, dictates the chemical constituents present in the exhaust air;
- Size of the cooking facility. The number of covers (for these premises, as no dining is included, the important aspect is the amount of general food output from the kitchen); and
- Types of cooking appliances used. This dictates the level of fat, water droplets and temperature within the ventilation air

5.12 The guidance includes two Tables which classify the odour and grease content of extract air according to the general cooking type and equipment used. These are reproduced in Appendix 3 (Table 2A and Table 2B). The information, in Appendix 3, has been used in this report to carry out the odour risk assessment in respect of the consented change of use development.

6. Odour Impact Assessment

6.1 Based on the observed location of the proposed external extraction system, this odour impact assessment and Odour Management Plan has been undertaken in accordance with the EMAQ guidance 'Control of Odour and Noise from Commercial Kitchen Exhaust Systems'.

Risk Assessment

6.2 The guidance provides a means of risk assessing the impact of any catering establishment and proposed and existing uses. The key elements of the method are reproduced in Appendix 3. The method relies on scoring the proposal on four different aspects:

- **Dispersion** – where the extract vents to atmosphere are in relation to the building to which the vent is attached.
- **Proximity of receptors** – the location of the nearest residents;
- **The kitchen size** – number of covers, i.e. level of activity; and
- **Cooking type** – based on grease and odour loading.

6.3 The level of odour which is created by a premises will depend on the size of kitchen and type of cooking. These can be determined using categories which have been set out in the guidance and are replicated in Appendix 4.

6.4 The scores for each aspect are summed to derive an overall significance score, an impact risk, and a statement about the odour control requirement. The guidance has been utilised where possible to determine the risk of odour nuisance from the proposed change of use development, without any additional odour abatement in place.

6.5 The risk assessment provided in Table 1, is a worst-case scenario.

Table 1: Odour Risk Assessment – 450 Barlow Moor Rd, Chorlton-cum-Hardy, Manchester, M21 0BQ.

	Descriptor	Score	Impact Risk	Odour Control Requirement
Dispersion	Moderate	10	High	High level odour control
Proximity of Receptors	Close	10		
Size of kitchen/food cooking area	Small	1		
Cooking Type (Odour & grease loading)	High	7		
Total		28		

6.6 For the proposed flue extract system, exiting at the ground floor level to above the eaves (Moderate, Score 10). There are receptors within 20m of the proposed flue extract (Close, Score 10).

6.7 The kitchen will be Small, less than 30 covers or small sized restaurant (Small, Score 1).

6.8 There will be the cooking of grilling of Middle Eastern type food proposed to take place at the premises. Therefore, the cooking type is classed as High (Score 7).

6.9 The results of the overall assessment are potentially a High Risk.

7. The Odour Management Plan

7.1 Section 7 has quantified that as a worst case for the proposed change of use development (provided the recommendations are taken into account) there is deemed to be a 'High' risk of potential nuisance and ordinarily a High level of odour mitigation would be recommended.

7.2 The proposals are for the installation of an external vent to the rear of the property to above the eaves The example mitigation requirements which could be used:

1. Fine filtration or Electrostatic Precipitator (ESP) followed by carbon filtration (carbon filter with a 0.2 – 0.4 residence time); or
2. Fine filtration or ESP followed by a UV ozone system to achieve the same level of control as 1.

7.3 An example ESP is manufactured by Purifiedair. Purifiedair ESP's have been specifically designed for kitchen extract systems and have integral sumps to collect the oil, grease and smoke particles filtered out of the exhaust. This not only simplifies servicing but eradicates potentially dangerous spillage from the bottom of the units and this cuts down on the buildup of grease within the ducting.

7.4 Purifiedair also provides a UV-O Range, The UV-O range uses UV-C technology to produce ozone and hydroxyl free radicals to oxidise cooking odours through a process of ozonolysis.

7.5 Unlike other UV-C systems, Purifiedair's UV-O units are located outside of the kitchen extract duct and are connected via a spigot and small diameter ducting.

7.6 For optimum performance it is recommended that between two and six seconds of dwell time to allow the ozone to work effectively upon the malodorous gasses within the duct.

Maintenance Programme (Type, Frequency and Regime)

7.7 To minimize the risk of complaints, it is recommended that:

- A visual inspection of the ventilation system be carried out at least once a week. All metal surfaces should be checked to ensure that there is no accumulation of grease or dirt and that there is no surface damage;
- Cooker hoods and grease filters should be cleaned on a daily basis;
- Baffle type self-draining filters and collection drawers should be cleaned weekly, as a minimum. The cleaning period for mesh filters should be at least twice a week;
- Cleaning period for extract ductwork should as follows:

Use	No. hours use per day	Minimum cleaning interval
Heavy use	12-16	Every 3 months
Moderate use	6-12	Every 6 months
Light use	2-6	Annually

7.8 Based on the information provided, it is likely that the premises will be of Light to Moderate Use and should be cleaned at least every 6 months.

- Periodic 'deep hygiene cleaning' should be undertaken by a specialist contractor. All accessible main ductwork runs and branches, including fitted equipment should be inspected and cleaned.
- All fans are to be maintained on a regular basis as recommended by the fan manufacturer; and

- Ventilation grilles, where fitted should have easily removable cores to facilitate cleaning.

Recommendations for maintenance of odour control system

7.9 If the system employs fine filtration and carbon filtration;

- Change fine filters every two weeks
- Change carbon filters every 4 to 6 months

7.10 For a system employing ESP and other in line abatement systems:

- Clean every 2-6 months

7.11 An Autowash nozzle attachment can be sited inside the standard ESP units. Once connected to the control / wash station the collection cells can be automatically cleaned on a regular frequency.

7.12 The autowash system is usually factory fitted but can, if required be retro fitted in existing installations, where required.

7.13 Daily cleaning keeps the filters working at their optimum efficiency and will greatly reduce the number of service visits required throughout the year.

7.14 It will be important that the odour control methods are fully implemented and additionally, that the proposed OMP management measures and frequency of servicing is complied with. With respect to the servicing and maintenance regime, audit and service records should be maintained and made available to the Local Authority on demand.

8. Summary

8.1 With respect to odour, it has been identified that providing that the recommendations are taken into account, there should not be a loss of amenity at the existing residential receptors in the vicinity of the extraction flue and as long as the system similar to the ones recommended in the OMP are implemented, this would consist of using the “best practicable means” and would prevent statutory nuisance occurring.

8.2 If the proposed extraction system is properly maintained on a regular basis, it is highly unlikely that odour would become an issue in the future.

Appendices

APPENDIX A – Site Location

Site location



APPENDIX B – Classification of Odour and Grease Content of Extract Air from Commercial Kitchens

Table 2A: Table detailing the grease and odour content of various types of food

Catering establishment	Description	Odour content				Grease content			
		Low	Moderate	High	Very high	Low	Moderate	High	Very high
Tea shop		■				■			
Pizza restaurant	Herb		■				■		
Steakhouses	Fat		■				■		
French	Herbs/garlic		■				■		
Italian	Herbs/garlic		■				■		
Most pubs	Fat		■				■		
Chinese	Ginger, spices, oil		■					■	
Japanese	Spices, oil		■					■	
Cantonese	Spices, oil		■					■	
Indian	Spices, oil			■				■	
Thai	Spices, oil			■				■	
Vietnamese	Spices, oil			■				■	
Kebab	Fat cooking meat			■				■	
Fried Chicken	Oil, cooking meat				■				■
Pubs (fried)	Oil, cooking meat				■				■
Fish & chip	Oil				■				■
Fast food, burger	Oil, cooking meat				■				■

Table 2B: Table detailing the grease & moisture content of various cooking appliances

Cooking appliance	Grease loading			Moisture content		
	Light	Medium	Heavy	Light	Medium	Heavy
Cooking pots	■					■
Bains Marie	■					■
Steam ovens	■					■
Pizza ovens		■			■	
Bratt pans		■				■
Oven ranges		■			■	
Flat top grills		■			■	
Chip fryers		■			■	
Salamanders		■			■	
Charcoal			■		■	
Gas fired open grills			■		■	
Char boilers			■		■	
Chinese wok ranges			■			■

APPENDIX C – EMAQ Odour Impact Risk Assessment Methodology

Odour control must be designed to prevent odour nuisance in a given situation. The following score methodology is suggested as a means of determining odour control requirements using a simple risk assessment approach.

Impact Risk	Odour Control Requirement	Significance Score*
Low to medium	Low level odour control	<20
High	High level odour control	20-35
Very high	Very high level odour control	>35

*based on the sum of contributions from dispersion, proximity of receptors, size of kitchen and cooking type.

Criteria	Descriptor	Score	Details
Dispersion	Very poor	20	Low level discharge, discharge into courtyard or restriction on stack.
	Poor	15	Not low level but below eaves, or discharge at below 10m/s
	Moderate	10	Discharging 1m above eaves at 10-15m/s
	Good	5	Discharging 1m above ridge at 15m/s
Proximity of receptors	Close	10	Closest sensitive receptor less than 20 m from kitchen discharge
	Medium	5	Closest sensitive receptor between 20-100m from kitchen discharge
	Far	1	Closest sensitive receptor greater than 100m from kitchen discharge
Size of kitchen	Large	5	More than 100 covers or large sized restaurant
	Medium	3	Between 30-100 covers or medium sized restaurant
	Small	1	Less than 30 covers or small restaurant
Cooking type (odour and grease loading)	Very high	10	Pub (high level of fried food), fried chicken, burgers or fish and chips
	High	7	Kebab, Vietnamese, Thai or Indian
	Medium	4	Cantonese, Japanese or Chinese
	Low	1	Most pubs, Italian, French, pizza or steakhouse

APPENDIX D – Specifications

Sitesafe Carbon Filters

We manufacture Sitesafe carbon filters, these innovative carbon units measure 594x196x597mm, three combining to 594x594x597mm, directly replacing our original carbon blocks whilst providing exactly the same filter performance as an existing full size cell.

Their advantage is that they only weigh 18kg each against the 68kg of our original blocks. This takes the strain out of fitting and servicing, allowing only one engineer to complete the task where two had been previously required.

Our Sitesafe carbon filters use panels of activated carbon to remove the malodourous gases within the commercial kitchen extract duct through the process of chemical adsorption. By installing our ESP units before our Sitesafe filters, the carbon life span is greatly increased, allowing it to nullify malodours at optimum efficiency for much longer.

Will require two people plus lifting gear to carry and install.





Carbon PA242424

Size	594x594x597
Gross Weight	68.20kg
Carbon Weight	50.00kg
Rated Airflow	3600m³/hr*
Pressure Drop	120Pa

Safe for one person to carry. No special lifting gear required.



Sitesafe PA240824

Size	594x196x597
Gross Weight	17.95kg
Carbon Weight	16.6kg
Rated Airflow	1200m³/hr*
Pressure Drop	120Pa



Sitesafe 3 x PA240824

Size	594x594x597
Gross Weight	53.85kg
Carbon Weight	50.00kg
Rated Airflow	3600m³/hr*
Pressure Drop	120Pa

purified air® since 1984

Please see below for the recommended minimum dwell times required for different applications and scale up accordingly.

It should be noted that filtration performance will be improved by increasing the dwell times applied.

Application	Recommended Dwell Time	Grade
Cooking - Low Odour, Tea Shop, Canteens	0.1 to 0.2 Seconds	Carbon grade Enhanced for improved performance for light catering odours
Cooking - Moderate Odour. Pizza, Steak House, French, Italian, Pubs, Chinese, Japanese, Cantonese	0.2 to 0.4 Seconds	Enhanced Carbon grade suitable for many applications 65% Minimum CTC
Cooking High Odour, Indian, Thai, Vietnamese, Kebab	0.4-0.6 Seconds	Enhanced Carbon grade suitable for many applications 65% Minimum CTC
Cooking Very High Odour. Fried Chicken, Pubs with large fried food turnover, Fish and Chip Shops, Fast Food / Burgers	0.4-0.8 Seconds	Enhanced Carbon grade suitable for many applications 65% Minimum CTC
Reduction of Kerosene Exhaust fumes	0.1 to 0.2 Seconds	General Purpose Activated Carbon
Reduction of Ozone	0.1 to 0.2 Seconds	General Purpose Activated Carbon
Reduction of Diesel Fumes, including H_2S, SO_2, NOX, HCl	0.2 Seconds	Carbon Museum,Archive, Café Directive: SO2 SOX NO2 NOX Removal
Museum and Archives	0.2 Seconds	Carbon Museum,Archive, Café Directive: SO2 SOX NO2 NOX Removal

The cooking odour classes above are as classified by DEFRA in **Guidance on the Control of Odour and Noise from Commercial Kitchen Exhaust Systems, PB10527**

Electrostatic Precipitation (ESP) Filter Unit



FUSIONHOT LTD

Stainless Steel Fabrication

Commercial Kitchen Design and Installation

Anti Vibration Mounts (A.V. Mounts)



Load range per mount 5Kg -28Kg

Anti Vibration Mounts (A.V. Mounts) attach to the bottom of Mounting Feet.

A.V. Mounts are used to isolate the fan from the system to prevent vibration transfer through fixings or structures.

A.V. Mounts can be used to isolate any products from the main system to prevent vibration transfer

The main uses A.V. Mounts for are, Axial flow fans, Box fans, Centrifugal fans, in fact A.V. Mounts can be used with anything that causes vibration.

FUSIONHOT
Stainless Steel Fabrication
Commercial Kitchen Design and Installation


Unit5 Firefly Square Plantation Road Burscough Industrial Estate L40 8JT

VAT No. 245073616

Tel: 01704-893945 **Fax:** 0844-4122296

Email: fusionhot1@gmail.com **Web:** wwwFusionHot.co.uk

UNISTRUT P2663



Load Data (All Loads are kN)

Part Number	L	1/2 L F1 1/2 L	F1 L	1/3L F2 1/3L F2 1/3L	1/4L F3 1/4L F3 1/4L F3 1/4L
P2663/150	150	6.2	3.1	3.1	2.06
P2663/300	300	3.2	1.6	1.6	1.06
P2663/450	450	2.15	1.07	1.07	0.71
P2663/600	600	1.62	0.81	0.81	0.54
P2663/750	750	1.3	0.65	0.65	0.43

Part No.	Finish	Size	Length	Weight
P2663/150	HG	41mm	150mm	0.80
P2663/300	HG	41mm	300mm	1.17
P2663/450	HG	41mm	450	1.59
P2663/600	HG	41mm	600	2.03
P2663/750	HG	41mm	750	2.53
P2663/150	SS	41mm	150mm	0.81
P2663/300	SS	41mm	300mm	1.20
P2663/450	SS	41mm	450	1.62
P2663/600	SS	41mm	600	2.08
P2663/750	SS	41mm	750	2.62

Project: A

Architect / Engineer: B

Date: C **Phone:** D

Contractor: E

Address: F

Notes 1: G

Approval Stamp:

UV-O 1000



INTRODUCTION

Reduction of cooking odours from commercial kitchens is an increasingly important issue, different combinations of product are required to do this.

HOW IT WORKS


The Purified Air UV-O 1000 unit uses UV-C technology to produce ozone and hydroxyl free radicals to oxidise odours through a process of Ozonolysis.

Unlike other UV-C systems, the UV-O 1000 is located outside the kitchen extract duct and connects via spigots and small diameter ducting. It is widely accepted that the best way to apply UV-C is in the airstream itself. However, the lamps quickly become dirty and the effectiveness is greatly reduced. By applying the lamps outside of the airstream we are able to fully control the condition of the lamps which provides for a uniform output, the air entering the UV-O 1000 does not come via the extract and is filtered on entry, the system allows a uniform delivery of clean treated air to enter the extract system. A further advantage is that the pressure loss exhibited when the unit is installed is low and uniform.



purified air®

ABOUT US


HERE TO HELP
We undertake various noise assessments and noise survey for a wide range of clients to meet their noise requirements and obligations, including for Planning Applications, new developments, building extensions, change of use, small businesses, restaurants, shops and much more.
QUALIFIED AND EXPERIENCED
Over 15 years UK and international acoustic engineering experience of undertaking Noise Monitoring, acoustic solutions, noise survey and Reporting.
Members of the Instituite of Acoustics. Undertaken projects in Manchester, North West and across the UK.
GET THE PROJECT DONE
We offer competitive, cost effective acoustic solutions, delivering a noise survey report which complies with Local Planning Authority requirements and sound insulation or health and safety obligations.
We can also undertake Noise Modelling if required.