Outlook

Re: OTH-2026-000590

From heather@phaus.co.uk <heather@phaus.co.uk>
Date Tue 2026-06-23 10:21 AM
To Lea Joseph <Lea.Joseph@manchester.gov.uk>
Cc Paul Swindles <paul@phaus.co.uk>; Benet Crangle <ben@proloco.uk>; Richard Carver <rich@proloco.uk>; Dan Hope <dan@proloco.uk>; Martyn Richards <m.richards@rischegroup.co.uk>; Rachael Cook <r.cook@rischegroup.co.uk>

ALERT This message originated outside of the Manchester City Council network. **BE CAUTIOUS** before clicking any links or opening any attachments. Please remember your Cyber Training and report anything suspicious.

Hi again Lea

See below which I have received from the Principle Contractor, Rische, with respect to Condition 19:

> ***Canopy;***
> *Front Face Canopy Hood, size 2400 x 1200 x 540, complete with fully welded perimeter gutter and rear extract plenum with baffle type st/steel grease filters and clean out drawers. Within the hood LED Spot lighting.*
>
> ***Extract System for canopy;***
> *For the extract 1x fan, controller, 2x Silencers, to suit equipment. (Woods MaXfan Compac) Data sheet attached.*
>
> *UV/ Ozone unit installed to suit*

Should you require anything additional to this then please come back to me.

Many thanks
Heather
PHAUS
07528661968

From: heather@phaus.co.uk <heather@phaus.co.uk>
Sent: 23 June 2026 10:20 AM
To: Lea Joseph <lea.joseph@manchester.gov.uk>
Cc: Paul Swindles <paul@phaus.co.uk>; Benet Crangle <ben@proloco.uk>; Richard Carver <rich@proloco.uk>; Dan Hope <dan@proloco.uk>; Martyn Richards <m.richards@rischegroup.co.uk>; Rachael Cook <r.cook@rischegroup.co.uk>
Subject: Re: OTH-2026-000590

> Hi Lea