
NATURAL VENTILATION
THIS ROOM TO BE NATURALLY
VENTILATED VIA OPENABLE WINDOWS.
NATURAL VENTILATION
THIS OPEN PLAN
TO BE NATURALLY VENTILATED
VIA OPENABLE WINDOWS.
NATURAL VENTILATION
THIS ROOM TO BE NATURALLY
VENTILATED VIA OPENABLE WINDOWS.
NATURAL VENTILATION
THIS OPEN SPACE IS TO BE NATURALLY
VENTILATED VIA OPENABLE WINDOWS.
NATURAL VENTILATION
THIS TO BE NATURALLY
VENTILATED VIA OPENABLE WINDOWS.
NATURAL VENTILATION
THIS AREA TO BE NATURALLY
VENTILATED VIA OPENABLE WINDOWS.
COURTYARD
MOTORISED SMOKE FIRE DAMPER PROVIDED TO FORM AIRFLOW PATH BETWEEN ROOM AND ADJACENT AREAS TO BE LINKED TO BUILDING WIDER FIRE ALARM SYSTEM.
MOTORISED SMOKE FIRE DAMPER PROVIDED TO FORM AIRFLOW PATH BETWEEN CORRIDOR AND TO BE LINKED TO BUILDING WIDER FIRE ALARM SYSTEM.
1250mm DUCT CAPPED OFF FOR TENANT FIT-OUT WITHIN THE CEILING VOID.
DUCTWORK AT HL WITHIN THE RAILINGS
NEW EXTRACT FAN (EF/SE3) TO BE INSTALLED WITHIN THE EXISTING PLANT ATS (SEE EXISTING LAYOUT) INCLUDING DUCTWORK, C/W CONTROL, ATT AND AP FOR MAINTENANCE ACCESS. POWER SUPPLY TO BE TAKEN FROM TENANT DB.
NEW EXTRACT FAN (EF/SE2) TO BE INSTALLED WITHIN THE EXISTING PLANT ATS (SEE EXISTING LAYOUT) INCLUDING DUCTWORK, C/W CONTROL, ATT AND AP FOR MAINTENANCE ACCESS. POWER SUPPLY TO BE TAKEN FROM TENANT DB.
ACCESSIBLE WC
WC
WC
WC
WC
WC
WC
WC
LIFT GOODS LIFT
LIFT 1
LIFT 2
LIFT 3
LIFT 4
LIFT 5
LIFT 6
EXTERNAL RISER
FEMME WC
CORRIDOR
CORRIDOR
CORRIDOR
FIRE ESCAPE STAIR
FIRE ESCAPE STAIR
NORTH LIFT CORE
SOUTH LIFT CORE
SERVICE RISER
PLANT ROOM
PLANT ROOM
PLANT ROOM