

ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE INDICATED.

DO NOT SCALE FROM THIS DRAWING. IF IN DOUBT ASK.

THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE PROJECT SPECIFICATION AND ALL OTHER PROJECT DOCUMENTATION.

CONTAINMENT NOTES

1. THIS DRAWING SHOULD BE READ IN COLOUR.
2. THIS DRAWING IS A PRELIMINARY DRAWING ONLY.
3. ALL CONTAINMENT TO BE SIZED TO INCLUDE A MINIMUM OF 20% SPARE CAPACITY.
4. WHERE CONTAINMENT PASSES THROUGH FIRE COMPARTMENTS THE ELECTRICAL CONTRACTOR SHALL ALLOW FOR ALL FIRE STOPPING.
5. THE DRAWING INDICATES PRIMARY RUNS ONLY, THE ELECTRICAL CONTRACTOR SHALL PROVIDE ADDITIONAL SECONDARY RUNS WHERE REQUIRED.
6. THE ELECTRICAL CONTRACTOR SHALL PREPARE HIS OWN FULL DETAILED CONSTRUCTION AND WORKING DRAWINGS BASED UPON ARCHITECTURAL DRAWINGS AND STRUCTURAL ENGINEERING DRAWINGS. THESE DRAWINGS SHOULD BE REQUESTED BY THE ELECTRICAL CONTRACTOR AT TENDER STAGE FROM THE MAIN CONTRACTOR.F
7. AL CONTAINMENT TO RUN WITHIN CEILING VOID UNLESS OTHERWISE DENOTED.
8. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL OTHER CONSULTANTS DRAWINGS, SPECIFICATIONS AND SCHEDULES.
9. ALL CONTAINMENT TO BE INSTALLED IN ACCORDANCE WITH THE LATEST IET WIRING REGULATIONS
10. ALL INSTALLATIONS SHALL COMPLY WITH THE CURRENT EDITION OF MECHANICAL, ELECTRICAL AND PUBLIC HEALTH (MEP) STANDARD SPECIFICATION & GUIDANCE (TECHNICAL ANNEX) GPA-WDG-TA-XX-MEP-001 AND IT INFRASTRUCTURE ANNEX DOCUMENT
11. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE ACCOMPANYING SPECIFICATION

LEGEND

- CMD UNDERFLOOR BUSBAR (LENGTH DENOTED ON DRAWING)
- EF — CMD BETATRAK END FEED (PBSF3010/SM)
- TO — CMD BETATRAK TAP OFF (RAB114)
- NEW TENANT POWER LOW-LEVEL CONTAINMENT
  - MAIN TENANT POWER 200mm CABLE TRAY
- NEW TENANT POWER LOW-LEVEL CONTAINMENT
  - SUBMAIN TENANT POWER 100mm CABLE TRAY
- TENANT DATA LOW-LEVEL CONTAINMENT
  - MAIN TENANT DATA 100mm BASKET
- TENANT DATA LOW-LEVEL CONTAINMENT
  - SUBMAIN TENANT DATA 50mm BASKET
- OUT-OF-SCOPE

Revision	Date	Description
P04	19.06.26	RIBA STAGE 4
P03	29.05.26	TENDER ISSUE
P02	02.04.26	TENDER ISSUE
P01	13.03.26	PRELIMINARY STAGE 4 ISSUE

Client & Site

SUNLIGHT HOUSE
LITTLE QUAY STREET
MANCHESTER
M3 3HP

Title

PROPOSED LOW LEVEL CONTAINMENT
8TH FLOOR LAYOUT

Steven A. Hunt & Associates
Hangar 9, De Havilland Drive, Liverpool L24 8RN
T 0151 427 8009
W www.stevenhunt.com E info@stevenhunt.com

Scale: 1:100 Size: A1 Drawn: EV Chkd: DK

Drawing No. ISO19650 Compliant

Project	Origin	Zone	Level	File Type	Role	Number	Suitability	Rev:
4745	SHA	XX	08	DR	E	4000	S2	P04

PRELIMINARY

Y:\4745 - Sunlight House\6.0 Drawings\6.2 Electrical Engineers\8th Floor\E400 - Low Level Containment and Busbar 8th Floor.dwg
Plot Date: 19 June 2026 Layout Name: 4745-SHA-XX-08-DR-E-4000 Paper Size: ISO A1 (841.00 x 594.00 MM)
ELLIOT VEREGAN