Outlook

RE: 22-036 - Russell Rd - External lighting queries.

From [redacted]
Date Mon 13/07/2026 09:20
To [redacted]

Apologies they should be on the drawing.

They will go above every external door.

They will only ever be illuminated when:-

1. The emergency light is under test – very rare
2. When the local lighting circuit (nearest to the relevant door) has lost power – again very rare

They will be off virtually 99.9% of the time

Regards,

[redacted]

TeDS (Electrical) Ltd
St Mark's House, 29 West Street, Dukinfield, Cheshire, SK16 4PL

This e-mail, its attachments, and the information they contain, are confidential, may be privileged and are solely for the use of the intended recipient(s). If you have received this e-mail in error please notify us immediately, and delete this communication. You should not copy it for purpose, or disclose its contents to any other person. TeDS (Electrical) Ltd monitors emails to ensure its systems operate effectively and to minimise the risk of viruses. If you or your Company do not wish to receive future e-mails from TeDS (Electrical) Ltd then please email database@tedsltd.co.uk and you/your Companies details will be removed from our databases and your domain will be blocked until further notice.

TeDS (Electrical) Ltd is a company registered in England and Wales under number 08095257.
Registered office: St Mark's House, 29 West Street, Dukinfield, Cheshire, SK16 4PL