A0



TYPICAL CORNICE
MAIN STAIRCASE



TYPICAL SKIRTING
MAIN STAIRCASE



TYPICAL DADO RAIL
MAIN STAIRCASE

FIRE DAMAGED AREA



TYPICAL SKIRTING
CORRIDOR/CIRCULATION



TYPICAL CORNICE
CORRIDOR/CIRCULATION



TYPICAL CORNICE
MUSIC ROOM



TYPICAL SKIRTING
MUSIC ROOM



TYPICAL DADO RAIL
MUSIC ROOM

FIRE DAMAGED AREA



TYPICAL CORNICE
SALOON



TYPICAL SKIRTING
SALOON



TYPICAL DADO RAIL
SALOON

Continued Below

Continued From Above



TYPICAL CORNICE
LIBRARY




TYPICAL SKIRTING
LIBRARY



TYPICAL DADO RAIL
LIBRARY




SIDE VIEW





SIDE VIEW MICC BARE CABLE IN FRONT OF SKIRTING BOARD- IF APPROVED BY CONSERVATION OFFICER INCLUDE FOR SUFACE CLIPPING ON SKIRTING BOARD




FRONT VIEW




FRONT VIEW MICC BARE CABLE IN FRONT OF SKIRTING BOARD - IF APPROVED BY CONSERVATION OFFICER INCLUDE FOR SURFACE CLIPPING ON SKIRTING BOARD



FRONT ELEVATION





FRONT ELEVATION OF MICC BARE CABLE CLIPPED FOR SHORT LENGTH ABOVE THE SKIRTING BOARD


THE CONTRACTOR SHALL NOTE THAT THE FINAL DETAILS IN RELATION TO ASSOCIATED BUILDERS WORK SHALL BE AGREED WITH THE PRINCIPAL CONTRACTOR











**GENERAL NOTES**

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE ECS BUILDING ENGINEERING SPECIFICATION.
2. THIS DRAWING IS INDICATIVE AND IS INTENDED TO HIGHLIGHT THE GENERAL EXTENT OF WORK ON ELECTRICAL SERVICES. THE CONTRACTOR SHALL NOTE THAT THIS DRAWING IS NOT BE USED FOR CONSTRUCTION PURPOSES. THE CONTRACTOR SHALL: INCLUDE TO PRODUCE THEIR OWN WORKING DRAWINGS. TAKE OFF FROM THESE DRAWINGS. INDICATE THE PROVISION OF BUILDERS WORKS AND FINALLY THE INSTALLATION OF ALL SERVICES.
3. THE CONTRACTOR SHALL NOTE THIS DRAWING HAS BEEN PRODUCED USING LIMITED SITE SURVEY INFORMATION. THE CONTRACTOR SHALL INCLUDE FOR CARRYING OUT AN INTRUSIVE SURVEY AND TO PRODUCE DRAWINGS THAT REFLECT THE INSTALLATION.
4. ALL EQUIPMENT SHALL BE INSTALLED SO AS TO MAINTAIN SPATIAL REQUIREMENTS TO FACILITATE SAFE ACCESS AND COMPLY IN LINE WITH MANUFACTURERS RECOMMENDATIONS AND GOOD PRACTICE GUIDES.
5. ALL EQUIPMENT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURERS GUIDELINES.
6. DO NOT SCALE FROM THIS DRAWING.
7. ALL DETAILS ARE APPLICABLE TO EVERY DRAWING UNLESS INDICATED OTHERWISE.
8. THE CONTRACTOR SHALL INCLUDE TO IDENTIFY THE COMPLETE EXISTING ELECTRICAL INSTALLATION, EXTEND AND ADAPT AS REQUIRED TO THE PROPOSED WORKS

**LEGEND**

| SYMBOL | DESCRIPTION |
|---|---|
| | CABLE/CONTAINMENT IN FRONT OF CORNICE |
| | CABLE/CONTAINMENT IN FRONT OF SKIRTING |
| | FLOORBOARDS THAT HAVE PREVIOUSLY BEEN REMOVED AND ARE TO BE REMOVED AND REPLACED |
| | FLOORBOARDS THAT HAVE NOT PREVIOUSLY BEEN REMOVED THAT ARE TO BE REMOVED AND REPLACED |
| | EXISTING BOARDS TAKEN UP NOT SHOWN ON THIS TENDER DOCUMENT |
| | NEW BOARDS TAKEN UP TO GAIN ACCESS |
| | EXISTING DAMAGED SKIRTINGS TO BE REPAIRED |
| | REMOVE ARCHITRAVE (WINDOW) FOR EW |

THE CONTRACTOR SHALL NOTE THAT THE FINAL DETAILS IN RELATION TO ASSOCIATED BUILDERS WORK SHALL BE AGREED WITH THE PRINCIPAL CONTRACTOR

SAMPLE PHOTOGRAPHS OF CORNICE, FLOORBOARDS, ARCHITRAVE ETC

| | | | |
|---|---|---|---|
| AF2 | CONSTRUCTION ISSUE. | G.M. | June '26 |
| AF1 | CONSTRUCTION ISSUE. | G.M. | Jan '26 |
| Rev. | Description | Revised By | Date |

STATUS

AS FITTED


ecs CONSULTANTS
Building Services Consulting Engineers
148 Stockport Road
Cheadle, Cheshire. SK8 2DP
Tel. 0161 283 2662 Fax 0161 282 8825
Web Site: www.ecs-ecs.co.uk Email: sales@ecs-ecs.co.uk


| JOB NO. | DRAWING NO. | COMPUTER FILE | REVISION |
|---|---|---|---|
| 24/100 | 24/100/BW/01 | 24_100_BW_01 | AF2 |
| DATE | SCALE | DRAWN | CHECKED |
| Jan. 2026 | 1:100 @ A0 | P.H. | G.M. |

JOB TITLE
Heaton Park Hall

DRAWING TITLE
Ground Floor
Building Enabling Works
MCC Planners Information

CAD original - not to be modified by hand