OUR TOWN HALL PROJECT

Document Name: Reco-Air Unit Schedule

Document Ref: OTH-HAK-TH-GF-SCH-V-0002

Status: S4 – Suitable for Construction

Document Type: Schedules

Revision History:

REV.	DATE	DESCRIPTION OF CHANGE
P01	23/08/2019	Issue For Comment
P02	30/08/2019	Issue For Tender
P03	21/02/2023	Issued For Construction

Reco-Air Unit Schedule

Project :	**Manchester Town Hall Catering Works**	Project No :	**50801**	Schedule Ref :	**OTH-HAK-TH-GF-SCH-V-0002**
		Area Served :	**Ground Floor**	Purpose of Issue :	**Suitable for Construction**
		Issue Date :	**21 February 2023**	Revision :	**P03**

RECO-01 Details		
Manufacturer		Reco-Air or Equal and Approved
Model		RA2.0
Quanity		1
Reference		RECO-01
Unit Size	(mm)	1430 x 3580 x 895
Air Flowrate	(m^3/s)	1.80
Static Pressure	Pa	250
Fan Size	(mm)	450Ø
Unit Weight	kg	1020

General Specification

- Unit Shall be Void Mounted.
- Unit Shall be Complete With UL Control Panel.

Revision	Revision Notes	Revision Date
P01	Tender - For Comment	23 August 2019
P02	Issue For Tender	30 August 2019
P03	Suitable for Construction	21 February 2023