1509-1513 Ashton Old Road, Openshaw, Manchester, M11 1NF
NP-014341
Validation Noise Impact Assessment

KMM HOMES

Following the noise impact assessment completed by Nova Acoustics and the subsequent recommendations I can confirm, with evidence, that all recommendations have been implemented on the 3 houses at "The Grove". The below remediation measure have been installed;

1. MVHR Silencers
2. Acoustic Trickle vents 42Db in an open position

[redacted]

MAX GALE 28/07/26