Serial No.
B6019107

LANDLORD/HOME OWNER GAS SAFETY RECORD

This form allows the recording of the results of the required checks as defined by the Gas Safety (Installation and Use) Regulations.
The information recorded on this form does not confirm that the installation was installed by a Gas Safe registered engineer or that the installation complies with any relevant Building Regulations.
Chimney systems were inspected visually and checked for satisfactory evacuation of products of combustion, a detailed internal inspection of the chimney system has not been carried out.

Registered Business Details REG NO 144949
Gas operative NEIL JOHNSON (Print name)
Operative licence No. 3784330
Company ALLEGRA SERVICES LTD
Address 850 GARRATT AVENUE
MORTON MANSOM
Postcode ST4 3EA Tel No.

Job Address
Name (Mr/Mrs/Miss/Ms)
Address FLAT 19
DAVID MAIN COURT
Postcode
Tel No.

Landlord (or where appropriate their agent)
Name (Mr/Mrs/Miss/Ms)
Address
Postcode Tel No.
Number of appliances tested 2

APPLIANCE DETAILS

	Location	Appliance type	Make	Model	Landlord's appliance Yes/No/NA	Appliance inspected Yes/No	Flue type OF/RS/FL
1	KITCHEN	CH3	WORCESTER	G.STAR	YES	YES	RS
2	KITCHEN	CH2	VAILLANT	HOB	YES	YES	OF
3							
4							

INSPECTION DETAILS

	Operating pressure in mbar or heat input in kW	Initial combustion analyser reading (if applicable)	Final combustion analyser reading (if applicable)	Safety device(s) correct operation Yes/No/NA	Ventilation provision satisfactory Yes/No	Visual condition of chimney/termination satisfactory Yes/No/NA	Flue performance checks Pass/Fail/NA	Appliance serviced Yes/No	**Appliance safe to use Yes/No**
1	19mb	0.0004	0.0004	YES	YES	YES	PASS	NO	YES
2	24kW			YES	YES	NA	NA	NO	YES
3									
4									

AUDIBLE CO ALARM

Approved CO alarm fitted Yes/No/NA	Is CO alarm in date Yes/No/NA	Testing of CO alarm satisfactory Yes/No/NA

DEFECT(S) IDENTIFIED

		If Warning/Advice Notice issued insert serial No*
1		
2		
3		
4		

REMEDIAL ACTION TAKEN

1	
2	
3	
4	

Gas installation pipework satisfactory visual inspection Yes/No YES
Emergency Control Valve (ECV) accessible Yes/No YES
Satisfactory gas tightness test Yes/No/NA YES
Protective equipotential bonding satisfactory Yes/No YES

NEXT SAFETY CHECK DUE WITHIN 12 MONTHS

This Safety Record issued by: Signed [redacted]
Print Name: N. JOHNSON
Received by: Signed *Tenant/Landlord/Agent/Home Owner*
Date appliance(s)/chimney(s) checked: 3.6.16

Key Top Copy – Landlord/Managing Agent/Home Owner **Green Copy** – Tenant **Yellow Copy** – Registered Business * Refer to separate Warning/Advice Notice To re-order quote Ref. CP12

Copyright © CORGIdirect July 2014. The format and layout of this document may not be reproduced in any manner without prior written consent.

Gas Safe is a registered trade mark of the HSE and is used under licence.