

## 137226 - Plots C & E Great Jackson St - louveres

Lucy Harrison

Tue 25/07/2023 16:52

To: Poole, Rachel J <rpoole@deloitte.co.uk>

Cc: Nevin, Danielle <dnevin@deloitte.co.uk>; Scrafton, Eleanor <escrafton@deloitte.co.uk>

Hi Rachel

Further to the above application, I note that most of the ground and first floor elevations have louveres above the glazing. Please would you look at amending this so that provision is made for internal ducting in risers that terminate at roof level to accommodate any extract requirements for the ground and first floor areas. We want to avoid having louveres within/above the glazed frontages as they don't look great.

Please would you also look at replacing/screening the louveres around the waste storage and substation/plant areas with more decorative perforated panels (eg to match those used for purge vents on the upper floors of the building).

Many thanks

Lucy

Lucy Harrison  
Senior Planner  
Development Management Central Core  
Planning, Building Control & Licensing  
Growth & Development Directorate  
Manchester City Council

Tel: (External) 0161 234 5795

Tel: (Internal) 800 35795

Fax: 0161 274 7000

Textphone: 0161 234 4505

email: [lucy.harrison@manchester.gov.uk](mailto:lucy.harrison@manchester.gov.uk)

<http://www.manchester.gov.uk>

Postal Address: Planning, Manchester City Council, Floor 6, Town Hall Extension, PO Box 532, Town Hall Manchester M60 2LA (Sat Nav System use M2 5DB)

\*NB My days of work are Monday, Tuesday, Wednesday and Thursday\*