

RE:137226 - Part of Plot C and Plot E, Great Jackson Street

Tue 27/06/2023 17:52

To: Poole, Rachel J [REDACTED]; Lucy Harrison [REDACTED]

Cc: [REDACTED] Britton, Ed [REDACTED]

Good afternoon Lucy,

As mentioned in my colleague Rachel's earlier email, please find details below that outline how 10% of the apartments can be adapted to comply with DFA2.

Plot D - Adaptable apartments to meet Approved Document and DFA2

All apartments have been designed to meet requirement M4 (1): Visitable dwellings of Approved Document M.

In addition, a number of apartments have been designed so that they are capable of being adapted over time to meet the changing needs of occupants, including those of some older and disabled people, and meet the optional requirements outlined in M4(2): 'accessible and adaptable dwellings.

Drawing nos Z1-SHP-F900-PL-XX-B5D801 and 802 identify the apartments which are capable of being adapted in line with the requirements of AD M4(2). These total 65no, just over 10% of the total no of apartments.

The main adaption required centres around the need to provide a level access shower. The minimum feasible depth for a shower is 75mm and the apartments can be adapted to provide a 1:21 incline to allow step free wheelchair access into the shower room. There is also scope within the apartment dimensions to increase the overall dimensions for the en suite shower room to facilitate a 1500mm turning circle. As an alternative to the ramp a track hoist could be provided, fixed directly to the concrete soffit above the plasterboard ceiling.

The above apartments have also been designed so that they can be adapted to adhere to additional requirements within Design for Access 2 (DFA2).

However, there are two areas where the adapted apartment will only partially comply with DFA2.

- The communal corridors, leading from the lifts to the apartment entrance are generally 2.1m, which is in excess of the DFA 2 requirement of 1.8m. Short lengths of corridor leading to apartment doors are 1.5m wide. This is considered acceptable on the basis that all corridors are more generous than the requirements of Approved Document M.
- DFA2 suggests that at least one accessible bedroom should be provided with dimensions of 4m x 4m. The apartment can be adapted to provide an accessible bedroom which has a total floor area which is very close to that achieved within a 4m x 4m room, although only one of the overall dimensions exceeds 4m.

This approach is consistent with that taken with all previously approved Renaker Build Ltd schemes over recent years.

I trust the above provides sufficient detail.

Many thanks,

Pronouns: she / her / hers

Senior Associate | FA - Real Assets Advisory | Deloitte LLP

The Hanover Building, Corporation Street, Manchester, M4 4AH
escrafton@deloitte.co.uk | www.deloitte.co.uk

From: Poole, Rachel J [REDACTED]
Sent: 27 June 2023 14:06
To: Lucy Harrison [REDACTED]
Cc: [REDACTED] Britton, Ed
Subject: RE: 137226 - Part of Plot C and Plot E, Great Jackson Street

Hi Lucy

Please can I confirm which application the below comments relate to? The description in the e-mail relates to Part Plot C and Plot E, which we refer to as Crown Street Phase 3. However, the questions include the office block which is in the Plot D application.

We have responded to the below points in relation to Plot D as included in the invalidation letter. In addition, my colleague will provide some more detail this afternoon on DFA2.

Many thanks

Rachel

Rachel Poole
Assistant Director | FA - Real Assets Advisory | Deloitte LLP

[REDACTED]
www.deloitte.co.uk

Please note Thursday is my non work day

From: Lucy Harrison [REDACTED]
Sent: 26 June 2023 14:15
To: Poole, Rachel J [REDACTED]
Cc: [REDACTED]
Subject: [EXT] 137226 - Part of Plot C and Plot E, Great Jackson Street

Hi Rachel

Further to the invalid letter you should have received for the above application, please would you also provide the following information (this won't hold up validation but it would be best to have this information before publicity/consultations are carried out):


1. Are green rooves/planting proposed for the office building and the tower level 02? If so, please annotate this on the roof plan drawing and provide a landscape planting plan.
2. Full details of Design for Access 2 (DFA2) accessible apartments showing that at least 10% of the residential units are DFA2 compliant.

Many thanks

Lucy

Lucy Harrison
Senior Planner
Development Management Central Core

Planning, Building Control & Licensing
Growth & Development Directorate
Manchester City Council



<http://www.manchester.gov.uk>

Postal Address: Planning, Manchester City Council, Floor 6, Town Hall Extension, PO Box 532, Town Hall Manchester M60 2LA (Sat Nav System use M2 5DB)

NB My days of work are Monday, Tuesday, Wednesday and Thursday

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed.

If you have received this email in error, please notify the system manager.

The full text of the Council's email disclaimer is available at: www.manchester.gov.uk/emaildisclaimer.

Your personal data is very important to us. Please refer to our privacy notice at: www.manchester.gov.uk/privacy for further information.

This footnote also confirms that this email message has been swept for the presence of computer viruses.

IMPORTANT NOTICE

This communication is from Deloitte LLP, a limited liability partnership registered in England and Wales with registered number OC303675. Its registered office is 1 New Street Square, London EC4A 3HQ, United Kingdom. Deloitte LLP is the United Kingdom affiliate of Deloitte NSE LLP, a member firm of Deloitte Touche Tohmatsu Limited, a UK private company limited by guarantee ("DTTL"). DTTL and each of its member firms are legally separate and independent entities. DTTL and Deloitte NSE LLP do not provide services to clients. Please see www.deloitte.co.uk/about to learn more about our global network of member firms. For details of our professional regulation please see [Regulators](#).

This communication contains information which is confidential and may also be privileged. It is for the exclusive use of the intended recipient(s). If you are not the intended recipient(s), please notify datasecurityreport@deloitte.co.uk and destroy this message immediately. Email communications cannot be guaranteed to be secure or free from error or viruses. All emails sent to or from a @deloitte.co.uk email account are securely archived and stored by an external supplier within the European Union.

You can understand more about how we collect and use (process) your personal information in our [Privacy Notice](#).

Deloitte LLP does not accept any liability for use of or reliance on the contents of this email by any person save by the intended recipient(s) to the extent agreed in a Deloitte LLP engagement contract.

Opinions, conclusions and other information in this email which have not been delivered by way of the business of Deloitte LLP are neither given nor endorsed by it.